

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS, DELHI FIRE SERVICE, NEW DELHI-110001  
Fax: 23412593, Email: director.dlfire@nic.in, Tel:- 011-23414000

No.F6/DFS/MS/2016/ 52/946

Dated: 07/06/16

FIRE SAFETY CERTIFICATE

Certified that the Natya Tarangini, located at Plot No. 49-52, Pushp Vihar, Sec-IV, M B Road, New Delhi. Comprised of basement, ground plus fourth upper floors (The Management closed & sealed fourth floor "an affidavit submitted") owned/occupied by Natya Tarangini was granted FSC by this department vide letter No. F6/DFS/MS/2013/124 dated:- 26/03/2013. The premises was re-inspected by the officer concerned of this department on 30/05/2016 in the presence of Mrs. Kaushalya Reddy and observed that the said premises have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class **Group-B, "Educational Building"** with effect from 07/06/16...for a period of **three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules 2010.

Issued ..07/06/16.....at New Delhi by.

  
(Atul Garg)  
Chief Fire Officer

AC  
h

Copy to:-

Mrs. Kaushalya Reddy  
Natya Tarangini,  
Plot No. 49-52, Pushp Vihar, Sec-IV,  
M B Road, New Delhi.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
2. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
5. The basement shall be used as per the provisions of BBL.
6. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form "J" [ sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)

**INSPECTION REPORT**

1. Name & address of the building: - Natya Tarangini, Plot No. 49-52, Pushp Vihar, Sec-IV, M B Road, New Delhi.
2. Type of occupancy:- Educational Building "B"
3. Type of case: - Renewal
4. Details of previous NOC: - F6/DFS/MS/2013/124 dated :- 26/03/2013
5. Fire safety directives No.- F6/DFS/MS/BP/2006/600 dated 10/03/2006
6. Date of inspection:- 30/05/2016
7. Name of the inspecting officer:- Dharampal Bhardwaj, Dy.CFO, D.B.Mukherjee, A.D.O.(BCP)
8. Name & designation of officer From the building side: - Mrs. Kaushalya Reddy
9. Year of construction:- 2013
10. Applicant's letter No:- Nil dated 26/04/2016
11. Composition of building; - Basement & Ground Plus Four Upper Floors.  
(Fourth Floor Sealed Affidavit Submit)

Sl. No	Minimum Standards on fire Prevention and fire safety U/R 33	BBL/NBC Requirement	Provided at site	Remarks MR/NMR
<b>1.</b>	<b>Access to Building</b>			
	1) Road width	12mtr	Provided	MR
	2) Gate width	5mtr	Provided	MR
	3) Width of internal road	N/A	N/A	N/A
<b>2.</b>	<b>Number, Width Type &amp; Arrangement of Exits</b>			
	A. Number of staircases			
	1. Upper floors	02nos	Provided	MR
	2. Basements	02nos	Provided	MR
	B. Width of staircase			
	1. Upper floors	1.5 Mtr	1.50mtr & 1.25mtr	MR
	2. Basements	1.5 Mtr	1.50mtr & 2.37mtr	MR
	C. Protection of exits			
	1. Fire check door	Required	Provided	MR
	2. Pressurization	N/A	N/A	N/A
	D. No. of continuous staircase to terrace	01nos	01 nos.	MR
	E. Width of corridor	N/A	N/A	N/A
	F. Door size	1mtr	Provided	MR
<b>3.</b>	<b>Compartmentation</b>			
	1) Fire check door	N/A	N/A	N/A
	2) Sealing of electrical shafts	Required	Provided	MR
	3) Fire rating of shaft door	Required	Provided	MR
	4) Water curtain	N/A	N/A	N/A
	5) Fire Dampers	N/A	N/A	N/A
<b>4.</b>	<b>Smoke Management System</b>			
	1) Basements	30 a/c per hour	Exhaust Fan	MR
	2) Upper floors	12 a/c per hour	Natural Ventilation	MR
<b>5.</b>	<b>Fire Extinguishers</b>			
	1) Total numbers	ISI Marked	12 Nos. Provided	MR
	2) Types		ABC, Co2	MR
	3) ISI marking		Yes	MR
<b>6.</b>	<b>First-Aid Hose Reel</b>			
	1) Total number of each floor	01 no.	Provided at each floor	MR
	2) Length of hose reel hose	30 m	Provided	MR
	3) Nozzle diameter	5 mm	Provided	MR

→


<b>7.</b>	<b>Automatic Fire Detection &amp; Alarming System</b>			
	1) Type of detectors	Required	Smoke Provided	MR
	2) Location of main panel	Required	Ground Floor	MR
	3) Location of repeater panel	N/A	N/A	N/A
	4) Alternate source of power	Required	Provided	MR
	5) Hooter's Location	Required	Provided at staircase	MR
<b>8.</b>	<b>MOEFA</b>	Required	Provided	MR
<b>9.</b>	<b>Public Address System</b>	Required	Provided	MR
<b>10.</b>	<b>Automatic Sprinkler System</b>			
	1) Basement	Required	Provided	MR
	2) Upper floors	N/A	N/A	N/A
	3) Sprinkler above false ceiling	N/A	N/A	N/A
<b>11.</b>	<b>Internal Hydrants</b>			
	1) Size of riser/down-comer	100mm	Provided	MR
	2) Number of hydrants per floor	1nos	Provided	MR
	3) Hose box	1nos	Provided	MR
<b>12.</b>	<b>Yard Hydrants</b>			
	1) Total number of hydrants	01no	Provided	MR
	2) Hose box	01no	Provided	MR
<b>13.</b>	<b>Pumping Arrangement</b>			
	<b>1) Ground level</b>	N/A	N/A	N/A
	a) Discharge of main pump	N/A	N/A	N/A
	b) Head of main pump	N/A	N/A	N/A
	c) Number of main pump	N/A	N/A	N/A
	d) Jockey pump out put	N/A	N/A	N/A
	e) Jockey pump head	N/A	N/A	N/A
	f) Stand by pump output	N/A	N/A	N/A
	g) Stand by pump head	N/A	N/A	N/A
	h) Auto starting/Manual stopping	N/A	N/A	N/A
	<b>2) Terrace level</b>			
	a) Discharge of pump	900LPM	900LPM	MR
	b) Head of pump	40mtr	40 mtr	MR
	c) Power supply	Required	Provided	MR
	d) Auto starting of pump	Required	Provided	MR
<b>14.</b>	<b>Captive Water Storage for Fire Fighting</b>			
	1) Underground tank capacity	N/A	N/A	N/A
	a) Draw-off connection	N/A	N/A	N/A
	b) Fire service inlet	Required	Provided	MR
	c) Access to tank	N/A	N/A	N/A
	d) Over head tank capacity	25,000ltr	25,000 Ltrs.	MR
<b>15.</b>	<b>Exit Signage.</b>	Required	Provided	MR
<b>16.</b>	<b>Provision of Lifts.</b>			
	a) Pressurization of lift shaft	Required	Provided	MR
	b) Pressurization of lift lobby	N/A	N/A	N/A
	c) Communication in lift car	Required	Provided	MR
	d) Fireman's switch	Required	Provided	MR
	e) Lift signage	Required	Provided	MR
<b>17.</b>	<b>Standby Power Supply</b>	Required	Provided DG Set	MR
<b>18.</b>	<b>Refuge Area</b>			
	Total area location	N/A	N/A	N/A

19.	<b>Fire Control Room</b>	Required	Provided	MR
	a) Detector system panel	N/A	N/A	N/A
	b) Flow switch panel	Required	Provided	MR
	c) PA system panel	Required	Provided	MR
	d) Battery backup	N/A	N/A	N/A
	e) Building floor plan	N/A	N/A	N/A
20.	<b>Special Fire Protection System for Protection of special Risk, if any:</b>			N/A

The fire system provided in the building were checked and found functional at the time of inspection.

In view of the compliance of the minimum standards on fire prevention and fire safety measures as required under the rules the FSC issued vide letter No F6/DFS/MS/2013/124 dated: - 26/03/2013, renewal under rules 35 of the Delhi Fire Service Rules 2010 is recommended to grant fire safety certificate.

Accordingly DFA is put up for perusal and signature pl.

  
26/6/16

  
11/6/2016

Signature of the Inspecting Officer  
Name: Dharampal Bhardwaj  
Designation: - Dy.CFO

Signature of the Inspecting Officer  
Name: D.B. Mukherjee  
Designation: - Assitt. Divisional. Officer (BCP)

~~CFO Atul Garg~~  
~~2/6/16~~

~~DIRECTOR~~  
~~2/6/16~~