

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE  
NEW DELHI- 110 001


No. F6/DPS/MS/2016/1102/954

Dated: 8/6/16

**FIRE SAFETY CERTIFICATE**

Certified that M/s Singh Service Centre at FC-8, Loni Road, Shahdara, Delhi-110094, owned/occupied by Singh Service Centre was granted NOC by this department vide letter No.-F.5/(3A)/DFS/2003/451 dated 26/06/2003. The premises was re-inspected by the officer concerned of this department on 01/06/2016 in the presence of Mr. Mani Bhushan, Manager and found that the Retail Outlet (Petrol Pump) have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules 2010 and that the premises is fit for occupancy class Hazardous Group J with effect from 8/6/16..... for a period of **three** years in accordance with the rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010, printed overleaf.

Issued on 8/6/16..... at New Delhi by

  
**(Vipin Kantal)**  
Chief Fire Officer  
Delhi Fire Service

To,  
The Manager,  
Singh Service Centre, (Petrol Pump),  
FC-8, Loni Road, Shahdara, Delhi-110094

Copy to:-  
The Chief Divisional Manager,  
I.O.C. Co. Ltd.,  
Second floor, World Trade Centre,  
Babar Road Connaught Place,, New Delhi-110001

o/c



## Condition

1. No trade susceptible to cause ignition to Petroleum vapours by generating heat, mechanical/electrical spark should be allowed within the licensed premises.
2. Overhead electrical cable and loose/naked wiring shall not be allowed across the licensed premises. The electrical equipments, electrical gadgets and fitting in the premises shall conform to hazardous area classification for that purpose and be of a type approved by the CCE.
3. In premises "No Smoking" signs board both in Hindi and English shall be displayed in such a manner as to be easily readable by all people.
4. All fire protection arrangements shall be maintained.
5. Nothing contravention of the explosive Act. 1884 and Rules their under 1983, and static and mobile pressure vessels (unfired) Rules 1981 as modified from time to time.
6. All comments/directions of the Chief Inspector of Explosives should always be permitted and followed.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
8. The owner / occupier shall apply for renewal of this Fire Safety Certificate of the Director in Form 'J' [sub rule (1) of rule (37)] along with a copy of this Certificate, Six Months prior to its expiry

1. Name & address of the building : Singh Service Centre, (Petrol Pump),  
FC-8, Loni Road, Shahdara, Delhi-110094
2. Building is comprised of : N/A
3. Type of Occupancy : Hazardous Group J
4. Type of Case : **Renewal**
5. Details of Previous NOC letter : F.5/(3A)/DFS/2003/451 dated-26/06/2003
6. Fire Safety direction letter No : N/A
7. Date of Inspection : 01/05/2016
8. Name of the Inspecting officers : ADO Vijay Bahadur
9. Name and designation of Officer from the building side : Mr. Mani Bhushan (Manager)
10. Year of Construction : 1999
11. Applicant's letter No : Letter No.-Nil, Dated-16/05/2016


Sr. No.	Minimum Standards on Fire Prevention and Fire Safety U/R33	Existing Requirement	Provided at Site	Remarks MR/NMR
01	Access to Building			
	• Road width	12 mtr.	15 mtr.	<b>MR</b>
	• Gate width	4.50 mtr.	06 mtr.	<b>MR</b>
	• Width of internal road	N/A	N/A	N/A
02	Number, Width, Type and Arrangement of Exits			
	a. Number of Staircases			
	• Upper floor	N/A	N/A	N/A
	• Basement	N/A	N/A	N/A
	b. Width of Staircases			
	• Upper floor	N/A	N/A	N/A
	• Basement	N/A	N/A	N/A
	c. Protection of Exits			
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	d. No. of Continuous Staircases to Terrace	N/A	N/A	N/A
	e. Width of Corridor	N/A	N/A	N/A
	f. Door Size	N/A	N/A	N/A
03	Compartmentation.			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire rating of shaft door	N/A	N/A	N/A
	• Water curtain	N/A	N/A	N/A
	• Fire dampers	N/A	N/A	N/A
04	Smoke Management System.			
	• Basement	N/A	N/A	N/A
	• Upper floor	N/A	N/A	N/A
05.	Fire Extinguishers			
	• Total numbers	06 nos.	08 nos.	<b>MR</b>
	• types	ABC/Foam	ABC/Foam	<b>MR</b>
	• IS marking	ISI marked	ISI marked	<b>MR</b>

06	First-Aid-Hose Reels.			
	• Total numbers on each floor	N/A	N/A	N/A
	• Length of hose reel hose	N/A	N/A	N/A
	• Nozzle diameter	N/A	N/A	N/A
07	Automatic Fire Detection and Alarming System.			
	• Type of detectors	N/A	N/A	N/A
	• Location of main panel	N/A	N/A	N/A
	• Location of repeater panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooter's location	N/A	N/A	N/A
08	MOEFA			
		N/A	N/A	N/A
09	Public Address System.			
		N/A	N/A	N/A
10	Automatic Sprinkler System.			
	• Basement	N/A	N/A	N/A
	• upper floor	N/A	N/A	N/A
	• sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants			
	• size of riser/down-comer	N/A	N/A	N/A
	• Number of hydrants per floor	N/A	N/A	N/A
	• Hose box	N/A	N/A	N/A
12	Yard Hydrants.			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose box	N/A	N/A	N/A
13	Pumping Arrangements.			
	➤ Ground Level			
	• Discharge of main pump	N/A	N/A	N/A
	• Head of main pump	N/A	N/A	N/A
	• Number of main pumps	N/A	N/A	N/A
	• Jockey pump out put	N/A	N/A	N/A
	• Jockey pump head	N/A	N/A	N/A
	• Standby pump out put	N/A	N/A	N/A
	• Standby pump head	N/A	N/A	N/A
	• Auto starting/manual stopping	N/A	N/A	N/A
	• Pump house access	N/A	N/A	N/A
	➤ Terrace Level			
	• Discharge of pump	N/A	N/A	N/A
	• Head of the pump	N/A	N/A	N/A
	• Power supply	N/A	N/A	N/A
	• Auto starting of pump	N/A	N/A	N/A
14	Captive Water Storage for Fire Fighting.			
	• Underground tank capacity	N/A	N/A	N/A
	• Draw-off connection	N/A	N/A	N/A
	• Fire service inlet	N/A	N/A	N/A
	• Access to tank	N/A	N/A	N/A
	• Overhead tank capacity	N/A	N/A	N/A
15	Exit Signage.			
		N/A	N/A	N/A

16	Provision of Lifts.			
	<ul style="list-style-type: none"> <li>• Pressurization of lift shaft</li> <li>• Pressurization of lift lobby</li> <li>• Communication in lift car</li> <li>• Firemen's grounding switch</li> <li>• Lift signage</li> </ul>	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
17	Standby power supply	N/A	N/A	N/A
18	Refuge Area.			
	<ul style="list-style-type: none"> <li>• Total area</li> <li>• Location</li> </ul>	N/A	N/A	N/A
		N/A	N/A	N/A
19	Fire Control Room			
	<ul style="list-style-type: none"> <li>• Detector system panel</li> <li>• Flow switch panel</li> <li>• PA system panel</li> <li>• Battery backup</li> <li>• Building floor plans</li> </ul>	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of Special Risks, if Any:	N/A	N/A	N/A

The fire protection systems i.e. fire extinguishers provided at petrol pump were checked and found functional at the time of inspection. "No Smoking" sign board both in Hindi & English displayed and fire bucket filled with dry & loose sand were found provided. The Petrol Pump was issued NOC earlier vide letter No.-F.5/(3A)/DFS/2003/451 dated-26/06/2003

Keeping in view the deemed compliance of the minimum standards on fire prevention and fire safety required under rule 35 of the Delhi Fire Service Rule 2010, it is recommended to grant Fire Safety Certificate.

  
21/6/16


Signature of the Inspecting Officer  
Name- Vijay Bahadur  
Designation- A.D.O (T.Pur)


D.C.F.O (V.S.)

Submitted for approval please.

Dy C.F.O (A.D.O.)

Vingh  
31/6/16

  
3/6

  
6/6