

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE, NEW DELHI - 110001

No.F6/DFS/MS/Cinema/2016/ 960

Dated : 8/6/16

FIRE SAFETY CERTIFICATE

Certified that the M/S Delite Diamond & Delite Theatre with Delite Restaurant having 91 seats no cooking located at 1st floor, Delite Theatre Building, Asaf Ali Road, New Delhi comprised of B + Ground + 04 upper floor was granted NOC vide letter No. F6/DFS/MS/2015/1289 dated 17/06/2015. The Cinema building was inspected by the officers concerned of this department on 07-05-2016 along with Sh. R. K. Mehrotra (GM) and found that the Cinema building have deemed complied with the fire prevention and fire safety requirements in accordance with the rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and that the building is fit for occupancy Group D " Assembly Building" with effect from 19/05/16 -----for a period of three years.

Issued on 8/6/16 -----at New Delhi by



(Rajesh Panwar)
Dy. Chief Fire Officer
Delhi Fire Service
Ph. 011-23412025

Copy to :-

1. The District Magistrate (Central),
Old Employment Exchange Building, Daryaganj, New Delhi.
2. Dy. Health Officer,
City Zone,
NDMC, Car parking Asif Ali Road, Delhi -110002.
3. The Manager,
M/S Delite Diamond & Delite Theatre located at Delite Theatre Building, 3rd floor, Asaf Ali Road, New Delhi

Condition for the validity of fire safety certificate

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the used and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipment shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. The clarification with regards electrical installation, ventilation, structure stability set back areas, occupancy and constructional deviation in building etc may be got verified from the authorities concerned.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in

INSPECTION REPORT

1. Name & address of the building : M/S Delite Diamond & Delite Theatre with Delite Restaurant having 91 seats no cooking at 1st floor Delite Theatre Building, Asaf Ali Road, New Delhi
2. Type of occupancy : Assembly Building (B + Gr. + 04 Upper floor)
3. Type of case:- : Renewal
4. Details of previous NOC : F6/DFS/MS/2015/1289 dated 17/06/15
5. Fire safety directives No. : F6/DFS/MS/BP/2006/469 dated 24/02/06
6. Date of inspection:- : 07/05/16
7. Name of the inspecting officer : Sh. M.K. Sharma ADO/CC
8. Name & designation of officer
From the building side : Sh. R.K. Mehrotra (GM)
9. Year of construction : 2006
10. Applicant's letter No : Nil Dated 03/05/2016

Old Case

S.No.	Minimum Standards on fire Prevention and fire safety U/R 33	Requirement Existing	Provided at site	Remarks MR/NMR
1.	Access to Building			
	1) Road width	09 mtr.	15 Mtr.	MR
	2) Gate width	On road	Provided	MR
	3) Width of internal road	NA	NA	NA
2.	Number, Width Type & Arrangement of Exits			
	A. Number of staircases			
	1. Upper floors	04 Nos.	04 Nos.	MR
	2. Basements	02 Nos.	02 Nos.	MR
	B. Width of staircase			
	1. Upper floors	1.2 mtr.	1.65 mtr. each	MR
	2. Basements	1 mtr.	1.25 mtr. each	MR
	C. Protection of exits			
	1. Fire check door	Required	Provided	MR
	2. Pressurization	NA	NA	NA
	D. No. of continuous staircase to terrace	02 No	02 No	MR
	E. Width of corridor	1 mtr.	1.25 mtr.	MR
	F. Door size	1 Mtr.	1 Mtr.	MR
3.	Compartmentation			
	1) Fire check door	Required	Provided	MR
	2) Sealing of electrical shafts	Required	Provided	MR
	3) Fire rating of shaft door	NA	NA	NA
	4) Water curtain	NA	NA	NA
	5) Fire Dampers	NA	NA	NA
4.	Smoke Management System			
	1) Basements	30 ACPH	Provided	MR
	2) Upper floors	12 ACPH	Natural	MR
5.	Fire Extinguishers			
	1) Total numbers	72 Nos.	72 Nos.	MR
	2) Types	ABC, CO ₂ & W. CO ₂	ABC, CO ₂ & W.CO ₂	MR
	3) ISI marking	Required	Provided	MR
6.	First-Aid Hose Reel			
	1) Total number of each	06 No.	06 No.	MR

MR

	floor			
	2) Length of hose reel hose	30 m	30 m	MR
	3) Nozzle diameter	6 mm	6 mm	MR
7.	Automatic Fire Detection & Alarming System			
	1) Type of detectors	Required	Provided	MR
	2) Location of main panel	Gr. Floor	Provided	MR
	3) Location of repeater panel	Gr. Floor	Provided	MR
	4) Alternate source of power	Required	Provided	MR
	5) Hooter's Location	Office main lobby	Provided	MR
8.	MOEFA	Required	Provided	MR
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	1) Basement	Required	Provided	MR
	2) Mezzanine floors	Required	provided	MR
	3) Sprinkler above false ceiling	NA	NA	NA
11.	Internal Hydrants			
	1) Size of riser/down-comer	150 MM	150 MM	MR
	2) Number of hydrants per floor	03	03	MR
	3) Hose box each floor	03	03	MR
12.	Yard Hydrants			
	1) Total number of hydrants	02	02	MR
	2) Hose box	02	02	MR
13.	Pumping Arrangement			
	1) Ground level			
	a) Discharge of main pump	2280 LPM	2400 LPM	MR
	b) Head of main pump	30 mtr.	95 mtr.	MR
	c) Number of main pump	N/A	N/A	N/A
	d) Jockey pump out put (2 Nos.)	N/A	N/A	N/A
	e) Jockey pump head	N/A	N/A	N/A
	f) Stand by pump output	N/A	N/A	N/A
	g) Stand by pump head	N/A	N/A	N/A
	h) Auto starting/Manual stopping	N/A	N/A	N/A
	2) Terrace level			
	a) Discharge of pump	280 LPM	280 LPM	MR
	b) Head of pump	30 mtr.	30 mtr.	MR
	c) Power supply	Required	Provided	MR
	d) Auto starting of pump	Required	Provided	MR
14.	Captive Water Storage for Fire Fighting			
	1) Under ground tank capacity	N/A	N/A	N/A
	a) Draw-off connection	Required	Provided	MR
	b) Fire service inlet	Required	Provided	MR
	c) Access to tank			
	d) Over head tank capacity	1,00,000 ltr.	1,00,000 ltr.	MR
15.	Exit Signage.	Required	Provided	MR

16.	Provision of Lifts.			
	a) Pressurization of lift shaft	NA	NA	NA
	b) Pressurization of lift lobby	NA	NA	NA
	c) Communication in lift car	Required	Provided	MR
	d) Fireman's switch	Required	Provided	MR
	e) Lift signage	Required	Provided	MR
17.	Stand by Power Supply	Required	Provided	MR
18.	Refuge Area	N/A	N/A	N/A
	Total area location	NA	NA	NA
19.	Fire Control Room			
	a) Detector system panel	Required	Provided	MR
	b) Flow switch panel	Required	Provided	MR
	c) PA system panel	Required	Provided	MR
	d) Battery backup	Required	Provided	MR
	e) Building floor plan	Required	Provided	MR
20.	Special Fire Protection System for Protection of special Risk, if any:			MR

The waiting lounge at first floor in Delite Theatre is named as Delite Restaurant where only snacks are served.

The fire protection systems provided in the building were randomly tested, checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the NOC issued vide letter no. F6/DFS/MS/2015/1289 dated 17/06/2015 renewal under rule 35 of the Delhi Fire Service rules 2010, is recommended.

Signature of the Inspecting Officer

M.K. Sharma

Name :- M.K. Sharma
Designation :- ADO (CC)

~~DO (CD)~~

bskhd

By CSD (NDZ)

The matter was discussed with your self in ref to letter no DHO/city/16/73 dtd 25/16
From DHO. FSc is put up for