

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI

HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

NO. F-6/DFS/MS/2016/W2/979

Dated: 08/07/2016



FIRE SAFETY CERTIFICATE

Certified that Invitation Ceremonial, B-12, G T K Road Indl. Area, Delhi-110033 is Comprised of Basement + Ground + Two Upper Floors with Basement for Services, Ground and First Floor for Banquet Hall, Second Floor for Office & Kitchen owned / occupied by Invitation Ceremonial has already been issued fire safety certificate vide letter no. F.6/DFS/MS/2013/867 dated 01/03/2013. The premises was re-inspected by the officers concerned of fire service on 25/05/2016 in the presence of Sh. Subhash Kakkar and observed that all the fire prevention and fire safety arrangements as provided in the premises found in good working condition. The premises have therefore deemed complied with the fire prevention and fire safety in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and building / premises is fit for occupancy Assembly Buildings (Banquet) with effect 08/07/2016 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Conditions for the validity of Fire Safety Certificate:

1. All employees shall be acquainted with the use and maintenance of all the fire fighting installation/equipments.
2. The fire suppression / protection arrangements provided are to minimize losses, if maintained in good working condition. These systems cannot give a guarantee that there will be no fire or losses in the event of one.
3. Any loss of life and property due to non-functional of fire safety arrangements and other installations shall be the responsibility of the licensee.
4. This report may not in any way be treated as regularization of unauthorized construction, if any. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. The trained fire fighting staff should be available round the clock.
6. The basement shall be used strictly as per the provision of building bye laws.
7. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in

Issued on 08/07/2016 at New Delhi by


(Vipin Kental)
Chief Fire Officer
Ph: 011-23846352


Copy to:

1. The Dy. Health Officer, Civil Line Zone, Public Health Department, 16, Rajpur Road, Delhi-54.
2. Sh. Subhash Kakkar, Invitation Ceremonial, B-12, G T K Road Indl. Area, Delhi-110033

INSPECTION REPORT

Basement – Services
G.F & F.F – Banquet Hall
2nd Floor- Office & Kitchen

1. Name & address of the building. : Invitation Ceremonial, B-12, G T K Road Indl. Area, Delhi-110033
2. Type of Occupancy : Assembly Place (Banquet Hall)
3. Type of Case : Renewal
4. Details of previous NOC : F.6/DFS/MS/2013/867 dated 01/03/2013 ✓
5. Fire Safety directives letter No : F6/DFS/MS/2012/BP/3201 dated 09/09/2012
6. Date of inspection : 25/05/2016
7. Name of the Inspecting Officers : Sh. Rajesh Kumar ADO (R & RN)
8. Name and designation of officers from the building side : Sh Subhash Kakkar
9. Year of Construction : 2010
10. Applicant's letter No. : ODD No 4057 dated 28/04/2016

S. No	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks
1	Access to building			
	• Road width	12 mtr	18 mtr	M/R
	• Gate width	--	Directly accessible	--
	• Width of internal road	--	--	--
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	2	2	M/R
	• Basements	2	2	M/R
	b. Width of staircases			
	• Upper Floors	1.50 mtr	Provided	M/R
	• Basements	1.50 mtr	Provided	M/R
	c. Protection of exits			
	• Fire check door	R	P	M/R
	• Pressurization	N.A.	N.A.	N.A.
	d. No. of continuous staircases to terrace	N.A.	N.A.	N.A.
	e. Width of Corridor	N.A.	N.A.	N.A.

	f. Door Size	2 mtr	P	M/R
3	Compartmentation.			
	<ul style="list-style-type: none"> • Fire check door 	R	P	M/R
	<ul style="list-style-type: none"> • Sealing of electrical shafts 	On elect. Shaft inside the building		
	<ul style="list-style-type: none"> • Fire Rating of shaft door 	N.A.	N.A.	N.A.
	<ul style="list-style-type: none"> • Water Curtain 	N.A.	N.A.	N.A.
	<ul style="list-style-type: none"> • Fire Dampers 	N.A.	N.A.	N.A.
4	Smoke Management System.			
	<ul style="list-style-type: none"> • Basements 	30 a/c per hour	P	M/R
	<ul style="list-style-type: none"> • Upper floors 	12 a/c per hour	P	M/R
5	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total numbers 	04 Wco2 of 9 ltr 06 DCP/Co2 type ISI marked	P	M/R
	<ul style="list-style-type: none"> • Types 		P	M.R
	<ul style="list-style-type: none"> • IS marking 		Yes	M.R
6	First-Aid Hose Reels.			
	<ul style="list-style-type: none"> • Total numbers on each floor 	One at each floor	P	M/R
	<ul style="list-style-type: none"> • Length of hose reel hose 	30 m	P	M/R
	<ul style="list-style-type: none"> • Nozzle diameter 	5 mm	P	M/R
7	Automatic fire detection and alarming system.			
	<ul style="list-style-type: none"> • Type of detectors 	Smoke & Heat	P	M.R
	<ul style="list-style-type: none"> • Location of Main Panel 	GF	P	M.R
	<ul style="list-style-type: none"> • Location of Repeater Panel 	N.A.	N.A.	N.A.
	<ul style="list-style-type: none"> • Alternate source of power 	R	P	M/R
	<ul style="list-style-type: none"> • Hooters' Location 	Common area	P	M.R
8	MOEFA	R	P	M.R
9	Public Address System.	N.A.	N.A.	N.A.
10	Automatic Sprinkler System.			
	<ul style="list-style-type: none"> • Basement 	R	P	M.R
	<ul style="list-style-type: none"> • Upper Floor 	N.A.	P	M.R
	<ul style="list-style-type: none"> • Sprinkler above false ceiling 	On false ceiling in basement		
11	Internal Hydrants			
	<ul style="list-style-type: none"> • Size of riser/down-comer 	100 mm	P	M/R
	<ul style="list-style-type: none"> • Number of hydrants per floor 	01	P	M/R

	• Hose Box	01	P	M/R
12	Yard Hydrants.			
	• Total number of hydrants	02	P	M/R
	• Hose Box	02	P	M/R
13	Pumping Arrangements.			
	• Ground Level			
	➤ Discharge of main Pump	2280 LPM	P	M/R
	➤ Head of Main pump	60 M	P	M/R
	➤ Number of main pumps	03	P	M/R
	➤ Jockey Pump out put	180 LPM	P	M/R
	➤ Jockey pump head	60	P	M/R
	➤ Standby Pump out put	2280 LPM	P	M/R
	➤ Standby Pump Head	60 M	P	M/R
	➤ Auto Starting/ Manual stopping	R	P	M/R
	➤ Pump House Access	R	P	M/R
	• Terrace level			
	➤ Discharge of pump	900 LPM	P	M/R
	➤ Head of the pump	60 M	P	M/R
	➤ Power Supply	R	P	M/R
	➤ Auto Starting of pump	R	P	M/R
14	Captive Water Storage for fire fighting.			
	• Underground tank capacity	50,000 Ltr	50,000 ltr	M/R
	➤ Draw-off connection	R	P	M/R
	➤ Fire service inlet	R	P	M/R
	➤ Access to tank	R	P	M/R
	• Overhead Tank capacity	10,000 ltr	10,000 ltr	M/R
15	Exit Signage.	R	P	M/R
16	Provision of Lifts.			
	• Pressurization of Lift Shaft	N.A.	N.A.	N.A.
	• Pressurization of Lift lobby	N.A.	N.A.	N.A.
	• Communication In lift Car	R	P	M/R
	• Fireman's Grounding Switch	R	P	M/R
	• Lift Signage	R	P	M/R

17	Standby power supply	R	P	M/R
18	Refuge Area.			
	➤ Total Area	N.A.	N.A.	N.A.
	➤ Location	N.A.	N.A.	N.A.
19	Fire Control Room			
	• Detector System Panel	R	P	M/R
	• Flow Switch Panel	N.A.	N.A.	N.A.
	• PA System Panel	R	P	M/R
	• Batter backup	R	P	M/R
	• Building Floor Plans	N.A.	N.A.	N.A.
20	Special Fire Protection Systems for Protection of special Risks, if any:	--	--	--

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of the fire prevention and fire safety measures as required under the rules the NOC issued vide letter no. F.6/DFS/MS/2013/867 dated 01/03/2013 **renewal** under rule 35 of the Delhi Fire Service rules 2010 is recommended.

Signature of the Inspecting Officer

Name

Designation DO/NWD - On leave

Signature of the Inspecting Officer

Name Rajesh Kumar

Designation ASO IRN

CFD

Director Leentat
3/6.
6/6

18/1 CFD Vik
3/6/16.

As approved, f.t. letter is pulup
for your signature pl.

CFD

M:scell 16/6.

18/1
08/08/16