

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

NO. F.6/DFS/MS/EH/2016/ W2/989

Dated: 9/6 /2016

FIRE SAFETY CERTIFICATE

Certified that Lotus Leaf Restaurant (A unit of Aliens Buildcom Pvt. Ltd), located at Fun City Multiplex Prashant Vihar, Delhi comprised of Basement, Ground + Four Upper Floors is owned / occupied by Lotus Leaf Restaurant, located on First Floor was granted FSC by this department vide letter no F6/DFS/MS/2013/EH/658 Dated 14/02/2013. The premises was re-inspected by the officers concerned of this department on 24/05/2016 in the presence of Mr. Naren Negi (Manager) and found that the building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and premises is fit for Assembly building occupancy with effect from 9/6 /2016 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Conditions for the validity of fire safety Certificate:

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in

Issued on.. 9.../6.../2016 at New Delhi by


(Vipin Kental)
Chief Fire Officer
Ph: 011-23846352

Copy to:

1. The Dy. Health Officer MCD, Rohini Zone, Sector 5, Rohini Delhi for information
2. Lotus Leaf Restaurant (A unit of Aliens Buildcom Pvt. Ltd), located at Fun City Multiplex Prashant Vihar, Delhi -110085.

INSPECTION REPORT

1. Name & address of the building : Lotus Leaf Restaurant, at F-104 Multiplex Prashant Vihar,
Sector – 14, Rohini Delhi.
2. Type of Occupancy : Assembly **(Restaurant running on First Floor)**
3. Type of Case : Renewal
4. Details of previous NOC : F-6/DFS/MS/2013/EH/658 Dated 14/02/2013
5. Fire Safety directives letter No : ---
6. Date of inspection : 24 / 05 / 2016
7. Name of the Inspecting Officers : Sh. SS Tuli, DO (NW) & ADO(R)
8. Name and designation of officers
from the building side : Mr. Naren Negi (Manager)
9. Year of Construction : ---
10. Applicant's letter No. : nil Dated 22/04/2016

	Minimum Standards on fire prevention and fire safety U/R 33	Restaurant guide line of DFS dt 04/11/05	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	4.5 mtr	P	M/R
	• Gate width	---	Not provided at site	---
	• Width of internal road	--	--	--
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	02 no's	02 No's	M/R
	• Basements	--	--	--
	b. Width of staircases			
	• Upper Floors	1.50 & 1.25 mtr	1.50 & 1.25 mtr	M/R (old case)
	• Basements	--	--	--
	c. Protection of exits			
	• Fire check door	N/R	--	--
	• Pressurization	--	--	--
	d. No. of continuous staircases to terrace			
	e. Width of Corridor	--	--	--
	f. Door Size	1 mtr	P	M/R
3	Compartmentation.			

	<ul style="list-style-type: none"> • Fire check door 	N/A	N/A	N/A
	<ul style="list-style-type: none"> • Sealing of electrical shafts 	N/A	N/A	N/A
	<ul style="list-style-type: none"> • Fire Rating of shaft door 	N/A	N/A	N/A
	<ul style="list-style-type: none"> • Water Curtain 	N/A	N/A	N/A
	<ul style="list-style-type: none"> • Fire Dampers 	N/A	N/A	N/A
4	Smoke Management System.			
	<ul style="list-style-type: none"> • Basements 	30 a/c per hour	---	--
	<ul style="list-style-type: none"> • Upper floors 	12 a/c per hour	Exhaust provided	M/R
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total numbers 	One at 300 m ²	08 No's Provided	M/R
	<ul style="list-style-type: none"> • Types 		ABC & W Co2	M/R
	<ul style="list-style-type: none"> • IS marking 	ISI marked	Yes	M/R
6	First-Aid Hose Reels.			
	<ul style="list-style-type: none"> • Total numbers on each floor 	one	Provided in mall	M/R
	<ul style="list-style-type: none"> • Length of hose reel hose 	30 m	P	M/R
	<ul style="list-style-type: none"> • Nozzle diameter 	5 mm	P	M/R
7	Automatic fire detection and alarming system.			
	<ul style="list-style-type: none"> • Type of detectors 	Smoke	Provided	M/R
	<ul style="list-style-type: none"> • Location of Main Panel 	GF	Provided	M/R
	<ul style="list-style-type: none"> • Location of Repeater Panel 	N/A	N/A	N/A
	<ul style="list-style-type: none"> • Alternate source of power 	R	Provided with Mall	M/R
	<ul style="list-style-type: none"> • Hooters' Location 	R	Provided	M/R
8	MOEFA	R	Provided	M/R
9	Public Address System.	N/R	Provided with Mall	M/R
10	Automatic Sprinkler System.			
	<ul style="list-style-type: none"> • Basement 	N/A	N/A	N/A
	<ul style="list-style-type: none"> • Upper Floor 	R	Provided	M/R
	<ul style="list-style-type: none"> • Sprinkler above false ceiling 	--	---	--
11	Internal Hydrants	Provided with Shopping Mall		
	<ul style="list-style-type: none"> • Size of riser/down-comer 	150	Provided	M/R

	<ul style="list-style-type: none"> Number of hydrants per floor Hose Box 	01	Provided	M/R
		01	Provided	M/R
12	Yard Hydrants.	Provided with Shopping Mall		
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	N/A	Provided	M/R
		N/A	Provided	M/R
13	Pumping Arrangements.	Provided with Shopping Mall		
	<ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> Discharge of main Pump Head of Main pump Number of main pumps Jockey Pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Starting/ Manual stopping Pump House Access Terrace level <ul style="list-style-type: none"> Discharge of pump Head of the pump Power Supply Auto Starting of pump 			
		2850 LPM	Provided	M/R
		60 M	Provided	M/R
		03 X 2850	Provided	M/R
		180 LPM	Provided	M/R
		60 M	Provided	M/R
		2850 LPM	Provided	M/R
		60 M	Provided	M/R
		R	Provided	M/R
		R	Provided	M/R
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
14	Captive Water Storage for fire fighting.	Provided with Mall		
	<ul style="list-style-type: none"> Underground tank capacity Draw-off connection Fire service inlet Access to tank Overhead Tank capacity 	1,00,000 Ltr	Provided	M/R
		R	Provided	M/R
		R	Provided	M/R
		R	Provided	M/R
		30,000 ltr	Provided	M/R
15	Exit Signage.	R	P	M/R
16	Provision of Lifts.			

	<ul style="list-style-type: none"> • Pressurization of Lift Shaft 	N/A	N/A	N/A
	<ul style="list-style-type: none"> • Pressurization of Lift lobby 	N/A	N/A	N/A
	<ul style="list-style-type: none"> • Communication In lift Car 	N/A	N/A	N/A
	<ul style="list-style-type: none"> • Fireman's Grounding Switch 	N/A	N/A	N/A
	<ul style="list-style-type: none"> • Lift Signage 	N/A	N/A	N/A
17	Standby power supply	R	Provided with mall	M/R
18	Refuge Area.			
	➤ Total Area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19	Fire Control Room			
	<ul style="list-style-type: none"> • Detector System Panel 	Smoke	Provided	M/R
	<ul style="list-style-type: none"> • Flow Switch Panel 	N/A	N/A	N/A
	<ul style="list-style-type: none"> • PA System Panel 	N/A	N/A	N/A
	<ul style="list-style-type: none"> • Batter backup 	R	P	M/R
	<ul style="list-style-type: none"> • Building Floor Plans 	N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of special Risks, if any:	--		--

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of the fire prevention and fire safety measures as required under the rules the FSC issued vide letter no. **F-6/DFS/MS/2013/EH/658 Dated 14/02/2013** Renewal under rule 35 of the Delhi Fire Service rules 2010 is recommended.

Signature of the Inspecting Officer

Name *SS Tuli*

Designation *DO/NWD - on leave*

Signature of the Inspecting Officer

Name *Rajesh Kumar*

Designation *ADD/RN&Review*

CFD

M-SCell

W 8/6

11/3/6