

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

NO. F6/DFS/MS/school/2016/w2/985 Dated: 9/6/2016

FIRE SAFETY CERTIFICATE

Certified that Rosary School, Sanjay Colony, earlier known as St. John Mary Vianney School, Gali No.10, Narela, Delhi-110040 comprised of Single block, basement + ground + one upper floor & a hall on ground floor owned/occupied by St. John Mary Vianney School earlier, now known as Rosary School has already been issued fire safety certificate vide letter no. F.6/DFS/MS/School/2013/350 Dated 22/05/2013. The premises was re-inspected by the officer from this department on dated 24/05/2016 in the presence of Fr. Kulandi Samy (Principal) and observed that all the fire prevention & fire safety arrangements as provided in the premises found in good working condition. The premises have therefore deem complied with the requirements of Circular No F.16/Estate/CC/Fire Safety/2011/3298-3398 dated 01/03/2011 issued by Director of Education and the building / premise is fit for occupancy of Group Class B (Educational) with effect from 9/6/2016 for a period of three years, subject to compliance of the conditions mentioned below:

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. The basement shall be used strictly as per the provision of building bye laws.
6. This certificate cannot be treated in any case for regularizations of unauthorized construction.
7. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
8. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in

Issued on 9/6/16 at New Delhi by


(VIPIN KENTAL)
Chief Fire Officer
Delhi Fire Service

Copy to:

1. The Principal, Rosary School, Sanjay Colony, Gali No.10, Narela, Delhi-110040
2. The Director of Education, Old Secretariat, Delhi

INSPECTION REPORTSingle Block.
Basement +Gr.+ one upper floor

1. Name & address of the building : Rosary School, Sanjay Colony, Gali No.10, Narela, Delhi-40
 2. Type of Occupancy : Educational (previous name st. John Mary Vianney School) ✓
 3. Type of Case : Renewal
 4. Details of previous NOC : Letter No.F.6/DFS/MS/School/2013/350 Dated 22/05/2013
 5. Fire Safety directives letter No : Dir of Edu. Cir 01/03/2011
 6. Date of inspection : 24/05/2016
 7. Name of the Inspecting Officers : ADO (BW)
 8. Name and designation of officers
from the building side : Fr. Kulandi Samy (Principal)
 9. Year of Construction : 2006
 10. Applicant's letter No. : 63/2016 dated 05/05/2016
- Plot Area:1300 sq m Covered Area:1732.52 sq m No. of Students:495 NO. of Class Rooms: 15 + 05 room for other purpose

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	Dir. Of Edu. Requirement	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	6.00 mtr	5.00 mtr	MR Being old case
	• Gate width	—	—	—
	• Width of internal road	—	—	—
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases	—	—	—
	• Upper Floors	02	02	MR
	• Basements	02	02	MR
	b. Width of staircases	—	—	—
	• Upper Floors	1.50 mtr each	2 X 1.41 mtr	MR Being old case
	• Basements	1.50 mtr each	2 X 1.41 mtr	MR Being old case
	c. Protection of exits	—	—	—
	• Fire check door	—	—	—
	• Pressurization	—	—	—
	e. No. of continuous staircases to terrace	—	—	—
	g. Width of Corridor	—	—	—
	h. Door Size	CR-1.00 mtr Hall-2 X 1.50 mtr	1.28 mtr 3 X 1.80 mtr	MR MR

3	Compartmentation.	—	—	—
	• Fire check door	—	—	—
	• Sealing of electrical shafts	—	—	—
	• Fire Rating of shaft door	—	—	—
	• Water Curtain	—	—	—
	• Fire Dampers	—	—	—
4	Smoke Management System.			
	• Basements	30 a/c per hour	Exhaust Fan Provided	M/R
	• Upper floors	12 a/c per hour	—	—
5	Fire Extinguishers			
	• Total numbers	12 ABC	10 ABC 10 Co2	MR
	• Types	ISI marked	Yes	MR
	• IS marking			MR
6	First-Aid Hose Reels.			
	• Total numbers on each floor	One	P	MR
	• Length of hose reel hose	30 m	P	MR
	• Nozzle diameter	5 mm	P	MR
7	Automatic fire detection and alarming system.			
	• Type of detectors	—	—	—
	• Location of Main Panel	—	—	—
	• Location of Repeater Panel	—	—	—
	• Alternate source of power	—	—	—
	• Hooters' Location	—	—	—
8	MOEFA	—	—	—
9	Public Address System.	—	—	—
10	Automatic Sprinkler System.			
	• Basement	R	P	MR
	• Upper Floor	—	—	—
	• Sprinkler above false ceiling	—	—	—
11	Internal Hydrants			
	• Size of riser/down-comer	—	—	—
	• Number of hydrants per floor	—	—	—
	• Hose Box	—	—	—

12	Yard Hydrants.			
	• Total number of hydrants	—	—	—
	• Hose Box	—	—	—
13	Pumping Arrangements.			
	• Ground Level	—	—	—
	➤ Discharge of main Pump	—	—	—
	➤ Head of Main pump	—	—	—
	➤ Number of main pumps	—	—	—
	➤ Jockey Pump out put	—	—	—
	➤ Jockey pump head	—	—	—
	➤ Standby Pump out put	—	—	—
	➤ Standby Pump Head	—	—	—
	➤ Auto Starting/ Manual stopping	—	—	—
	➤ Pump House Access	—	—	—
	• Terrace level	—	—	—
	➤ Discharge of pump	450 LPM	P	MR
	➤ Head of the pump	40 M	P	MR
	➤ Power Supply	—	—	—
	➤ Auto Starting of pump	R	P	MR
14	Captive Water Storage for fire fighting.			
	• Underground tank capacity	—	—	—
	➤ Draw-off connection	—	—	—
	➤ Fire service inlet	—	—	—
	➤ Access to tank	—	—	—
	• Overhead Tank capacity	5000 ltrs	P	MR
		R	P	MR
15	Exit Signage.			
16	Provision of Lifts.			
	• Pressurization of Lift Shaft	—	—	—
	• Pressurization of Lift lobby	—	—	—
	• Communication In lift Car	—	—	—
	• Fireman's Grounding Switch	—	—	—
	• Lift Signage	—	—	—
17	Standby power supply	—	—	—

18	Refuge Area.			
	➤ Total Area	—	—	—
	➤ Location	—	—	—
19	Fire Control Room			
	• Detector System Panel	—	—	—
	• Flow Switch Panel	—	—	—
	• PA System Panel	—	—	—
	• Batter backup	—	—	—
	• Building Floor Plans	—	—	—
20	Special Fire Protection Systems for Protection of special Risks, if any:	—	—	—

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of the fire prevention and fire safety measures as required under the rules the NOC issued vide letter no Letter No. F.6/DFS/MS/School/2013/350 Dated 22/05/2013. Renewal under rule 35 of the Delhi Fire Service rules 2010 is recommended

Signature of the Inspecting Officer

Name

Designation

DD(MW) 0151L
CFO/MS

name of school has been changed from St. John mary wainey school to Rosary school as intimated by school principal letter dt 5th may 2016 A.

Director
27/6

Signature of the Inspecting Officer

Name

Designation

Alkhan
25/5/16
ADD(BD)

178/cfo
1/6

178/cfo
3/6/16