

FORM 'H'
FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[Refer sub - rule (1) of rule 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI

No. F6/DFS/MS/EH/2016/W2/1029

Dated: 14/06/16

FIRE SAFETY CERTIFICATE

Certified that **APS Food Ltd.** Located at **Premises No.28, GF, FF, SF, Adarsh Bhawan Co-op. Society, West Punjabi Bagh New Delhi - 110026** was issued FSC vide Letter no. F6/DFS/MS/EH/2013/411 Dated 03/06/2013. The premises was re inspected by the officers concerned of this department on 26-05-2016 in the presence of Mr Ashu Taneja and found that the said building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rule, 2010 and that the premises is fit for occupancy class "Assembly" Group D with effect from 14/06/16 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on ...16/06/16... at New Delhi by.

W 10/6
(Vipin Kental)
Chief Fire Officer,
Ph: 011-23846352

o/c Q
8/6

Copy to:

1. Sh. APS Food Ltd. Premises No.28, GF, FF, SF , Adarsh Bhawan Co-op. Society, West Punjabi Bagh New Delhi - 110026.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. Basement shall be used as per building bye laws.
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.
8. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.

INSPECTION REPORT

1. Name & address of the building: **APS Food Ltd. Located at Premises No.28, GF, FF, SF , Adarsh Bhawan Co-op. Society, West Punjabi Bagh New Delhi – 110026..**
2. Type of Occupancy : Assembly (Basement + Ground + 3 Upper Floors) ✓
3. Type of Case : Renewal
4. Details of previous NOC : F6/DFS/MS/EH/2013/411 Dated 03/06/2013
5. Fire Safety directives Letter No. : Nil
6. Date of inspection : 26-05-2016
7. Name of the Inspecting Officer : DO (West) & ADO (MN)
8. Name and designation of Officer
from the building side : Sh. Ashu Taneja
9. Year of Construction :
10. Applicant's letter No. : Nil dated 13-04-2016

S No	Minimum standards on fire prevention and fire safety U/R 33	BBL Requirements	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	9 m	12mtr	MR
	• Gate width	Old case	Old case	MR
	• Width of internal road	Old case	Old case	MR
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	2	2	MR
	• Basements	2	2	MR
	b. Width of staircases			
	• Upper floors	Old case	99 cm & 126 cm (Ground to 2 nd Floor), 59 cm (2 nd to 3 rd Floor)	MR (being old case)
	• Basements	Old case	95 cm & 77 Cm	MR (Being old case)
	c. Protection of exits			
	• Fire check door	Required in basement	Provided	MR
	• Pressurization	NR	NR	NR
	d. No of continuous staircase to terrace	1	Provided	MR

	e. Width Of Corridor	NA	NA	NA
	f. Door Size	Old case	2 exits provided on each floor	MR
3.	Compartmentation			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4.	Smoke managements System			
	• Basements	Required	Provided	MR
	• Upper floors	Required	Provided	MR
5.	Fire Extinguishers			
	• Total numbers	12 nos.	Provided	MR
	• Types	ABC & CO ₂	Provided	MR
	• IS marking	ISI marked	Provided	MR
6.	First – Aid Hose Reels			
	• Total numbers on each floor	Required	Provided	MR
	• Length of hose reel hose	30 m	Provided	MR
	• Nozzle diameter	5 mm	Provided	MR
7.	Automatic fire detection and alarming system			
	• Type of detectors	Smoke & heat	Provided	MR
	• Location of Main Panel	G. floor	Provided	MR
	• Location of Repeater Panel	Required	Provided	NR
	• Alternate source of power	Required	Provided	NR
	• Hooters' Location	Required	Provided	NR
8.	MOEFA	Required	Provided	MR
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	• Basements	Required	Provided	MR
	• Upper Floor	NR	NR	NR
	• Sprinkler above false ceiling	Required	Provided	MR
11.	Internal Hydrants			
	• Size of riser/down-comer	150 mm	Provided	MR
	• Number of hydrants per floor	1	Provided	MR
	• Hose Box	1	Provided	MR
12.	Yard Hydrants			
	• Total number of hydrants	NR	NR	NR
	• Hose Box	NR	NR	NR

13.	Pumping Arrangements			
	• Ground Level			
	• Discharge of main pump	NR	NR	NR
	➤ Head of main pump	NR	NR	NR
	➤ Number of main pumps	NR	NR	NR
	➤ Jockey pump out put	NR	NR	NR
	➤ Jockey pump head	NR	NR	NR
	➤ Standby Pump out put	NR	NR	NR
	➤ Standby Pump Head	NR	NR	NR
	➤ Auto Staring/Manual stopping	NR	NR	NR
	➤ Pump House Access	NR	NR	NR
	• Terrace level			
	➤ Discharge of pump	2x450 lpm	Provided	MR
	➤ Head of the pump	60 m	Provided	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto starting of pump	Required	Provided	MR
14.	Captive water Storage for fire fighting			
	• Under ground tank capacity	NR	NR	NR
	➤ Draw of connection	NR	NR	NR
	➤ Fire service inlet	NR	NR	NR
	➤ Access to tank	NR	NR	NR
	• Overhead Tank capacity	5,000 litres	5,000 ltrs	MR
15	Exit Signage	Required	Provided	MR
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	NR	NR	NR
	➤ Pressurization of lift lobby	NR	NR	NR
	➤ Communication in lift Car	NR	NR	NR
	➤ Fireman's Grounding Switch	NR	NR	NR
	➤ Lift Signage	NR	NR	NR
17.	Standby power supply	Required	Provided	MR
18.	Refuge Area			
	➤ Total area	NA	NA	NA
	➤ Location	NA	NA	NA
19.	Fire control room			
	➤ Detector system panel	Required	Provided	MR
	➤ Flow Switch Panel	Required	Provided	MR
	➤ PA System Panel	Required	Provided	MR
	➤ Battery backup	Required	Provided	MR
	➤ Building Floor Plans	Required	Provided	MR
20.	Special Fire Protection Systems for Protection of special Risks, if any;	NA	NA	NA

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of minimum standards on fire prevention and fire safety as required under the rules the NOC issued vide letter no. F6/DFS/MS/EH/2013/411 Dated 03/06/2013 renewal under rule 35 of the Delhi Fire Service Rules 2010 is recommended.

Inspector 27/5/16
Signature of the Inspecting Officer
Name *Mukulish Verma*
Designation *ASO (MN)*

28/5
Signature of the Inspecting Officer
Name *SUNIL CHANDHARY*
Designation *DO (West)*

C. F. P.

Director
27/5
28/5

114/dfo
2/6/16.