

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001

No F 6 / DFS / MS / 2016 / *school/w2/1980*

Dated: *09/06/2016*

FIRE SAFETY CERTIFICATE

Certified that the Lord Krishna Convent School, Gali No. 94, opposite Apex Main Gate, Sant Nagar, Burari, Delhi-110084, comprised of Ground and two upper floors owned/ occupied by Lord Krishna Convent School was granted NOC by this department vide letter No F 6 / DFS / MS / 2009/464 dated 16.02.2009. The premise was re-inspected by the officer concerned of this department on 21.05.2016 in the presence of Smt. Supriya Gupta/ Principal and observed that all the fire prevention and fire safety arrangements as provided in the premise found in good working condition and there is no additional construction. The premise have therefore deemed complied with the requirements under rule 33 of the Delhi Fire Service Rules, 2010 and the building premise is fit for occupancy under **Educational "Group B"** with effect from *...09/06/16..* for a period of three years in accordance with the rule 36 unless renewed under rule 37 or sooner cancelled under rule 40, subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010,

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in

Issued on *...09/06/16.....* at New Delhi

W
STG.
(Vipin Kantal)
Chief Fire Officer
Ph:- 01123846352
o/ka

Copy to :-

1. The Director, Education, Government of N.C.T of Delhi. Old Sectt. Delhi - 110054.
2. The Principal, Lord Krishna Convent School, Gali no.94, Sant Nagar, Burari, Delhi-84.

INSPECTION REPORT

1. Name & address of the building : Lord Krishna Convent School, Gali no.94, Sant Nagar, Burari, Delhi-84.
(Ground +02 Floors)
2. Type of Occupancy : Educational
3. Type of Case : Renewal
4. Details of previous NOC : F6/DFS/MS/2009/464 dated 16.02.09
5. Fire Safety directives letter No : Director of Education Letter dated 01.03.2011/ NBC Part 4.
6. Date of inspection : 21/05/2016
7. Name of the Inspecting Officers : ADO (RN)
8. Name and designation of officers
from the building side : Supriya Gupta/ Principal
9. Year of Construction : 2003
10. Applicant's letter No. : 17.12.2015

Plot Area-250 SqY Covered area ----350sqY, No of student—400 nos, Total class room --15nos

	Minimum Standards on fire prevention and fire safety U/R 33	Dir. Of Education/ NBC Requirement	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	6m	6m	MR
	• Gate width	4.5m	1.5m(old case)	MR
	• Width of internal road	NA	NA	NA
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	01	02	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper Floors	1.50 m	95cm & 85cm(old case)	MR
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No. of continuous staircases to terrace	NA	NA	NA
	e. Width of Corridor	NA	NA	NA
	f. Door Size	1.0m	1.0m	MR

AK

3	Compartmentation.			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4	Smoke Management System.			
	• Basements	30 a/c per hour	No basement	NA
	• Upper floors	12 a/c per hour	Natural Ventilated	MR
5	Fire Extinguishers			
	• Total numbers	5nos	5 nos	MR
	• Types	ABC/Co2	ABC--5	MR
	• ISI marking	Yes	Yes	MR
6	First-Aid Hose Reels.			
	• Total numbers on each floor	01	P	MR ✓
	• Length of hose reel hose	30 m	P	MR
	• Nozzle diameter	5mm	P	MR
7	Automatic fire detection and alarming system			
	• Type of detectors	NA	NA	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
	• Hooters' Location	NA	NA	NA
8	MOEFA			
9	Public Address System.			
10	Automatic Sprinkler System.			
	• Basement	NA	NA	NA
	• Upper Floor	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11	Internal Hydrants			
	• Size of riser/down-comer	R	P	MR ✓
	• Number of hydrants per floor	1	P	MR
	• Hose Box	R	P	MR

14

12	Yard Hydrants.				
	<ul style="list-style-type: none"> • Total number of hydrants • Hose Box 	NA	NA	NA	
13	Pumping Arrangements.				
	<ul style="list-style-type: none"> • Ground Level <ul style="list-style-type: none"> ➤ Discharge of main Pump ➤ Head of Main pump ➤ Number of main pumps ➤ Jockey Pump out put ➤ Jockey pump head ➤ Standby Pump out put ➤ Standby Pump Head ➤ Auto Starting/ Manual stopping ➤ Pump House Access • Terrace level <ul style="list-style-type: none"> ➤ Discharge of pump ➤ Head of the pump ➤ Power Supply ➤ Auto Starting of pump 	N/A	N/A	N/A	
		N/A	N/A	N/A	
		N/A	N/A	N/A	
		N/A	N/A	N/A	
		N/A	N/A	N/A	
		N/A	N/A	N/A	
		N/A	N/A	N/A	
		N/A	N/A	N/A	
		450lpm	P	MR	
		40m	P	MR	
		Required	P	MR	
		Required	P	MR	
		Captive Water Storage for fire fighting.			
		14	<ul style="list-style-type: none"> • Underground tank capacity ➤ Draw-off connection ➤ Fire service inlet ➤ Access to tank • Overhead Tank capacity 	NA	NA
NA	NA			NA	
NA	NA			NA	
NA	NA			NA	
5000 ltr	P			MR	
Exit Signage.					
15	Required	P	MR		
16	Provision of Lifts.				
	<ul style="list-style-type: none"> • Pressurization of Lift Shaft • Pressurization of Lift lobby • Communication In lift Car • Fireman's Grounding Switch • Lift Signage 	N/A	N/A	N/A	
		N/A	N/A	N/A	
		N/A	N/A	N/A	
		N/A	N/A	N/A	
		N/A	N/A	N/A	
N/A		N/A	N/A		
17	Standby power supply	N/A	N/A	N/A	
18	Refuge Area.				

16

	➤ Total Area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector System Panel.	N/A	N/A	N/A
	• Flow Switch Panel	N/A	N/A	N/A
	• PA System Panel	N/A	N/A	N/A
	• Batter backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of special Risks, if any:	N/A	N/A	N/A
		N/A	N/A	N/A

The fire protection systems provided in the building were tested/ checked randomly and found in working condition.

The school management has complied all the observations issued & communicated by this department vide letter of even no. 484 dated 22.02.2016.

Keeping in view the satisfactory compliance of the minimum standards on fire prevention and fire safety required as stipulated in director of education Circular dated 17.01.2005, the NOC issued vide letter of even no 464 dated 16.02.2009, renewal under rule 35 of the Delhi Fire Service Rules, 2010 is recommended.

DO/NWD - on leave

CFO/wyz

Director
 1/6.
 2016

Signature of the Inspecting Officer

Name: - Rajesh Kumar

Designation: - ADO/RN

165/cfo
 21/6/16.