

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110001

No. *F6/DFS/MS/school/2016/MD2/1020*

Dated: *13/06/16*

FIRE SAFETY CERTIFICATE

Certified that the Prabhakar Model School, 5th Sloping, Near Masjid Wali Gali, Sonia Vihar, Delhi-94, comprised of two block i.e. A and B Blocks, each blocks having ground plus one upper floor owned/occupied by Prabhakar Model School, have complied with the fire prevention and fire safety requirements in accordance with the circular No. F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01.03.11 issued by the Director of Education and verified by the officer concerned of Fire Service on 02.06.2016 in the presence of Manager of the school and found that the School building having each blocks is GF+FF is fit for occupancy class B 'Educational Building' with effect from *13/06/16* for a period of three years, subject to conditions printed overleaf.

Issued on...*13/06/16*.....at New Delhi by

Virendra Singh
(Virendra Singh)

Dy. Chief Fire Officer

O/C S.M.

To,
The Principal,
Prabhakar Model School, 5th Sloping, Near Masjid Wali Gali, Sinia Vihar, Delhi-94

Copy to:-

The Joint Director of Education
(Land & Estate)
Directorate of Education, Lucknow Road, Delhi -54

CONDITIONS:

1. The owner /occupier shall apply for renewal of this fire safety certificate to the Director in form 'J' [sub rule(1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
2. All the means of escape shall be kept free of all type of obstruction all the time.
3. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
4. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
5. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities.
6. This Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in

INSPECTION REPORT

1. Name & address of the building : Prabhakar Model School, 5th Sloping, Near Masjid Wali Gali, Sinia Vihar, Delhi-94
2. Building is comprised of : Two blocks i.e. A & B, each block having ground plus one upper floor
3. Type of Occupancy : Educational
4. Type of Case : New Case
5. Details of Previous NOC : Nil
6. Fire Safety direction letter No : F.16/Estate/CC/Fire safety/2011/3298 to 3398 dated 01.03.11
7. Date of Inspection : 02.06.2016
8. Name of the Inspecting Officers: : Suresh Singh (ADO)
9. Name of the designation of Officer from the building side : Manager
10. Year of Construction : 2004
11. Applicant's letter No : PMS/03/16 dated 01.06.2016

S.No	Minimum Standards on fire safety requirements as per circular no. 3298 to 3398 Dated. 01.03.11	Requirement	Provided at Site	Remarks MR/NMR
1	Access to building			
	Road width	6 m	6 m	MR
	Gate width	N.A	N.A	N.A
	Width of internal road	N.A	N.A	N.A
2	Number, Width, Type and Arrangement of Exits			
	a. Number of Staircases			
	Upper Floor	1no. in each block	1no. in each block	MR
	Basement	N.A	N.A	N.A
	B. Width of Staircases			
	Upper Floor	1.5 m	A=1.7m, & B=1.6m & 0.80 m	MR
	Basement	N.A	N.A	N.A
	c. Protection of exits	N.A	N.A	N.A
	Fire check door	N.A	N.A	N.A
	Pressurization	N.A	N.A	N.A
	e. No. of continuous staircases to terrace	1 no.	1 no.	N.A.
g. Width of Corridor	1.5 m	1.5 m	MR	
h. Door Size	1 m	1 m	MR	
3	Compartmentation.			
	Fire check door	N.A	N.A	N.A
	Sealing of electrical shafts	N.A	N.A	N.A
	Fire rating of shaft door	N.A	N.A	N.A
	Water curtain	N.A	N.A	N.A
	Fire Dampers	N.A	N.A	N.A
4	Smoke Management System.			
	Basement	30a/c per hour	N.A	N.A
	Upper floor	12a/c per hour	N.A	N.A

14	Captive Water Storage for Fire Fighting.			
	Underground tank capacity	N.A	N.A	N.A
	Draw-off connection	N.A	N.A	N.A
	Fire service inlet	N.A	N.A	N.A
	Access to tank	N.A	N.A	N.A
	Overhead Tank capacity	N.A	N.A	N.A
15	Exit Signage.	N.A	N.A	N.A
16	Provision of Lifts.			
	Pressurization of Lift Shaft	N.A	N.A	N.A
	Pressurization of Lift lobby	N.A	N.A	N.A
	Communication in lift car	N.A	N.A	N.A
	Firemen's grounding switch	N.A	N.A	N.A
	Lift Signage	N.A	N.A	N.A
17	Standby power supply	N.A	N.A	N.A
18	Refuge Area.			
	Total area	N.A	N.A	N.A
	Location	N.A	N.A	N.A
19	Fire Control Room			
	Detector system panel	N.A	N.A	N.A
	Flow switch panel	N.A	N.A	N.A
	PA system panel	N.A	N.A	N.A
	Batter backup	N.A	N.A	N.A
	Building Floor Plans	N.A	N.A	N.A
20	Special Fire Protection systems for protection of special Risks, if any:	N.A	N.A	N.A

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety measures as required under the rules it is recommended to grant Fire Safety Certificate under the circular No. 3298 to 3398 dated 01.03.11

Singh
2.6.16
Signature of the Inspecting Officer

Name Suresh Singh
Designation ADO (Shah)

Dy CEO (Virendra Singh)
Submitted for approval please.

Dy CEO (NO2)

Singh
3/6/16

ADDO