

NO. F6/DFS/MS/Indl./2016/SZ/ 972

DATED: 08/06/16

FIRE SAFETY CERTIFICATE

Certified that the M/s SMS Exports at Plot No. D-28, Okhla Phase-I, New Delhi comprised of basement, ground, mezzanine and one upper floors was granted NOC by this department vide letter no. F6/DFS/MS/Indl./2013/342 Dated 21.05.2013. The premises re-inspected by the officers concerned on 02.06.2016 in the presence of Sh. Ajay Sahni the factory and observed that fire safety norms as required under Rule 33 of Delhi Fire Service Rules, 2010 have deemed complied and that the building / premises is fit for occupancy Group G "Industrial Building" with effect from... 08/06/16... for a period of **three years**. , in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rule 2010, Subject to conditions as mentioned below.

Issued on 08/06/16 at New Delhi by


(Atul Garg)
Chief Fire Officer

Copy To:-

1. The Authorized Signatory, M/s SMS Exports at Plot No. D-28, Okhla Phase-I, New Delhi-110020.

Conditions for the validity of fire safety certificate

1. All the fire safety and means of escape facilities shall be maintained in good working conditions at all time. Any lapse rendering fire safety or means of evacuation facilities rendering non-functional shall be the responsibility of the management.
2. Building Sanctioning authority may verify any deviation with regard to the construction/occupancy in the building. In case of any deviation, the fire safety certificate stands null and void.
3. The staffs shall be trained for operating fire fighting system and mock evacuation drills be conducted at regular intervals and record be maintained.
4. The basement shall be used strictly as per the provisions of Building Bye laws.
5. The owner/occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules-2010. The form is available on www.dfs.delhigovt.nic.in
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form "J" [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry. The form is available on www.dfs.delhigovt.nic.in.

INSPECTION REPORT

1	Name & address of the building	M/S SMS Export at Plot No. D-28, Okhla Industrial Area, Phase-I, New Delhi
	Building Comprised of	B+G+M+1 upper floor
2	Type of Occupancy	Industrial "G"
3	Type of case	Renewal
4	Details of previous NOC	F6/DFS/MS/Indl./2013/342 Dated 21.05.2013
5	Fire safety directives letter No	Nil
6	Date of inspection	2.06.2016
7	Name of the inspecting Officers :	DCFO D.P. Bhardwaj & ADO M.K. Chatopadhyay
8	Name and designation of officers from the building side	Mr. Ajay Sahni(Partner)
9	Year of construction	2005
10	Applicant's letter No.	Nil dated 23.05.2016

Old Case

S. NO.	Minimum Standards on fire prevention and fire safety U/R 33	BBL-1983/NBC Requirement	Provided at site	Remarks MR / NMR
1	Access to building			
	1) Road width	6 Mtr	Provided	MR
	2) Gate width	N/A	N/A	N/A
	3) Width of internal road	N/A	N/A	N/A
2	Number, width Type & arrangement of exits			
	a. Number of staircases			
	1. Upper floors	Two	Provided	MR
	2. basements	Two	Provided	MR
	b. Width of staircase			
	1. Upper floors	1.25 mtrs	1.7 & 1.00 Mtrs Provided	MR
	2. basements	1.25 mtrs	1.90 & 1.3 Mtrs Provided	MR
	c. Protection of exits			
	1. Fire check door	Required	Provided	MR
	2. Pressurization	N/A	N/A	N/A
	d. No. of continuous staircase to terrace	Required	One Provided	MR
	e. Width of corridor	N/A	N/A	N/A
	f. Door size	N/A	N/A	N/A
3	Compartmentation.			
	1. Fire check door	N/A	N/A	N/A
	2. Sealing of electrical shafts	Required	Provided	MR
	3. Fire Rating of shaft door	N/A	N/A	N/A
	4. Water curtain	N/A	N/A	N/A
	5. Fire dampers	N/A	N/A	N/A
4	Smoke Management system.			
	basement	30 a/c per hour	Exhaust Fan Provided	MR
		12 a/c per hour		
	upper floors		Exhaust Fan Provided	MR
5	Fire Extinguishers			
	total numbers		20 Nos	MR
	Types		Co2, Water Co2, ABC	MR
			Yes	MR


6	First-Aid Hose Reels.			
	total numbers on each floor	One	One Provided	MR
	Length of Hose reel hose	30 m	30 Mtr Provided	MR
	Nozzle Diameter	5 mm	Provided	MR
7	Automatic fire detection and alarming system			
	Type of Detectors	Required	Provided (Smoke/Heat)	MR
	location of Main Panel	Required	Provided (Ground)	MR
	location of Repeater panel	N/A	N/A	N/A
	Alternate source of power	Required	Battary Backup	MR
	hooter's location	Required	Stairs Provided	MR
8	MOEFA	Required	Provided	MR
9	Public Address System.	N/A	Provided	MR
10	Automatic Sprinkler System.			
	basement	Required	Provided	MR
	upper floors	Required	Provided	MR
	sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants			
	Size of riser/down-corner	150 mm	Provided	MR
	Number of Hydrants per floor	One	One Provided	MR
	hose Box	One	One Porvided	MR
12	Yard Hydrants.			
	total number of hydrants	Required	Provided	MR
	hose box	Required	Provided	MR
13	Pumping arrangements			
	1. Ground level			
	a. Discharge of main Pump	2280 LPM	2280 LPM Provided	MR
	b.Head of main pump	60 Mtr	60 Mtr Provided	MR
	c.Number of main pumps	One		MR
	d.jockey pump out put	180 LPM	180 LPM Provided	MR
	e.jockey pump head	60 Mtr	60 Mtr Provided	MR
	f. Standby Pump output	2280 LPM	2280 LPM Provided	MR
	g.Stanby Pump head	60 Mtr	60 Mtr Provided	MR
	h.Auto Starting/Manual stopping	Required	Provided (Both)	MR
	pump house access	Required	Provided	MR
	2.Terrace level			
	a. Discharge of pump	900 LPM	900 LPM Provided	MR
	b. head of the pump	35 mtr	35 Mtr Provided	MR
	c. Power supply	Required	Provided	MR
	d. Auto starting of pump	Required	Provided	MR
14	Captive water storage for fire fighting			
	1. Underground tank capacity	50,000 ltr	50,000 ltr Provided	MR
	a. Draw-off connection	Required	Provided	MR
	b. fire service inlet	Required	Provided	MR
	c.Access to tank	Required	Provided	MR
	Over head tank Capacity	15,000 ltr	15,000 ltr Provided	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of lifts.			
	a. Pressurization of lift shaft	N/A	N/A	N/A
	b. pressurization of lift lobby	N/A	N/A	N/A
	c. communication in lift car	N/A	N/A	N/A
	d. Fireman's grounding switch	N/A	N/A	N/A
	e. Lift signage	N/A	N/A	N/A

	Standby power supply	Required	Provided	MR
5	Refuge Area.		Not Required	
	total area			
	location			
19	Fire control room			
	a. Detector system Panel	N/A	N/A	N/A
	b. Flow switch Panel	N/A	N/A	N/A
	c. PA system Panel	N/A	N/A	N/A
	d. Batter backup	N/A	N/A	N/A
	e. Building floor plans	N/A	N/A	N/A
20	Special Fire Protection systems for protection of special risks, if any:	Required	2 Co2 Fire Extinguishers Provided	MR

The fire protection systems provided in the building were checked and found functional at the time of inspection.

In view of the substantial compliance of the minimum standards of fire prevention and fire safety measures as required under the rules of NOC issued vide letter no. **F6/DFS/MS/Indl./2013/342 Dated 21.05.2013** renewal under rule 35 of the Delhi Fire Service rules 2010 is recommended.

Accordingly DFA is put up for your approval and signature please.




Signature of the Inspecting Officer


Name D.P. Bhardwaj
Designation : DCFO



Signature of the Inspecting Officer


Name M.K. Chatopadhyay
Designation ADO (BCP)


~~CFO Atul Garg~~ 
6/5/16

~~DRB (DR) / DRB~~ 
7/6/16

~~ADO/MR~~

F.T. letter is put up for Sign please.

~~CFO (Atul Garg)~~ 
8/6/16


8/6/16