

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS, DELHI FIRE SERVICE, NEW DELHI-110001**  
**Fax: 23412593, Email: [director.dlfire@nic.in](mailto:director.dlfire@nic.in), Tel:- 011-23414000**

No.F6/MS/DFS/SZ/GH/2016/


1016

Dated : 10/08/16

**FIRE SAFETY CERTIFICATE**

Certified that the **Hotel Ivory 32** located at **C-32, Greater Kailash.- 1, New Delhi-110048** comprised of **Basement, Ground Floor + 3 Upper floors (23 Guest Rooms)** was granted FSC by this department vide letter No.F6/DFS/MS/EH/2013/599 dated 23/07/13 was re-inspected by the officer concerned of this department on 02/06/16 in the presence of Mr. R.K.Gupta and that the said premises have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises fit for occupancy class **Residential (Guest House)** with effect from-----10/06/16---for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules 2010.

Issued ...10/06/16.....at New Delhi by.

  
(ATUL GARG)  
CHIEF FIRE OFFICER  
g/c (ADD, ADD)

Copy to:- (1) Dy. Health Officer,  
MCD, South Zone, Green Park, New Delhi.

(2) Mr.R.K.Gupta  
Hotel Ivory 32 ,C-32, Greater Kailash.- 1,  
New Delhi-110048

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
2. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
5. The basement shall be used as per the provisions of BBL.
6. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form "J" [ sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)

## INSPECTION REPORT

1. Name & address of the building:- Hotel Ivory 32 located at C-32, Greater Kailash.- I, New Delhi-110048.
2. Type of occupancy:- Residential (Guest House)
3. Type of case:- Renewal.
4. Details of previous NOC:- No. F6/DFS/MS/GH/2013/SZ/599 dated 23/07/13.
5. Fire safety directives No.- No
6. Date of inspection:- 02 /06/16
7. Name of the inspecting officer:- D.B.Mukherjee A.D.O.(BCP)
8. Name & designation of officer From the building side:- Mr. R.K.Gupta
9. Year of construction:- 2010-11
10. Applicant's letter No:-NIL, dated 26/05/16

**Old Case**

S.No.	Minimum Standards on fire Prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR
<b>1.</b>	<b>Access to Building</b>			
	1) Road width	Required	Provided	MR
	2) Gate width	N/A	N/A	N/A
	3) Width of internal road	N/A	N/A	N/A
<b>2.</b>	<b>Number, Width Type &amp; Arrangement of Exits</b>			
	A. Number of staircases			
	1. Upper floors	Required	Provided 01 No.	MR
	2. Basements	Required	Provided 02 exits	MR
	B. Width of staircase			
	1. Upper floors	Required	1.25 mtr	MR
	2. Basements	Required	1.25 mtr & 0.9mtr	MR
	C. Protection of exits			
	1. Fire check door	Required	Provided	MR
	2. Pressurization	N/A	N/A	N/A
	D. No. of continuous staircase to terrace	Required	One	MR
	E. Width of corridor	Not required	Provided	MR
	F. Door size	N/A	N/A	N/A
<b>3.</b>	<b>Compartmentation</b>			
	1) Fire check door	N/A	N/A	N/A
	2) Sealing of electrical shafts	N/A	N/A	N/A
	3) Fire rating of shaft door	N/A	N/A	N/A
	4) Water curtain	N/A	N/A	N/A
	5) Fire Dampers	N/A	N/A	N/A
<b>4.</b>	<b>Smoke Management System</b>			
	1) Basements	30 a/c per hour	Exhaust fan Provided	N/A
	2) Upper floors	12 a/c per hour	N/A	N/A
<b>5.</b>	<b>Fire Extinguishers</b>			
	1) Total numbers		12 Nos.	MR
	2) Types		ABC, Co2 &	MR



		ISI Marked	W.Co2	
	3) ISI marking		Yes	MR
<b>6.</b>	<b>First-Aid Hose Reel</b>			
	1) Total number of each floor	Required	Provided one at each floor	MR
	2) Length of hose reel hose	30 m	Yes	MR
	3) Nozzle diameter	5 mm	Yes	MR
<b>7.</b>	<b>Automatic Fire Detection &amp; Alarming System</b>			
	1) Type of detectors	N/A	N/A	N/A
	2) Location of main panel	N/A	N/A	N/A
	3) Location of repeater panel	N/A	N/A	N/A
	4) Alternate source of power	Required	DG Set	MR
	5) Hooter's Location	NR	Provided	MR
<b>8.</b>	<b>MOEFA</b>	Required	Provided	MR
<b>9.</b>	<b>Public Address System</b>	Required	Provided	MR
<b>10.</b>	<b>Automatic Sprinkler System</b>			
	1) Basement	Required	Provided	MR
	2) Upper floors	N/A	N/A	N/A
	3) Sprinkler above false ceiling	N/A	N/A	N/A
<b>11.</b>	<b>Internal Hydrants</b>			
	1) Size of riser/down-comer	100 mm.	Provided	MR
	2) Number of hydrants per floor	2 Nos.	Provided	MR
	3) Hose box	2 Nos.	Provided	MR
<b>12.</b>	<b>Yard Hydrants</b>			
	1) Total number of hydrants	N/A	N/A	N/A
	2) Hose box	N/A	N/A	N/A
<b>13.</b>	<b>Pumping Arrangement</b>			
	1) Ground level	N/A	N/A	N/A
	a) Discharge of main pump	N/A	N/A	N/A
	b) Head of main pump	N/A	N/A	N/A
	c) Number of main pump	N/A	N/A	N/A
	d) Jockey pump out put	N/A	N/A	N/A
	e) Jockey pump head	N/A	N/A	N/A
	f) Stand by pump output	N/A	N/A	N/A
	g) Stand by pump head	N/A	N/A	N/A
	h) Auto starting/Manual stopping	N/A	N/A	N/A
	2) Terrace level			
	a) Discharge of pump	Required	900 LPM & 900 LPM	MR
	b) Head of pump	Required	30 m	MR
	c) Power supply	Required	Electric Supply & also by D.G. Set	MR
	d) Auto starting of pump	Required	yes	MR
<b>14.</b>	<b>Captive Water Storage for Fire Fighting</b>			
	1) Under ground tank capacity	N/A	N/A	N/A
	a) Draw-off connection	N/A	N/A	N/A
	b) Fire service inlet	Required	Provided	MR
	c) Access to tank	N/A	N/A	N/A

	d) Over head tank capacity	Required	10,000 Ltrs.	MR
15.	<b>Exit Signage.</b>	Yes	Provided	MR
16.	<b>Provision of Lifts.</b>			
	a) Pressurization of lift shaft	N/A	N/A	N/A
	b) Pressurization of lift lobby	N/A	N/A	N/A
	c) Communication in lift car	Required	Provided	MR
	d) Fireman's switch	Required	Provided	MR
	e) Lift signage	Required	Provided	MR
17.	<b>Standby Power Supply</b>	Required	Provided DG Set	MR
18.	<b>Refuge Area</b>			
	Total area location	N/A	N/A	N/A

19.	<b>Fire Control Room</b>	N/A	N/A	N/A
	a) Detector system panel	N/A	N/A	N/A
	b) Flow switch panel	N/A	N/A	N/A
	c) PA system panel	N/A	N/A	N/A
	d) Battery backup	N/A	N/A	N/A
	e) Building floor plan	N/A	N/A	N/A
20.	<b>Special Fire Protection System for Protection of special Risk, if any:</b>			N/A

The fire system provided in the building were checked and found functional at the time of inspection.

In view of the compliance of the minimum standards on fire prevention and fire safety measures as required under the rules the FSC issued vide letter No F6/DFS/MS/GH/2013/SZ/559 dated: - 23/07/2013, renewal under rules 35 of the Delhi Fire Service Rules 2010 is recommended to grant fire safety certificate.

Accordingly DFA is put up for perusal and signature pl.

*Handwritten signature*  
3/6/16

Signature of the Inspecting Officer

Name: D.B.Mukherjee

Designation: - Assitt. Divisional. Officer(BCP)

Dy cfo (D.P. Bhargava)

*Handwritten signature*  
3/6/16

cfo Atul Garg

*Handwritten signature*  
7/6/16

FT PLS