

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001**

No F 6 / DFS / MS / GH / 2016 / *W2/981*

Dated: *09/06/16*

FIRE SAFETY CERTIFICATE

Certified that the M/s Shalimar Guest House located at **A-18, Panchwati, Azadpur, G.T.K Road, Delhi** comprised of two blocks i.e (main block --basement+ ground and two upper floors having 21 guest rooms & adjoining block --Ground +02 upper floors having 03 guest rooms) owned/ occupied by Shalimar Guest House was granted fire safety certificate vide letter no. **F6/DFS/MS/GH/2013/244 dated 03/05/2013**. The premises was re-inspected by the officer concerned of Fire Service on 28/05/2016 in the presence of Sh. Inder Deep Singh (**Owner**) and observed that all the fire prevention and fire safety arrangements as provided in the premise found good working condition. The premise have therefore deemed complied with the fire prevention and fire safety measures in accordance with the rule 33 of Delhi Fire Service Rules, 2010 and that the building / premise is fit for occupancy class "Residential Group A-1" for total 24 guest rooms only, with effect from *09/06/16* for a period of **three years** in accordance with rules 36 unless renewed under rule. 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in
8. All the means of escape shall be kept free of any obstruction all the time to evacuate the occupant, in a safe manner, in the event of emergency.
9. The use of basement is restricted for storage of house hold items only.

Issued on *09/06/16*..... at New Delhi by

W.T.G.
(Vipin Kental)
Chief Fire Officer
Ph: 01123846352

o/c

Copy to :-

1. The Additional Commissioner of Police (Lic), 1st floor, Police Station, Defence Colony, New Delhi.
2. Sh Inder Deep Singh, M/s Shalimar Guest House, A-18, Panchwati, Azadpur, G.T Road Delhi.

M/19

Renewal

INSPECTION REPORT

1. Name & address of the building : M/s Shalimar Hotel, A-18, Panchwati Azadpur, Delhi.
2. Type of Occupancy : Guest House – 02 blocks , Block – I (B+G+02 upper floors) 7x3=21 g/room
Block-II (G + 02 upper floors) 1x3= 03 g/room
Basement—storage of house hold items
3. Type of Case : Renewal
4. Details of previous NOC : F6/DFS/MS/GH/2013/244 dated 03/05/2013
5. Fire Safety directives letter No : old case
6. Date of inspection : 28/05/2016
7. Name of the Inspecting Officers : ADO (RN)
8. Name and designation of officers from the building side : Sh. Inder Deep Singh (Manager)
9. Year of Construction : 1998
10. Applicant's letter No. : DHO/CLZ/2016/382 dated 12/05/2016

	Minimum Standards on fire prevention and fire safety U/R 33	NBC/ BBL Requirement	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	06m	9m approx	MR
	• Gate width	4.5m	3.5m(old Case)	MR
	• Width of internal road	NA	NA	NA
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	01 at each block	01 at each block	MR (old case)
	• Basements	02	02	MR
	b. Width of staircases			
	• Upper Floors	1.10m & 1.0m	1.10m & 1.0m	MR (old Case)
	• Basements	1.10m & 1.0m	1.10m & 1.0m	MR (old case)
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No. of continuous staircases to terrace	NA	NA	NA
	e. Width of Corridor	NA	NA	NA
	f. Door Size	1.0m	1.0m	MR

M

14/20

3	Compartmentation.			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4	Smoke Management System.			
	• Basements	30 a/c per hour	Exhaust fan provided	MR
	• Upper floors	12 a/c per hour	Natural Ventilated	MR
5	Fire Extinguishers			
	• Total numbers	10nos	10	MR
	• Types	ABC & Co2	W. Co2 - 02 Co2 - 02 ABC-06	MR
	• ISI marking	Yes	Yes	MR
6	First-Aid Hose Reels.			
	• Total numbers on each floor	01	PF	MR
	• Length of hose reel hose	30m	P	MR
	• Nozzle diameter	5mm	P	MR
7	Automatic fire detection and alarming system.			
	• Type of detectors	NA	NA	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
	• Hooters' Location	NA	NA	NA
8	MOEFA	R	P	MR
9	Public Address System.	NA	P	NA
10	Automatic Sprinkler System.			
	• Basement	R	PF	MR
	• Upper Floor	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11	Internal Hydrants			

14

	<ul style="list-style-type: none"> • Size of riser/down-comer • Number of hydrants per floor • Hose Box 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
12	Yard Hydrants.			
	<ul style="list-style-type: none"> • Total number of hydrants • Hose Box 	NA	NA	NA
		NA	NA	NA
13	Pumping Arrangements.			
	<ul style="list-style-type: none"> • Ground Level <ul style="list-style-type: none"> ➤ Discharge of main Pump ➤ Head of Main pump ➤ Number of main pumps ➤ Jockey Pump out put ➤ Jockey pump head ➤ Standby Pump out put ➤ Standby Pump Head ➤ Auto Starting/ Manual stopping ➤ Pump House Access • Terrace level <ul style="list-style-type: none"> ➤ Discharge of pump ➤ Head of the pump ➤ Power Supply ➤ Auto Starting of pump 			
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		900LPM	900lpm	MR
		40m	P	MR
		R	P	MR
		R	P	MR
14	Captive Water Storage for fire fighting.			
	<ul style="list-style-type: none"> • Underground tank capacity <ul style="list-style-type: none"> ➤ Draw-off connection ➤ Fire service inlet ➤ Access to tank • Overhead Tank capacity 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		15000 ltr	15000 ltr.	MR
15	Exit Signage.	Required	P	MR
16	Provision of Lifts.			
	<ul style="list-style-type: none"> • Pressurization of Lift Shaft • Pressurization of Lift lobby • Communication In lift Car 	N/A	N/A	N/A
		N/A	N/A	N/A
		NA	NA	NA

ML

11/22

	<ul style="list-style-type: none"> Fireman's Grounding Switch Lift Signage 	NA	NA	NA
17	Standby power supply	Required	Provided inverter	MR
18	Refuge Area.			
	➤ Total Area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19	Fire Control Room			
	<ul style="list-style-type: none"> Detector System Panel Flow Switch Panel PA System Panel Batter backup Building Floor Plans 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of special Risks, if any:	NA	NA	NA

The fire protection systems provided in the building were tested/ checked and found some in working order at the time of inspection.

Keeping in view the substantial compliance of the minimum standard on the fire prevention and fire safety required under the rules, FSC issued vide letter no. F6/DFS/MS/GH/2013/244 dated 03.05.2013, renewal under rule 35 of the Delhi Fire Service Rules, 2010 is recommended.

11/22

Signature of the Inspecting Officer

Name: - Rajesh Kumar

Designation:- ADO/RN

D.O/MOG - on leave

CFO/

Director
1/6
2/16

169/CFO
2/6/16