

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS, DELHI FIRE SERVICE, NEW DELHI-110001
Fax: 23412593, Email:gargatul@hotmail.com, Tel:- 011-26189168



No.F6/MS/DFS/GH/2016/52/1040

Dated: 16/06/16

FIRE SAFETY CERTIFICATE

Certified that the Young Women's Association (Regd), Working Women Hostel No-II, located at Avenue-21, Saket, New Delh-110017, comprised of basement, ground & 03 upper floors (3Blocks) was granted FSC by this department vide letter No. F6/DFS/MS/GH/2013/4241 dated 14/11/2012. The premises was re-inspected by the officer concerned of this department on 03/06/2016 in the presence of Mrs. Asha Sharma and observed that the said premises have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class **Group-A, Residential (Lodging or Rooming House)** with effect from 16.06.16 for a period of **three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules 2010.

Issued 16.06.16.....at New Delhi by.


(ATUL GARG)
CHIEF FIRE OFFICER
57c 

Copy to:-

- 1) The Joint commissioner Of Police (Licensing Branch)
1st Floor Defence Colony ,New Delhi
- 2) Young Women's Association (Regd), Working Women Hostel No-II,
Avenue-21, Saket, New Delh-110017,

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
2. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
5. The basement shall be used as per the provisions of BBL.
6. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form "J" [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry. The form is available on www.dfs.delhigovt.nic.in

2/15
INSPECTION REPORT

1. Name & address of the building:- Young Women's Association (Regd), Working Women Hostel No-II, Avenue-21, Saket, New Delh-110017
2. Type of occupancy:- Residential, Group-A, Rooming or Lodging Houses
3. Type of case: - Renewal
4. Details of previous NOC: - F6/DFS/MS/GH/2013/4241 dated :- 14/11/2012
5. Fire safety directives No.- Nil
6. Date of inspection:- 03/06/2016
7. Name of the inspecting officer:- D.B.Mukherjee, A.D.O.(BCP)
8. Name & designation of officer From the building side: - Mrs. Asha Sharma
9. Year of construction:- 1979
10. Applicant's letter No:- YWA/NOC/2016-17 dated - 13/05/2016
11. Composition of building:- Basement, Ground + 03 Upper Floors . In other two blocks- GF and 03 upper floors.

| Sl. No | Minimum Standards on fire Prevention and fire safety U/R 33 | BBL/NBC Requirement | Provided at site | Remarks MR/NMR |
|--------|---|---------------------|---|----------------|
| 1. | Access to Building | | | |
| | 1) Road width | Required | Provided | MR |
| | 2) Gate width | Required | Provided | MR |
| | 3) Width of internal road | Required | Provided | MR |
| 2. | Number, Width Type & Arrangement of Exits | | | |
| | A. Number of staircases | | | |
| | 1. Upper floors | 2nos | 02 Nos.in 1 st block, 1no. in 2 nd block & 1 No. in 3 rd block | MR |
| | 2. Basements | Required | 4Nos Provided | MR |
| | B. Width of staircase | | | |
| | 1. Upper floors | Required 1.25mtr | 1.26m & 1.33m in 1 st block, 1.33m in 2 nd block & 1.32m in 3 rd block | MR |
| | 2. Basements | Required | 1.22m, 1.20m, 1.17m & 111m | MR (Old Case) |
| | C. Protection of exits | | | |
| | 1. Fire check door | N/A | N/A | N/A |
| | 2. Pressurization | N/A | N/A | N/A |
| | D. No. of continuous staircase to terrace | Required | 01 Nos.in each block | MR |
| | E. Width of corridor | N/A | N/A | N/A |
| | F. Door size | 1mtr | Provided | MR |
| 3. | Compartmentation | | | |
| | 1) Fire check door | N/A | N/A | N/A |
| | 2) Sealing of electrical shafts | N/A | N/A | N/A |
| | 3) Fire rating of shaft door | N/A | N/A | N/A |
| | 4) Water curtain | N/A | N/A | N/A |
| | 5) Fire Dampers | N/A | N/A | N/A |
| 4. | Smoke Management System | | | |
| | 1) Basements | 30 a/c per hour | Exhaust fan | MR |
| | 2) Upper floors | 12 a/c per hour | N/A | N/A |

| | | | | |
|--|------------------|-------------------------------------|-----|--|
| 5. Fire Extinguishers | | | | |
| 1) Total numbers | ISI Marked | 33 Nos. Provided | MR | |
| 2) Types | | ABC, Co2 | MR | |
| 3) ISI marking | | Yes | MR | |
| 6. First-Aid Hose Reel | | | | |
| 1) Total number of each floor | 01 no. | Provided at each floor & each block | MR | |
| 2) Length of hose reel hose | 30 m | Provided | MR | |
| 3) Nozzle diameter | 5 mm | Provided | MR | |
| 7. Automatic Fire Detection & Alarming System | | | | |
| 1) Type of detectors | N/A | N/A | N/A | |
| 2) Location of main panel | N/A | N/A | N/A | |
| 3) Location of repeater panel | N/A | N/A | N/A | |
| 4) Alternate source of power | N/A | N/A | N/A | |
| 5) Hooter's Location | N/A | N/A | N/A | |
| 8. MOEFA | Required | Provided | MR | |
| 9. Public Address System | Required | Provided | MR | |
| 10. Automatic Sprinkler System | | | | |
| 1) Basement | Required | Provided | MR | |
| 2) Upper floors | N/A | N/A | N/A | |
| 3) Sprinkler above false ceiling | N/A | N/A | N/A | |
| 11. Internal Hydrants | | | | |
| 1) Size of riser/down-comer | N/A | N/A | N/A | |
| 2) Number of hydrants per floor | N/A | N/A | N/A | |
| 3) Hose box | N/A | N/A | N/A | |
| 12. Yard Hydrants | | | | |
| 1) Total number of hydrants | N/A | N/A | N/A | |
| 2) Hose box | N/A | N/A | N/A | |
| 13. Pumping Arrangement | | | | |
| 1) Ground level | N/A | N/A | N/A | |
| a) Discharge of main pump | N/A | N/A | N/A | |
| b) Head of main pump | N/A | N/A | N/A | |
| c) Number of main pump | N/A | N/A | N/A | |
| d) Jockey pump out put | N/A | N/A | N/A | |
| e) Jockey pump head | N/A | N/A | N/A | |
| f) Stand by pump output | N/A | N/A | N/A | |
| g) Stand by pump head | N/A | N/A | N/A | |
| h) Auto starting/Manual stopping | N/A | N/A | N/A | |
| 2) Terrace level | | | | |
| a) Discharge of pump | 450Lpm & 180 Lpm | Provided 450 & 180 Lpm | MR | |
| b) Head of pump | Required | Provided 40mtr | MR | |
| c) Power supply | Required | Provided D G set | MR | |
| d) Auto starting of pump | Required | Provided | MR | |
| 14. Captive Water Storage for Fire Fighting | | | | |
| 1) Underground tank capacity | N/A | N/A | N/A | |
| a) Draw-off connection | N/A | N/A | N/A | |
| b) Fire service inlet | Required | Provided | MR | |
| c) Access to tank | N/A | N/A | N/A | |
| d) Over head tank capacity | 10,000ltr | 10,000 Ltrs. | MR | |
| 15. Exit Signage. | Required | Provided | MR | |

[Handwritten mark]

N/17

| | | | | |
|-----|---|----------|-----------------|-----|
| 16. | Provision of Lifts. | | | |
| | a) Pressurization of lift shaft | N/A | N/A | N/A |
| | b) Pressurization of lift lobby | N/A | N/A | N/A |
| | c) Communication in lift car | N/A | N/A | N/A |
| | d) Fireman's switch | N/A | N/A | N/A |
| | e) Lift signage | N/A | N/A | N/A |
| 17. | Stand by Power Supply | Required | Provided DG Set | MR |
| 18. | Refuge Area | | | |
| | Total area location | N/A | N/A | N/A |
| 19. | Fire Control Room | N/A | N/A | N/A |
| | a) Detector system panel | N/A | N/A | N/A |
| | b) Flow switch panel | N/A | N/A | N/A |
| | c) PA system panel | N/A | N/A | N/A |
| | d) Battery backup | N/A | N/A | N/A |
| | e) Building floor plan | N/A | N/A | N/A |
| 20. | Special Fire Protection System for Protection of special Risk, if any: | | | N/A |

The shortcoming issued vide letter no.F6/DFS/MS/SZ/GH/2015/2540 dated 09/12/15 have been rectified.

In view of the compliance of the minimum standards on fire prevention and fire safety measures as required under the rules the FSC issued vide letter No F6/DFS/MS/ GH/2012/4241 dated 14/11/2012, renewal under rules 35 of the Delhi Fire Service Rules 2010.

Accordingly DFA is put up for perusal and signature pl.

Signature
4/6/16

Signature of the inspecting officer
Name: D.B.Mukherjee.
Designation:- Assistant Divisional Officer (BCP)

~~DY cfo (D.P. Bhargava),~~

~~cfo Atul Ganguly~~
14/6/16
FT P/S