

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI - 110001**

No.F6/DFS/MS/2016/ ND2/1042

Dated 16/06/16

**FIRE SAFETY CERTIFICATE**

Certified that **Reserve Bank of India**, located at **6, Sansad Marg, New Delhi** comprised of Basement + Ground + 03 upper floors owned /occupied by **RBI** has complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and verified by the officer concerned of Delhi Fire Service on 28-05-2016 in the presence of Sh. Aalok Chaturvedi (AGM) & Sh. Ram Kishor (Chief Engineer) that the building / premises, is fit for occupancy Business class Group E with effect from ~~---16/06/---~~16/06/2016 for period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 16/06/16..... at New Delhi by.

  
(Vipin Kental)  
Chief Fire Officer  
Delhi Fire Service  
Ph-011-23414333

Copy to:-

1. Sh. Aalok Chaturvedi,  
Assistant General Manager,  
Reserve Bank of India, 6, Sansad Marg, New Delhi.
2. Fire Officer,  
New Delhi Municipal Council, Palika Kendra, New Delhi.

Condition for the validity of fire safety certificate

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
2. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
7. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry".

INSPECTION REPORT

1. Name & address of the building : Reserve Bank of India, 6, Sansad Marg, New Delhi
2. Type of occupancy : Business Building (B + Gr. 03 Upper floor)
3. Type of case:- : Renewal
4. Details of previous NOC : NA
5. Fire safety directives No. : NA
6. Date of inspection:- 08/04/16
7. Name of the inspecting officer : Sh. G.S. Chauhan DO/CD &  
Sh. M.K. Sharma ADO/CC
8. Name & designation of officer  
From the building side : Sh. Aalok Chaturvedi &  
Sh. Ram Kishor (Chief Engineer)
9. Year of construction : Old
10. Applicant's letter No : ND SI & SU S/48/14.04.003/2015-16  
dated 28/03/2016

Old Case

S.No.	Minimum Standards on fire Prevention and fire safety U/R 33	Requirement	Provided at site	Remarks MR/NMR
1.	Access to Building			
	1) Road width	12 mtr.	16 Mtr.	MR
	2) Gate width	06 mtr.	06 Mtr.	MR
	3) Width of internal road	NA	NA	NA
2.	Number, Width Type & Arrangement of Exits			
	A. Number of staircases			
	1. Upper floors	05 Nos.	05 Nos.	MR
	2. Basements	02 Nos.	02 Nos.	MR
	B. Width of staircase			
	1. Upper floors	1.50 mtr.	2 Nos. 1.50 mtr., 02 Nos. 1.80 mtr., 01 Nos. 2 mtr.	MR
	2. Basements	1.50 mtr.	1.80 mtr. each	MR
	C. Protection of exits			
	1. Fire check door	Required	Provided	MR
	2. Pressurization	NA	NA	NA
	D. No. of continuous staircase to terrace	02 No	02 No	MR
	E. Width of corridor	1 Mtr.	1.5 Mtr.	MR
	F. Door size	1 Mtr.	1.25 Mtr.	MR
3.	Compartmentation			
	1) Fire check door	Required	Provided	MR
	2) Sealing of electrical shafts	Required	Provided	MR
	3) Fire rating of shaft door	NA	NA	NA
	4) Water curtain	NA	NA	NA
	5) Fire Dampers	NA	NA	NA
4.	Smoke Management System			
	1) Basements	30 ACPH	Provided	MR
	2) Upper floors	12 ACPH	Natural	MR

h

Ma

5.	Fire Extinguishers			
	1) Total numbers	Required	Provided	MR
	2) Types	ABC & CO2	ABC, CO2 & W.CO2	MR
	3) ISI marking	Required	Provided	MR
6.	First-Aid Hose Reel			
	1) Total number of each floor	Required	Provided	MR
	2) Length of hose reel hose	30 m	30 m	MR
	3) Nozzle diameter	6 mm	6 mm	MR
7.	Automatic Fire Detection & Alarming System			
	1) Type of detectors	Required	Provided	MR
	2) Location of main panel	Main exit	Main exit	MR
	3) Location of repeater panel	Floor Wise	Floor Wise	MR
	4) Alternate source of power	Required	Provided	MR
	5) Hooter's Location	Each floor	Each floor	MR
8.	MOEFA	Required	Provided	MR
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	1) Basement	Required	Provided	MR
	2) Upper floors	NA	NA	NA
	3) Sprinkler above false ceiling	NA	NA	NA
11.	Internal Hydrants			
	1) Size of riser/down-comer	100 MM	100 MM	MR
	2) Number of hydrants per floor	05	05	MR
	3) Hose box each floor	05	05	MR
12.	Yard Hydrants			
	1) Total number of hydrants	07	07	MR
	2) Hose box	07	07	MR
13.	Pumping Arrangement			
	1) Ground level			
	a) Discharge of main pump	2800 LPM	2800 LPM	MR
	b) Head of main pump	120 mtr.	120 mtr.	MR
	c) Number of main pump	02	02	MR
	d) Jockey pump out put (2 Nos.)	360 LPM	360 LPM	MR
	e) Jockey pump head	120 mtr.	120 mtr.	MR
	f) Stand by pump output	2800 LPM	2800 LPM	MR
	g) Stand by pump head	120 mtr.	120 mtr.	MR
	h) Auto starting/Manual stopping	Required	Provided	MR
	2) Terrace level			
	a) Discharge of pump	N/A	N/A	N/A
	b) Head of pump	N/A	N/A	N/A

h

me

	c) Power supply	N/A	N/A	N/A
	d) Auto starting of pump	N/A	N/A	N/A
14.	Captive Water Storage for Fire Fighting			
	1) Under ground tank capacity	75,000 ltr.	75,000 ltr.	MR
	a) Draw-off connection	Required	Provided	MR
	b) Fire service inlet	Required	Provided	MR
	c) Access to tank			
	d) Over head tank capacity	10,000 ltr.	Provided	MR
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	a) Pressurization of lift shaft	NA	NA	NA
	b) Pressurization of lift lobby	N/A	N/A	N/A
	c) Communication in lift car	Required	Provided	MR
	d) Fireman's switch	Required	Provided	MR
	e) Lift signage	Required	Provided	MR
17.	Stand by Power Supply	Required	Provided	MR
18.	Refuge Area			
	Total area location	N/A	N/A	N/A
19.	Fire Control Room			
	a) Detector system panel	Required	Provided	MR
	b) Flow switch panel	NA	NA	NA
	c) PA system panel	Required	Provided	MR
	d) Battery backup	Required	Provided	MR
	e) Building floor plan	Required	Provided	MR
20.	Special Fire Protection System for Protection of special Risk, if any: ABC & CO <sub>2</sub>			MR

The fire protection systems provided in the building were randomly tested, checked and found functional at the time of inspection.

Shortcomings communicated vide letter No. F6/DFS/MS/2016/969 dated 18/04/2016 have been rectified.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules, grant of fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010 / is recommended please.

Signature of the Inspecting Officer

*G.S Chauhan*

Name :- G.S Chauhan

Designation :- DO (CD)

Signature of the Inspecting Officer

*M.K. Sharma*

Name :- M.K. Sharma

Designation :- ADO (CC)

*Dy CFO (ND2)*

*F1 signed*

*M. S. Cell*

*16/6*

*05/DFS/ND2  
16/6/16*

*[Signature]*

*ADO F.C. men*