

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS, DELHI FIRE SERVICE, NEW DELHI - 110001**

No.F6/DFS/MS/GH/2016/ 1402/1057

Dated : 17/06/16

FIRE SAFETY CERTIFICATE

Certified that the **Jai Balaji Living Guest House** located at **9918/5, Multani Dhanda, Sadar Thana Road, Pahar Ganj, New Delhi** comprised of **Basement + Ground + 03 Upper floors, Basement (locked, less than 200 sqm), Ground floor (Reception + 01 office), 1st floor to 3rd floor (04 guest rooms + 02 staff rooms at each floor), total 12 guest rooms** have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and verified by the officer concerned of Delhi Fire Service on 02/06/2016 in the presence of **Sh. Rakash (Manager)** that the premises is fit for occupancy class **Residential, Sub Division-A-1 as above 12 guest rooms only** with effect from ~~17/06/16~~ for period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules 2010.

Issued 17/06/16 at New Delhi by.


(Vipin Kental)
Chief Fire Officer
Delhi Fire Service

Copy to:-

1. The Addl. Commissioner of Police (Lic), First Floor, P.S. Defence Colony New Delhi
The Manager,
Jai Balaji Living Guest House located at 9918/5, Multani Dhanda, Sadar Thana Road,
Pahar Ganj, New Delhi.

Condition for the validity of fire safety certificate

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
2. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
7. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry".

4/15
INSPECTION REPORT

1. Name & address of the building: Jai Balaji Living Guest House at 9918/5, Multani Dhanda, Sadar Thana Road, Pahar Ganj, New Delhi
 2. Type of occupancy:- Residential, Sub Division-A-1
B + Gr. + 03 Upper floors (total 12 Guest rooms)
 3. Type of case:- Fresh
 4. Details of previous FSC:- N/A
 5. Fire safety directives No.- N/A
 6. Date of inspection:- 02/06/16
 7. Name of the inspecting officer:- Sh. Manoj Kumar Sharma (ADO/CC)
 8. Name & designation of officer: Sh. Rakesh (Manager)
- From the building side:-
9. Year of construction:- 2000
10. Applicant's letter No:- Nil dated 06/05/2016.

S.No.	Minimum Standards on fire Prevention and fire safety U/R 33	Requirement/ Existing fire safety arrangements	Provided at site	Remarks MR/NMR
1. Access to Building				
	1) Road width	N/A	02 mtr.	MR
	2) Gate width	N/A	N/A	N/A
	3) Width of internal road	N/A	N/A	N/A
2. Number, Width Type & Arrangement of Exits				
A. Number of staircases				
	1. Upper floors	01 Nos.	01 Nos.	MR
	2. Basements	01 Nos.	01 Nos.	MR
B. Width of staircase				
	1. Upper floors	0.80 mtr.	0.92 mtr.	MR
	2. Basements	0.80 mtr.	1.0 mtr.	MR
C. Protection of exits				
	1. Fire check door	N/A	N/A	N/A
	2. Pressurization	N/A	N/A	N/A
	D. No. of continuous staircase to terrace	01	01	MR
	E. Width of corridor	N/A	N/A	N/A
	F. Door size	01 mtr.	01 mtr.	MR
3. Compartmentation				
	1) Fire check door	N/A	N/A	N/A
	2) Sealing of electrical shafts	N/A	N/A	N/A
	3) Fire rating of shaft door	N/A	N/A	N/A
	4) Water curtain	N/A	N/A	N/A
	5) Fire Dampers	N/A	N/A	N/A
4. Smoke Management System				
	1) Basements	30 ACPH	N/A	N/A
	2) Upper floors	12 a/c per hour	Natural	MR
5. Fire Extinguishers				
	1) Total numbers	10 Nos.	10 Nos.	MR
	2) Types	ABC & CO2	ABC & CO2	MR
	3) ISI marking	Required	Required	MR

Mew

N/16

6.	First-Aid Hose Reel			
	1) Total number of each floor	N/A	01	N/A
	2) Length of hose reel hose	N/A	30 mtr.	N/A
	3) Nozzle diameter	N/A	05 mm	N/A
7.	Automatic Fire Detection & Alarming System			
	1) Type of detectors	N/A	N/A	N/A
	2) Location of main panel	N/A	N/A	N/A
	3) Location of repeater panel	N/A	N/A	N/A
	4) Alternate source of power	N/A	N/A	N/A
	5) Hooter's Location	N/A	N/A	N/A
8.	MOEFA	N/A	N/A	N/A
9.	Public Address System	N/A	N/A	N/A
10.	Automatic Sprinkler System			
	1) Basement less than 200 SQM	N/A	N/A	N/A
	2) Upper floors	N/A	N/A	N/A
	3) Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants			
	1) Size of riser/down-comer	N/A	N/A	N/A
	2) Number of hydrants per floor	N/A	N/A	N/A
	3) Hose box	N/A	N/A	N/A
12.	Yard Hydrants			
	1) Total number of hydrants	N/A	N/A	N/A
	2) Hose box	N/A	N/A	N/A
13.	Pumping Arrangement			
	1) Ground level	N/A	N/A	N/A
	a) Discharge of main pump	N/A	N/A	N/A
	b) Head of main pump	N/A	N/A	N/A
	c) Number of main pump	N/A	N/A	N/A
	d) Jockey pump out put	N/A	N/A	N/A
	e) Jockey pump head	N/A	N/A	N/A
	f) Stand by pump output	N/A	N/A	N/A
	g) Stand by pump head	N/A	N/A	N/A
	h) Auto starting/Manual stopping	N/A	N/A	N/A
	2) Terrace level			
	a) Discharge of pump	N/A	450 LPM	N/A
	b) Head of pump	N/A	30 mtr.	N/A
	c) Power supply	N/A	Provided	N/A
	d) Auto starting of pump	N/A	Provided	N/A
14.	Captive Water Storage for Fire Fighting			
	1) Under ground tank capacity	N/A	N/A	N/A
	a) Draw-off connection	N/A	N/A	N/A
	b) Fire service inlet	N/A	N/A	N/A
	c) Access to tank	N/A	N/A	N/A
	d) Over head tank	5000 ltr.	5000 ltr.	MR

MR

7/17

15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	a) Pressurization of lift shaft	N/A	N/A	N/A
	b) Pressurization of lift lobby	N/A	N/A	N/A
	c) Communication in lift car	N/A	N/A	N/A
	d) Fireman's switch	N/A	N/A	N/A
	e) Lift signage	N/A	N/A	N/A
17.	Stand by Power Supply	N/A	N/A	N/A
18.	Refuge Area	N/A	N/A	N/A
	Total area location	N/A	N/A	N/A
19.	Fire Control Room	N/A	N/A	N/A
	a) Detector system panel	N/A	N/A	N/A
	b) Flow switch panel	N/A	N/A	N/A
	c) PA system panel	N/A	N/A	N/A
	d) Battery backup	N/A	N/A	N/A
	e) Building floor plan	N/A	N/A	N/A
20.	Special Fire Protection System for Protection of special Risk, if any:			NA

Shortcomings communicated vide letter No. F6/DFS/MS/GH/2015/540 & F6/DFS/MS/GH/2016/881 dated 17/03/2015 & 07/04/2016 have been rectified.

The fire protection systems provided in the building were randomly tested, checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules, grant of fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010 / is recommended please.

Signature of the Inspecting Officer

M.K. Sharma

Name: - M.K. Sharma
Designation: - ADO (CC)

~~DO(CD)~~

Behram
14/10/16