

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110 001

No. F4068/ms/school/2016/N22/1063

Dated: 21/06/16

FIRE SAFETY CERTIFICATE

Certified that the **Sneh International School** at New Rajdhani Enclave, Vikas Marg, Delhi-92. Comprised of basement ground plus two upper floors owned/occupied by Sneh International School have been deemed to comply with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and verified by the officer concerned of Fire Service on 01/06/16 & 06/06/16 in the presence of Sh. Subhash Dhingra, President, of the school and that the building is fit for occupancy class B' Educational Building' with effect from 21/06/16 for a period of **three** years in accordance with the rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010, printed overleaf.

Issued on 21/06/16 at New Delhi by


(Virendra Singh)
Dy. Chief Fire Officer

To,
Sh. Subhash Dhingra (President)
Sneh International School
New Rajdhani Enclave,
Vikas Marg, Delhi-92.

Copy:-
The Director of Education
Directorate of Education,
Lucknow Road, Delhi -54.

o/c
Rk

1. Name & address of the building : Sneh International School at Vikas Marg,
New Rajdhani Enclave, Delhi-92.
2. Building is comprised of : B+G+2 upper floors.
3. Type of Occupancy : Educational
4. Type of Case : Renewal
5. Details of Previous FSC letter : F6/DFS/MS/SCHOOL/2013/343 dt-21/05/13
6. Fire Safety direction letter No : NBC Part-IV
7. Date of Inspection : 01/06/16 & 06/06/16
8. Name of the Inspecting officers : ADO R.K.Yadav
9. Name and designation of Officer:
from the building side : Mr. Subhash Dhigra (President)
10. Year of Construction : 2004-12
11. Applicant's letter No : Nil Dated- 20/05/16

S. N	Minimum Standards on fire prevention and fire safety U/R33	NBC Part-IV Requirement	Provided at Site	Remarks MR/NMR
1	Access to building			
	• Road width	6 m.	15 m.	MR
	• Gate width	4.5 m.	4.5 m.	MR
	• Width of internal road	N/A	N/A	N/A
2	Number, Width, Type and Arrangement of Exits			
	a. Number of Staircases			
	• Upper Floor	02Nos.	02Nos.	MR
	• Basement	02Nos.	02Nos.	MR
	B. Width of Staircases			
	• Upper Floor	1.50 m.	1.50 m.each	MR
	• Basement	1.50 m.	1.50 m.each	MR
	c. Protection of exits			
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	d. No. of continuous staircases to terrace	01 Nos.	02 Nos.	MR
	e. Width of Corridor	1.50m.	1.50m.	MR
	f. Door Size	01 m.	01 m.	MR
3	Compartmentation.			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire rating of shaft door	N/A	N/A	N/A
	• Water curtain	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A
4	Smoke Management System.			
	• Basement	N/A	N/A	N/A
	• Upper floor	N/A	N/A	N/A
5.	Fire Extinguishers			
	• Total numbers	16 nos.	16 nos.	MR
	• types	ABC /CO ₂	ABC /CO ₂	MR
	• IS marking	ISI marked	ISI marked	MR

6	First-aid-Hose Reels.			
	Total numbers of each floor	2 Nos.	Provided	MR
	• Length of hose reel hose	30mtr.	Provided	MR
	• Nozzle diameter	05mm	Provided	MR
7	Automatic fire detection and alarming system.			
	• Type of detectors	N/A	N/A	N/A
	• Location of main panel	N/A	N/A	N/A
	• Location of repeater panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooter's location	N/A	N/A	N/A
8	MOEFA	N/A	N/A	N/A
9	Public address System.	Required	Provided	MR
10	Automatic Sprinkler System.			
	• Basement	Required	Provided	MR
	• upper floor	N/A	N/A	N/A
	• sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants			
	• size of riser/down-comer	Not Required	100 mm	MR
	• Number of hydrants per floor	Not Required	2 Nos each floor	MR
	• Hose Box	Not Required	2 Nos each floor	MR
12	Yard Hydrants.			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
13	Pumping Arrangements.			
	• Ground Level			
	➤ Discharge of main Pump	N/A	N/A	N/A
	➤ Head of Main Pump	N/A	N/A	N/A
	➤ Number of main pumps	N/A	N/A	N/A
	➤ Jockey pump out put	N/A	N/A	N/A
	➤ Jockey pump head	N/A	N/A	N/A
	➤ Standby pump out put	N/A	N/A	N/A
	➤ Standby pump Head	N/A	N/A	N/A
	➤ Auto Starting /Manual stopping	N/A	N/A	N/A
	➤ Pump House Access	N/A	N/A	N/A
	• Terrace Level	Required	Provided	MR
	➤ Discharge of pump	2 nos.of 450 Lpm.	1 no.of 450 Lpm, 1 no.of 950 Lpm	MR
	➤ Head of the Pump	40 M	Provided	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto Starting of pump	Required	Provided	MR
14	Captive Water Storage for Fire Fighting.			
	• Underground tank capacity	N/A	N/A	N/A
	➤ Draw-off connection	N/A	N/A	N/A
	➤ Fire service inlet	Required	Provided	MR
	➤ Access to tank	Required	Provided	MR
	• Overhead Tank capacity	15,000 Ltr.	15,000Ltr.	MR
15	Exit Signage.	Required	Provided	MR

N/14

16	Provision of Lifts.			
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication in lift car	N/A	N/A	N/A
	• Firemen's grounding switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A
17	Standby power supply	N/A	N/A	N/A
18	Refuge Area.			
	• Total area	N/A	N/A	N/A
	• Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector system panel	N/A	N/A	N/A
	• Flow switch panel	N/A	N/A	N/A
	• PA system panel	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection systems for protection of special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were tested checked and found functional at the time of inspection.

Keeping in view the compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to renew Fire Safety Certificate under rule 35 of the Delhi Fire Service Rule 2010.

R. K. Yadav
7/6/2016

Signature of the Inspecting Officer

Name R.K.Yadav

Designation ADO(LN)

DY CFO (V.S.)

Submitted for approval please.

Wing
10/6/16

CFO (NOZ)

DCFO (V.S.)

Went
10/6