

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001
Fax: 23412593, Email: director.dlfire@nic.in, Tel:- 011-23414000


NO.F6/ DFS/MS/SZ/School/2016/ 1072

Dated: 23/06/16

FIRE SAFETY CERTIFICATE

Certified that The Cambridge International School, located at C-198, Jawahar Park, Main Khanpur Devli Road, New Delhi-110062 comprised of two blocks- Primary Block-ground plus three upper floor and Senior block-ground plus three upper floors owned/occupied by The Cambridge International School was granted FSC by this department vide letter no. F6/DFS/MS/School/2013/385 Dated 29/05/13. The school building was re-inspected by the officer concerned of this department on 09/06/2016 in the presence of Mr. Samandhar and found that the management has added one more floor in the senior block and thus the composition of the school building is now Primary Block-ground plus three upper floor and Senior block-ground plus three upper floors. The said premises have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises fit for occupancy class **Educational Building (School)** with effect from....23/06/16...or period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules 2010.

Issued on...23/06/16...at New Delhi by.


(ATUL GARG)
CHIEF FIRE OFFICER
ec

Copy to: -

The Manager
The Cambridge International School,
C-198, Jawahar Park, Main Khanpur Devli Road,
New Delhi-110062

Conditions for the validity of fire safety certificate

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk & responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviation w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. The owner/occupier shall submit a declaration every year in form 'K' Provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in
7. The owner / occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form "J" [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry. The form is available on www.dfs.delhigovt.nic.in

219

INSPECTION REPORT

1. Name & address of the building:- The Cambridge International School,C-198,Jawahar Park, Main Khanpur Devli Road, New Delhi-110062
2. Type of occupancy:- Educational (School)
3. Type of case: - Renewal/addition
4. Details of previous NOC: - F6/DFS/MS/School/2013/385 Dated 29/05/13
5. Fire safety directives No.- Nil
6. Date of inspection:- 09/06/2016
7. Name of the inspecting officer:- D.B.Mukherjee, A.D.O.(BCP)
8. Name & designation of officer From the building side: - Mr. Samandhar
9. Year of construction:- 2002
10. Applicant's letter No:- Nil dated 20/05/2016
11. Composition of building: - School is in two Blocks- Primary Block-Ground Plus Three Upper Floor and Senior Block- Ground Plus Three Upper Floors.

Sl. No	Minimum Standards on fire Prevention and fire safety U/R 33	BBL/NBC Requirement	Provided at site	Remarks MR/NMR
1.	Access to Building			
	1) Road width	9mtr	Provided	MR
	2) Gate width	4mtr	Provided	MR
	3)Width of internal road	N/A	N/A	N/A
2.	Number, Width Type & Arrangement of Exits			
	A. Number of staircases			
	1. Upper floors	01no	Primary Block-02nos Senior Block-02nos.	MR
	2. Basements	N/A	N/A	N/A
	B. Width of staircase			
	1. Upper floors	1.50m	Primary block-1.50&1.70m Senior block- 1.50m each	MR
	2. Basements	N/A	N/A	N/A
	C. Protection of exits			
	1. Fire check door	N/A	N/A	N/A
	2. Pressurization	N/A	N/A	N/A
	D. No. of continuous staircase to terrace	01no	Provided 03nos	MR
	E. Width of corridor	1.5m	Provided 2.34 mtr	MR
	F. Door size	1m	1m	MR
3.	Compartmentation			
	1) Fire check door	N/A	N/A	N/A
	2) Sealing of electrical shafts	N/A	N/A	N/A
	3) Fire rating of shaft door	N/A	N/A	N/A
	4) Water curtain	N/A	N/A	N/A
	5) Fire Dampers	N/A	N/A	N/A
4.	Smoke Management System			
	1) Basements	30 a/c per hour	N/A	N/A
	2) Upper floors	12 a/c per hour	Open Corridor	MR

N/110

5.	Fire Extinguishers			
	1) Total numbers	ISI Marked	43 Nos	MR
	2) Types		ABC, Co2	MR
	3) ISI marking		Yes	MR
6.	First-Aid Hose Reel			
	1) Total number of each floor	01nos	Provided at each floor	MR
	2) Length of hose reel hose	30m	Provided	MR
	3) Nozzle diameter	5mm	Provided	MR
7.	Automatic Fire Detection & Alarming System			
	1) Type of detectors	N/A	N/A	N/A
	2) Location of main panel	N/A	N/A	N/A
	3) Location of repeater panel	N/A	N/A	N/A
	4) Alternate source of power	N/A	N/A	N/A
	5) Hooter's Location			
8.	MOEFA	Required	Provided	MR
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	1) Basement	N/A	N/A	N/A
	2) Upper floors	N/A	N/A	N/A
	3) sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants			
	1) Size of riser/down-comer	N/A	N/A	N/A
	2) Number of hydrants per floor	N/A	N/A	N/A
	3) Hose box	N/A	N/A	N/A
12.	Yard Hydrants			
	1) Total number of hydrants	N/A	N/A	N/A
	2) Hose box	N/A	N/A	N/A
13.	Pumping Arrangement			
	1) Ground level	N/A	N/A	N/A
	a) Discharge of main pump	N/A	N/A	N/A
	b) Head of main pump	N/A	N/A	N/A
	c) Number of main pump	N/A	N/A	N/A
	d) Jockey pump out put	N/A	N/A	N/A
	e) Jockey pump head	N/A	N/A	N/A
	f) Stand by pump output	N/A	N/A	N/A
	g) Stand by pump head	N/A	N/A	N/A
	h) Auto starting/Manual stopping	N/A	N/A	N/A
	2) Terrace level			
	a) Discharge of pump	450LPm	450LPm X2	MR
	b) Head of pump	40mtr	Provided	MR
	c) Power supply	Required	Provided	MR
	d) Auto starting of pump	Required	Provided	MR
14.	Captive Water Storage for Fire Fighting			
	1) Underground tank capacity	N/A	N/A	N/A
	a) Draw-off connection	N/A	N/A	N/A
	b) Fire service inlet	N/A	N/A	N/A
	c) Access to tank	N/A	N/A	N/A
	d) Over head tank capacity	10,000ltr	Provided	MR
15.	Exit Signage.	Required	Provided	MR

2/11

16.	Provision of Lifts.			
	a) Pressurization of lift shaft	N/A	N/A	N/A
	b) Pressurization of lift lobby	N/A	N/A	N/A
	c) Communication in lift car	N/A	N/A	N/A
	d) Fireman's switch	N/A	N/A	N/A
	e) Lift signage	N/A	N/A	N/A
17.	Standby Power Supply	Required	Provided	MR
18.	Refuge Area	N/A	N/A	N/A
	Total area location	N/A	N/A	N/A
19.	Fire Control Room	N/A	N/A	N/A
	a) Detector system panel	N/A	N/A	N/A
	b) Flow switch panel	N/A	N/A	N/A
	c) PA system panel	N/A	N/A	N/A
	d) Battery backup	N/A	N/A	N/A
	e) Building floor plan	N/A	N/A	N/A
20.	Special Fire Protection System for Protection of special Risk, if any:			N/A

The fire protection systems provided in the school were checked and found functional at the time of inspection.

Keeping in view of the compliance of the minimum standards on fire prevention and fire safety measures as required under the rules the FSC issued vide letter No. F6/DFS/MS/School/2013/385 Dated 29/05/13 renewal under rules 35 of the Delhi Fire Service Rules 2010 is recommended to issue fire safety certificate.

Accordingly DFA is put up for sign pl.


9/6/16

Signature of the inspecting officer

Name: - D.B. Mukherjee.

Designation:- Assistant Divisional Officer (BCP)

Dy Cfo (D. P. Bhandwari)

Cfo. Atul Garg
10/6/16

