

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110 001

No. 156/DFS/MS/EH/2016/52/1108

Dated: 01/07/16

FIRE SAFETY CERTIFICATE

Certified that M/S New Minar Restaurant located at M-65, M-Block Market, Greater Kailash-I, New Delhi-110048, comprised of Basement, Ground, plus two upper floors but Restaurant is at ground, 1<sup>st</sup> & 2<sup>nd</sup> floors only, was granted Fire Safety Certificate by this department vide letter No. F6/MS/DFS/EH/2013/399, dated 30-05-13. The premises was re-inspected by the officer concerned of this department on 17-06-2016 in the presence of Sh. Jitender Chopra, Owner and found that the said eating house (Ground plus two upper floors only) have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class Group-D Assembly Building(Eating House) with effect from 01/07/2016 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 01/07/2016 at New Delhi by.



(Rajesh Panwar)

Chief Fire Officer

T.No.011-23412025

To:- M/S New Minar Restaurant located at Ground, 1st & 2nd Floors, M-65, M-Block Market, Greater Kailash-I, New Delhi-110048.

Conditions for the validity of fire safety certificate are under:-

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities.
5. This Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
7. The owner/occupier shall apply for renewal of this Fire Safety Certificate in form J, six month prior to its expiry.

## INSPECTION REPORT

1	Name & address of the building	M/S New Minar Restaurant located at Ground, 1st & 2nd Floors, M-65, M-Block Market, Greater Kailash-I, New Delhi-110048.		
2	Building comprised of	Basement, Ground plus two upper floors. Restaurant is at ground, 1st & 2nd floors only.		
3	Type of Occupancy	Assembly building "D" Restaurant		
4	Type of case	Renewal		
5	Details of previous NOC	F6/MS/DFS/EH/2013/399, dt 30.05.2013.		
6	Fire safety directives letter No	Nil		
7	Date of inspection	17.06.2016.		
8	Name of the inspecting Officers	ADO Vedpal		
9	Name and designation of officers from the building side	Mr. Jitendra Chopra, Owner.		
10	Year of construction	2005		
11	Applicant's letter No.	Nil, Dated 10.06.2016.		

S. NO.	Minimum Standards on fire prevention and fire safety U/R	Requirement as per BBL	Provided at site	Remarks MR / NMR
<b>1</b>	<b>Access to building</b>			
	1) Road width	9m	4.5m	MR (Old Case)
	2) Gate width	N/A	N/A	N/A
	3) Width of internal road	N/A	N/A	N/A
<b>2</b>	<b>Number, width Type &amp; arrangement of exits</b>			
	<b>a. Number of staircases</b>			
	1. Upper floors	2 Nos	02 Nos.	MR
	2. basements	N/A	N/A	N/A
	<b>b. Width of staircase</b>			
	1. Upper floors	1.25 Mtr	1.11m & 72cm	MR (Old Case)
	2. basements	N/A	N/A	N/A
	<b>c. Protection of exits</b>			
	1. Fire check door	N/A	N/A	N/A
	2. Pressurization	N/A	N/A	N/A
	<b>d. No. of continuous staircase to terrace</b>	Required	01no.	MR
	<b>e. Width of corridor</b>	N/A	N/A	MR
	<b>f. Door size</b>	1.5m(02nos.)	1.5m & 1m	MR(old case)
<b>3</b>	<b>Compartmentation.</b>			
	1. Fire check door	N/A	N/A	N/A
	2. Sealing of electrical shafts	N/A	N/A	N/A
	3. Fire Rating of shaft door	N/A	N/A	N/A
	4. water curtain	N/A	N/A	N/A
	5. Fire dampers	N/A	N/A	N/A
<b>4</b>	<b>Smoke Management system.</b>			
	basement	30 a/c per hour	N/A	N/A
	upper floors	12 a/c per hour	Exhaust Fans	MR
<b>5</b>	<b>Fire Extinguishers</b>			
	total numbers	06Nos	08 Nos	MR
	Types	ABC & CO2	ABC, Co2, Foam	MR
	ISI marking	ISI	Yes	MR
<b>6</b>	<b>First-Aid Hose Reels.</b>			
	total numbers on each floor	1 nos.	01no.	MR
	Length of Hose reel hose	30 m	30m	MR

7	<b>Automatic fire detection and alarming system</b>			
	Type of detectors	N/A	N/A	N/A
	location of Main Panel	N/A	N/A	N/A
	location of Repeater panel	N/A	N/A	N/A
	Alternate source of power	N/A	N/A	N/A
	hooter's location	N/A	N/A	N/A
8	<b>MOEFA</b>	Required	Provided	MR
9	<b>Public Address System.</b>	N/A	Provided	N/A
10	<b>Automatic Sprinkler System.</b>			
	basement	N/A	N/A	N/A
	upper floors	Required	Provided	MR
	sprinkler above false ceiling	N/A	N/A	MR
11	<b>Internal Hydrants</b>			
	Size of riser/down-corner	100mm	100mm	MR
	Number of Hydrants per floor	01no.	01no.	MR
	hose Box	01no.	01no.	MR
12	<b>Yard Hydrants.</b>			
	total number of hydrants	N/A	N/A	N/A
	hose box	N/A	N/A	N/A
13	<b>Pumping arrangements</b>			
	<b>1. Ground level</b>			
	a. Discharge of main Pump	N/A	N/A	MR
	b. Head of main pump	N/A	N/A	MR
	c. Number of main pumps	N/A	N/A	MR
	d. jockey pump out put	N/A	N/A	MR
	e. jockey pump head	N/A	N/A	MR
	f. Standby Pump output	N/A	N/A	MR
	g. Stanby Pump head	N/A	N/A	MR
	h. Auto Starting/Manual stopping	N/A	N/A	MR
	pump house access	N/A	N/A	MR
	<b>2. Terrace level</b>			
	a. Discharge of pump	450LPM	450 & 180 LPM	MR
	b. head of the pump	35 mtr	35 mtr (each)	MR
	c. Power supply	Required	Provided	MR
	d. Auto starting of pump	Required	Provided	MR
14	<b>Captive water storage for fire fighting</b>			
	1. Underground tank capacity	N/A	N/A	N/A
	a. Draw-off connection	N/A	N/A	N/A
	b. fire service inlet	N/A	N/A	N/A
	c. Access to tank	N/A	N/A	N/A
	Over head tank Capacity	5,000 ltr	5000Liters	MR
15	<b>Exit Signage.</b>	Required	Provided	MR
16	<b>Provision of lifts.</b>			
	a. Pressurization of lift shaft	N/A	N/A	N/A
	b. pressurization of lift lobby	N/A	N/A	N/A
	c. communication in lift car	N/A	N/A	N/A
	d. Fireman's grounding switch	N/A	N/A	N/A
	e. Lift signage	N/A	N/A	N/A
17	<b>Standby power supply</b>	Required	Provided	MR
18	<b>Refuge Area.</b>			
	total area	Not Required		
	location			

19	Fire control room			
	a. detector system Panel	N/A	N/A	N/A
	b. Flow switch Panel	N/A	N/A	N/A
	c. PA system Panel	N/A	N/A	N/A
	d. Batter backup	N/A	N/A	N/A
	e. Building floor plans	N/A	N/A	N/A

**20 Special Fire Protection systems for protection of special risks, if any:**

The fire protection systems provided in the building were test checked randomly and found functional at the time of inspection. In view of the deemed compliance of the minimum standards on fire prevention and fire safety required under the rules the SFC issued vide letter No.F.6/MS/DFS/EH/2013/399, dated 30.05.2013 renewal under rule 37 of the Delhi Fire Service Rule 2010 is recommended.

Accordingly DFA is put up for your approval and signature please.

*[Handwritten Signature]*  
19/6/16

Signature of the inspecting officer

Name Vedpal

Designation : Assistant Divisional Officer

~~D.O. (S.D)~~  
*[Handwritten Signature]*  
23/6/16

Dy. (SP) (S2)

DCFO/S2/1145  
27/6/16

*[Handwritten Signature]*  
27/6/16

F7 M.

CFo(S2)

*[Handwritten Signature]*  
27/6