

FORM 'H'
FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[Refer sub - rule (1) of rule 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI

No.

F6/DFS/MS/BANQUET/2016/WZ/1098

Dated:

30/06/16

FIRE SAFETY CERTIFICATE

Certified that the **Wok in The Clouds (Banquet Hall)** located at **FC 01 3rd floor TDI Mall, Shivaji Place, Rajouri Garden, New Delhi**. Comprised of Class – D (Assembly) was issued FSC vide Letter No. F6/DFS/MS/Banquet/2012/245 dated 27/01/12. FSC to the mall is issued vide letter no. F6/DFS/MS/2016/WZ/68 dated 07-01-2016. The premises was re inspected by the officers concerned of this department on 25-05-2016 in the presence of Sh. Vipin Kumar (Owner) and found that the said building have deem complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rule, 2010 and that the premises is fit for occupancy class “Assembly” Group D with effect from 30/06/16 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on30/06/16..... at New Delhi by.

W
28/6
(Vipin Kental)
Chief Fire Officer,
Delhi Fire Service.

Copy to:

1. Sh. Vipin Kumar (Owner),
M/s Wok in the Clouds (Banquet Hall)
FC 01 3rd floor TDI Mall, Shivaji Place, Rajouri Garden, New Delhi..
Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. Basement shall be used as per building bye laws.
7. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
8. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.

INSPECTION REPORT

1. Name & address of the building: **Wok in The Clouds (Banquet Hall)** located at **FC 01 3rd floor TDI Mall, Shivaji Place, Rajouri Garden, New Delhi.**
2. Type of Occupancy : Class – D (Assembly)
3. Type of Case : Renewal
4. Details of previous NOC : Letter No. F6/DFS/MS/banquet/2012/245 dated- 27/01/12.
FSC to the mall is issued vide letter no. F6/DFS/MS/2016/WZ/68 dated 07-01-2016.
5. Fire Safety directives Letter No. : Nil
6. Date of inspection : 25/05/2016
7. Name of the Inspecting Officer : Sunil Chawdhary (DO), Mukesh Verma ADO (MN)
8. Name and designation of Officer
from the building side : Mr. Vipin Kumar (Owner)
9. Year of Construction : 2004,05
10. Applicant's letter No. : Nil Dated -Nil

S No	Minimum standards on fire prevention and fire safety U/R 33	N.B.C. Requirements	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	09 mtrs	30 mtr	MR
	• Gate width	6 mtr	6 mtr	MR
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	5	Provided	MR
	• Basements	8+2 ramps	Provided	MR
	b. Width of staircases			
	• Upper floors	1.5 mtr & 1.25 mtr	Provided	MR
	• Basements	1.5 mtr & 1.25 mtr	Provided	MR
	c. Protection of exits			
	• Fire check door	Required	Found Provided	MR
	• Pressurization	Required	Provided	MR
	d. No of continuous staircase to terrace	5	Provided	MR
	e. Width Of Corridor	2	2.5	MR
	f. Door Size	2 mtrs	Provided by the Banquet management	Provided by the Banquet management/MR
3.	Compartmentation: Common with the mall			
	• Fire check door	Required	Provided	MR
	• Sealing of electrical shafts	Required	Provided	MR
	• Fire Rating of shaft door	1 hrs	Provided	MR

	<ul style="list-style-type: none"> Water Curtain Fire Dampers 	NR Required	NR Provided	NR MR
4.	Smoke managements System			
	<ul style="list-style-type: none"> Basements Upper floors 	NA Required	Provided Provided	NA MR
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> Total numbers Types IS marking 	06 nos. ABC, CO ₂ & ISI marked	Provided Provided Provided	MR MR MR
6.	First – Aid Hose Reels			
	<ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter 	Four 30 m 5 mm	Provided Required Provided	MR MR MR
7.	Automatic fire detection and alarming system: Common with the mall			
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location 	Smoke Ground floor Ground floor Required All over building	Provided Provided Provided Provided Provided	MR MR MR MR MR
8.	MOEFA	Required	Provided	MR
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System: Common with mall			
	<ul style="list-style-type: none"> Basements Upper Floor Sprinkler above false ceiling 	NA Required Required	Provided Provided Provided	NA MR MR
11.	Internal Hydrants: Common with mall			
	<ul style="list-style-type: none"> Size of riser/down- comer Number of hydrants per floor Hose Box 	150 mm 4 4	Provided Provided Provided	MR MR MR
12.	Yard Hydrants: Common with mall			
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	NA NA	4 4	NA NA
13.	Pumping Arrangements: Common with mall			
	<ul style="list-style-type: none"> Ground Level Discharge of main pump ➤ Head of main pump ➤ Number of main pumps ➤ Jockey pump out put ➤ Jockey pump head ➤ Standby Pump out put ➤ Standby Pump Head ➤ Auto Staring/Manual stopping ➤ Pump House Access • Terrace level 			
		2280 LPM	4500 LPM	MR
		65 mtr	65 mtr	MR
		2	2	MR
		180 lpm	180 lpm	MR
		65 mtr	65 mtr	MR
		2280 LPM	4500 LPM	MR
		65 mtr	65 mtr	MR
		Required	Provided	MR
		Required	Provided	MR

	➤ Discharge of pump	900 LPM	Provided	MR
	➤ Head of the pump	65 mtr	Provided	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto starting of pump	Required	Provided	MR
14.	Captive water Storage for fire fighting			
	• Under ground tank capacity	50,000 litres	One lakh	MR
	➤ Draw of connection	Required	Provided	MR
	➤ Fire service inlet	Required	Provided	MR
	➤ Access to tank	Required	Provided	MR
	• Overhead Tank capacity	Required	30, 000 litres	MR
15	Exit Signage			
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	NA	Provided	NA
	➤ Pressurization of lift lobby	NA	Provided	NA
	➤ Communication in lift Car	NA	Provided	NA
	➤ Fireman's Grounding Switch	NA	Provided	NA
	➤ Lift Signage	NA	Provided	NA
17.	Standby power supply			
18.	Refuge Area			
	➤ Total area	NR	NR	Not applicable
	➤ Location	NR	NR	Not applicable
19.	Fire control room			
	➤ Detector system panel	Required	Provided	MR
	➤ Flow Switch Panel	Required	Provided	MR
	➤ PA System Panel	Required	Provided	MR
	➤ Battery backup	Required	Provided	MR
	➤ Building Floor Plans	Required	Provided	MR
20.	Special Fire Protection Systems for Protection of special Risks, if any;			
		NR	NR	Not applicable

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of minimum standards on fire prevention and fire safety required under the rules the NOC issued vide letter no F6/DFS/MS/Banquet/2012/245 dated- 27/01/2016 renewal under rule 35 of the Delhi Fire Service Rules 2010 is recommended.

Signature of the Inspecting Officer
 Name
 Designation

Mukesh Verma
 31/5
 Mukesh Verma
 ADO (MM)

Signature of the Inspecting Officer
 Name
 Designation

[Signature]
 21/6
 FTM

[Signature]

[Signature]
 17/6

C.F.B. m.scell 22/6

As approved, FSC is put up for signature please.

21/6
 22/6/29/16

[Signature]
 21/6