

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI

HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110 001

NO. F6/DFS/MS/Club/2016/1129

Dated: 08/07/16

FIRE SAFETY CERTIFICATE

Certified that M/S Defence Colony (WA) Club, located at C-600, Chetna Marg, Defence Colony, New Delhi-110024, comprised of ground plus one upper floor, owned/occupied by M/S Defence Colony (WA) Club, was granted Fire Safety Certificate by this department vide letter No. F6/DFS/MS/Club/2012/141, dated 09-01-2013. The premises was re-inspected by the officer concerned of this department on 29-06-2016 in the presence of Sh. Kamal Sharma, Manager and found that the said club premises have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class "D" (Assembly Building) with effect from ...08/07/2016 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of Delhi Fire Service Rules, 2010.

Issued on...08/07/16...2016 at New Delhi by


(Vipin Kental)

Chief Fire Officer

T.No.011-23413933

Copy to:- Sh. Shammi Chadha, Hony. General Secretary M/S Defence Colony (WA) Club, located at C-600, Chetna Marg, Defence Colony, New Delhi-110024.

Conditions for the validity of fire safety certificate are as under:-

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. The employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All fire fighting equipments shall be maintained in perfect working condition all time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities.
5. This Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in.
7. The owner/occupier shall apply for renewal of this Fire Safety Certificate, six month prior to its expiry.

INSPECTION REPORT


1. Name & address of the building : M/S Defence Colony (WA) Club, located at C-600, Chetna Marg, Defence Colony, New Delhi-110024.
2. Building is comprised of : Ground +one Upper floor.
3. Type of Occupancy : Club Building (Assembly Occupancy i.e. Eating House).
4. Type of Case : Renewal.
5. Details of Previous NOC : No.F6/DFS/MS/2013/Club/141, dated 09.01.2013.
6. Fire Safety direction letter No : Nil.
7. Date of Inspection : 29.06.2016.
8. Name of the Inspecting Officers: : Vedpal (ADO)
9. Name and designation of Officer from the building side : Sh. Kamal Sharma (Manager).
10. Year of Construction : 1976.
11. Applicant's letter No : No. DCC/43/Fire/2016, Dated 04.06.16.

S.No	Minimum Standards on fire prevention and fire safety U/R33	Requirements as Per BBL/NBC	Provided at Site	Remarks
1	Access to building			
	Road width	12m	12 m	MR
	Gate width	5m	5m	MR
	Width of internal road	N.A.	N.A.	N.A.
2	Number, Width, Type and Arrangement of Exits.			
	a. Number of Staircases			
	Upper Floor	03nos.	03nos.	MR
	Basement	N.A.	N.A.	N.A.
	B. Width of Staircases			
	Upper Floor	1.25m	1.17m, 1.05m & 59cm	MR(old case)
	Basement	N.A.	N.A.	N.A.
	c. Protection of exits			
	Fire check door	N.A.	N.A.	N.A.
	Pressurization	N.A.	N.A.	N.A.
	e. No. of continuous staircases to terrace	01no.	01no.	MR
	g. Width of Corridor			
	h. Door Size	N.A.	N.A.	N.A.
3	Compartmentation			
	Fire check door	N.A.	N.A.	N.A.
	Sealing of electrical shafts	N.A.	N.A.	N.A.
	Fire rating of shaft door	N.A.	N.A.	N.A.
	Water curtain	N.A.	N.A.	N.A.
	Fire Dampers	N.A.	N.A.	N.A.
4	Smoke Management System.			
	Basement	30a/c per hour	N/A	N/A
	Upper floor	12 a/c per hour	Exhaust fans Provided	MR
5	Fire Extinguisher			
	Total numbers	12 nos.	25 nos.	MR
	types	CO ₂ & ABC	CO ₂ & ABC	MR
	IS marking	ISI marked	ISI marked	MR
6	First-aid-Hose Reels.			
	Total numbers on each floor	01no.	01no.	MR
	Length of hose reel hose	30m.	30m Provided	MR
	Nozzle diameter	5mm	5mm Provided	MR
7	Automatic fire detection and alarming system.			
	Type of detectors	N.A.	N.A.	N.A.
	Location of main panel			

8	MOEFA	Required	Provided	MR
9	Public address System.	Required	Provided	MR
10	Automatic Sprinkler System.			MR
	Basement	N.A.	N.A.	N.A.
	upper floor	Required	Provided	MR
	sprinkler above false ceiling	N.A.	N.A.	N.A.
11	Internal Hydrants			
	size of riser/down-comer	100mm	100mm	MR
	Number of hydrants per floor	01no.	01no.	MR
	Hose Box	01no.	01no.	MR
12	Yard Hydrants.			
	Total number of hydrants	04nos.	04nos.	MR
	Hose Box	04nos.	04nos.	MR
13	Pumping Arrangements.			
	• Ground Level	N.A.	N.A.	N.A.
	➤ Discharge of main Pump	N.A.	N.A.	N.A.
	➤ Head of Main Pump	N.A.	N.A.	N.A.
	➤ Number of main pumps	N.A.	N.A.	N.A.
	➤ Jockey pump out put	N.A.	N.A.	N.A.
	➤ Jockey pump head	N.A.	N.A.	N.A.
	➤ Standby pump out put	N.A.	N.A.	N.A.
	➤ Standby pump Head	N.A.	N.A.	N.A.
	➤ Auto Starting /Manual stopping	N.A.	N.A.	N.A.
	➤ Pump House Access	N.A.	N.A.	N.A.
	• Terrace Level	N.A.	N.A.	N.A.
	➤ Discharge of pump	Required	Provided	MR
	➤ Head of the Pump	900+180LPM	900+180LPM	MR
	➤ Power supply	35m(each)	35m(each)	MR
	➤ Auto Starting of pump	Required	Provided	MR
		Required	Provided	MR
14	Captive Water Storage for Fire Fighting.			
	On ground tank capacity	N.A.	N.A.	N.A.
	Draw-off connection	N.A.	N.A.	N.A.
	Fire service inlet	Required	Provided	MR
	Access to tank	N.A.	N.A.	N.A.
	Overhead Tank capacity	5000Liters.	5000Liters	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.			
	Pressurization of Lift Shaft	N.A.	N.A.	N.A.
	Pressurization of Lift lobby	N.A.	N.A.	N.A.
	Communication in lift car	N.A.	N.A.	N.A.
	Firemen's grounding switch	Required	Provided	MR
	Lift Signage	Required	Provided	MR
17	Standby power supply	Required	Provided 10Kva Generator set	MR
18	Refuge Area.			
	Total area	N.A.	N.A.	N.A.
	Location	N.A.	N.A.	N.A.
19	Fire Control Room			
	Detector system panel	N.A.	N.A.	N.A.
	Flow switch panel	N.A.	N.A.	N.A.
	PA system panel	N.A.	N.A.	N.A.
	Batter backup	N.A.	N.A.	N.A.
	Building Floor Plans	N.A.	N.A.	N.A.

The fire protection systems provided in the building were test checked randomly and found functional at the time of inspection. In view of the deemed compliance of the minimum standards on fire prevention and fire safety required under the rules, the FSC issued vide letter No.F.6/DFS/MS/Club/2012/141, dated 09.01.2013 renewal under rule 35 of the Delhi Fire Service Rule 2010 is recommended.


Accordingly DFA is put up for your approval and signature please.

 20/6/16

Signature of the Inspecting Officer

Name : Vedpal

Designation: Assistant Divisional Officer

~~D.O. S.D.~~  11/7/16

~~26/CFD S2~~
~~8/7/16~~

~~Dy. CFO (S2)~~

~~~~
~~4/7~~

~~DCFO/S/2~~
~~4/7/16~~

~~2050/ADOSJ~~
~~30/6/16~~

~~CFD S2/1~~

~~M-scell~~

~~FT 101~~

~~4/7~~