

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001

No F 6 / DFS / MS / 2016 / *school/w2/1119*

Dated: *8/7/16*

**FIRE SAFETY CERTIFICATE**

Certified that the Maharaja Agarsen Public School located at plot no. 120/15, Shiv Mandir, Bakhtawarpur, Delhi-110036 is comprised of ground floor only owned/ occupied by the Maharaja Agarsen Public School was issued Fire Safety Certificate vide letter no. F6/DFS/school/2013/315 dated 15.05.2013 have deemed complied with the fire prevention and safety requirements in accordance with requirements of circular issued by Director of Education letter no 3298-3398 dated 01.03.2011 and verified by the officer concerned of Fire Service on 24.06.2016 in the presence of Sh. Shashi Nath Mishra, Principal and that the building/premises is fit for occupancy Group B Educational with effect from *8/7/16*..... for a period of three years, subject to compliance of the conditions mentioned below:

**Conditions for the validity of Fire Safety Certificate:**

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [www.dfs.Delhigovt.nic.in](http://www.dfs.Delhigovt.nic.in)

Issued on *8/7/16*..... at New Delhi

*Atul G*  
(Atul G)  
Chief Fire Officer  
Ph:-011-23414250

Copy to :-

1. The Director, Education, Government of N.C.T of Delhi. Old Sectt. Delhi - 110054.
2. The Maharaja Agarsen Public School, 120/15, Shiv Mandir, Bakhtawarpur, Delhi-110036

INSPECTION REPORT

1. Name & address of the building : Maharaja Agarsen Public School, 120/15, Shiv Mandir, Bakhtawarpur  
Delhi-36
2. Type of Occupancy : Educational
3. Type of Case : Old case (Ground Floor Single Block)
4. Details of previous NOC : F.6/DFS/MS/School/2013/315 Dated: 15/05/2013
5. Fire Safety directives letter No : Director of Education Circular dated 01.03.2011
6. Date of inspection : 24/06/2016
7. Name of the Inspecting Officers : ADO (RN)
8. Name and designation of officers  
from the building side : Sh. Shashi Nath (Principal)
9. Year of Construction : 2005
10. Applicant's letter No. : MAPS/661/2016 dated 04/06/2016

Plot Area-569 m2

Covered Area:494 m2

class rooms -12nos

Student -- 200nos

	Minimum Standards on fire prevention and fire safety U/R 33	Circular of Director of Education	Provided at site	Remarks MR/NMR
1	<b>Access to building</b>			
	• Road width	6m	6m	MR
	• Gate width	2.91m	2.91m(old case)	MR
	• Width of internal road	NA	NA	NA
2	<b>Number, Width, Type &amp; Arrangement of Exits</b>			
	a. Number of staircases			
	• Upper Floors	NA	NA	NA
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper Floors	NA	NA	NA
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No. of continuous staircases to terrace	NA	NA	NA
	e. Width of Corridor	NA	NA	NA
	f. Door Size	1 m	1.22 m	MR

AC

M/7

3	<b>Compartmentation.</b>			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4	<b>Smoke Management System.</b>			
	• Basements	30 a/c per hour	NA	NA
	• Upper floors	12 a/c per hour	NA	MR
5	<b>Fire Extinguishers</b>			
	• Total numbers	04nos	04nos	MR
	• Types	ABC/CO2	ABC—4	MR
	• ISI marking	ISI Marked	Yes	MR
6	<b>First-Aid Hose Reels.</b>			
	• Total numbers on each floor	NA	NA	NA
	• Length of hose reel hose	NA	NA	NA
	• Nozzle diameter	NA	NA	NA
7	<b>Automatic fire detection and alarming system.</b>			
	• Type of detectors	NA	NA	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
	• Hooters' Location	NA	NA	NA
8	MOEFA	NA	NA	NA
9	Public Address System.	NA	NA	NA
10	<b>Automatic Sprinkler System.</b>			
	• Basement	NA	NA	NA
	• Upper Floor	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11	<b>Internal Hydrants</b>			

12





1/9

	<ul style="list-style-type: none"> <li>• Communication In lift Car</li> <li>• Fireman's Grounding Switch</li> <li>• Lift Signage</li> </ul>	N/A	N/A	N/A
17	Standby power supply	N/A	N/A	N/A
18	<b>Refuge Area.</b>			
	➤ Total Area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19	<b>Fire Control Room</b>			
	• Detector System Panel	N/A	N/A	N/A
	• Flow Switch Panel	N/A	N/A	N/A
	• PA System Panel	N/A	N/A	N/A
	• Batter backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of special Risks, if any:	N/A	N/A	N/A

Accordingly, the fire protection systems provided in the building were tested/ checked randomly and found in working condition at the time of inspection.

Keeping in view the satisfactory compliance of the minimum standards on fire prevention and fire safety required as stipulated in Director of Education Circular the FSC issued vide letter of even no 315 dated 15.05.2013 renewal under rule 35 of the Delhi Fire Service Rules, 2010 is recommended.

  
 Signature of the Inspecting Officer

Name :- Rajesh Kumar

Designation:- ADO/RN

DD/N/A


S Singh

29.6.16

Dy CPO (WZ)

CPO. WZ

5/10/16

  
 4/7/16