

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110 001

No. F6/DFS/MS/EH/2016/SZ/1122

Dated: 8/7/16

FIRE SAFETY CERTIFICATE

Certified that M/S "Pind Balluchi" Restaurant located at No.17, Community Centre, Saket, New Delhi-110016, comprised of Basement, Ground, Mezzanine plus two upper floors where mezzanine floor is used as office & 1<sup>st</sup> floor for restaurant, was granted Fire Safety Certificate by this department vide letter No. F6/DFS/MS/2013/EH/SZ/486, dated 26-06-13. The premises was re-inspected by the officer concerned of this department on 23-06-2016 in the presence of Sh. Praveen Pokhriyal and found that the said eating house at mezzanine as office & 1<sup>st</sup> floors as restaurant have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class Group-D Assembly Building(Eating House) with effect from 8/7/.....2016 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on...8/7/..... 2016at New Delhi by.

(Vipin Kental)

Chief Fire Officer

T.No.011-23413990

To:- M/S "Pind Balluchi" Restaurant located at Mezzanine & 1st Floors, No.17, Community Centre, Saket, New Delhi-110016.

Conditions for the validity of fire safety certificate are under:-

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities.
5. This Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
7. The owner/occupier shall apply for renewal of this Fire Safety Certificate in form J, six month prior to its expiry.



## INSPECTION REPORT

1	Name & address of the building	M/S "Pind Balluchi" Restaurant located at Mezzanine & 1st Floors, No.17, Community Centre, Saket, New Delhi-110016.		
2	Building comprised of	Basement, Ground, Mezzanine plus two upper floors. Restaurant is at mezzanine & 1st floors only. Mezzanine floor is used as office & 1st floor as restaurant. All others floors are under control of other's ownership.		
3	Type of Occupancy	Assembly building "D" Restaurant		
4	Type of case	Renewal		
5	Details of previous NOC	F6/DFS/MS/2013/EH/SZ/486, dt 26.06.2013.		
6	Fire safety directives letter No	As per circulat dated 04.04.2005.		
7	Date of inspection	23.06.2016.		
8	Name of the inspecting Officers	ADO Vedpal		
9	Name and designation of officers from the building side	Mr. Praveen Pokhiyal.		
10	Year of construction	N/A		
11	Applicant's letter No.	Nil, Dated Nil.		

S. NO.	Minimum Standards on fire prevention and fire safety U/R 33	Requirement as per BBL/Circular 2005	Provided at site	Remarks
	<b>1 Access to building</b>			MR / NMR

1) Road width	9m	9m	MR
2) Gate width	N/A	N/A	N/A
3) Width of internal road	N/A	N/A	N/A

S. NO.	Minimum Standards on fire prevention and fire safety U/R 33	Requirement as per BBL/Circular 2005	Provided at site	Remarks
	<b>2 Number, width Type &amp; arrangement of exits</b>			
	<b>a. Number of staircases</b>			
	1. Upper floors	2 Nos	01 No.	MR(old case)
	2. basements	N/A	N/A	N/A
	<b>b. Width of staircase</b>			
	1. Upper floors	1.5 Mtr <i>1.25 m</i>	1.10m upto terrace & 1.12m(between mezn & 1st floor)	MR (Old Case)
	2. basements	N/A	N/A	N/A
	<b>c. Protection of exits</b>			
	1. Fire check door	N/A	N/A	N/A
	2. Pressurization	N/A	N/A	N/A
	<b>d. No. of continuous staircase to terrace</b>	01no.	01no.	MR
	e. Width of corridor	N/A	N/A	
	f. Door size	02nos.exits required	2nos exits of 1m each Provided	MR MR(old case)

S. NO.	Minimum Standards on fire prevention and fire safety U/R 33	Requirement as per BBL/Circular 2005	Provided at site	Remarks
	<b>3 Compartmentation.</b>			
	1. Fire check door	N/A	N/A	N/A
	2. Sealing of electrical shafts	N/A	N/A	N/A
	3. Fire Rating of shaft door	N/A	N/A	N/A
	4. water curtain	N/A	N/A	N/A
	5. Fire dampers	N/A	N/A	N/A

S. NO.	Minimum Standards on fire prevention and fire safety U/R 33	Requirement as per BBL/Circular 2005	Provided at site	Remarks
	<b>4 Smoke Management system.</b>			
	basement	30 a/c per hour	N/A	N/A
	upper floors	12 a/c per hour	Exhust Fans Provided	MR

S. NO.	Minimum Standards on fire prevention and fire safety U/R 33	Requirement as per BBL/Circular 2005	Provided at site	Remarks
	<b>5 Fire Extinguishers</b>			
	total numbers	06Nos	10 Nos	MR
	Types	ABC & CO2	ABC, Co2, Foam	MR
	ISI marking	ISI	Yes	

S. NO.	Minimum Standards on fire prevention and fire safety U/R 33	Requirement as per BBL/Circular 2005	Provided at site	Remarks
	<b>6 First-Aid Hose Reels</b>			



7 Automatic fire detection and alarming system			
	Type of detectors	N/A	N/A
	location of Main Panel	N/A	N/A
	location of Repeater panel	N/A	N/A
	Alternate source of power	N/A	N/A
	hooter's location	N/A	N/A
8	<b>MOEFA</b>	Required	Provided
9	<b>Public Address System.</b>	Required	Provided
10	<b>Automatic Sprinkler System.</b>		
	basement	N/A	N/A
	upper floors	Required	Provided
	sprinkler above false ceiling	N/A	N/A
11	<b>Internal Hydrants</b>		
	Size of riser/down-corner	100mm	100mm
	Number of Hydrants per floor	01no.	01no.
	hose Box	01no.	01no.
12	<b>Yard Hydrants.</b>		
	total number of hydrants	N/A	N/A
	hose box	N/A	N/A
13	<b>Pumping arrangements</b>		
	<b>1. Ground level</b>		
	a. Discharge of main Pump	N/A	N/A
	b. Head of main pump	N/A	N/A
	c. Number of main pumps	N/A	N/A
	d. jockey pump out put	N/A	N/A
	e. jockey pump head	N/A	N/A
	f. Standby Pump output	N/A	N/A
	g. Stanby Pump head	N/A	N/A
	h. Auto Starting/Manual stopping	N/A	N/A
	pump house access	N/A	N/A
	<b>2. Terrace level</b>		
	a. Discharge of pump	450LPM	450 & 180 LPM
	b. head of the pump	30 mtr	30 mtr (each)
	c. Power supply	Required	Provided
	d. Auto starting of pump	Required	Provided
14	<b>Captive water storage for fire fighting</b>		
	1. Underground tank capacity	N/A	N/A
	a. Draw-off connection	N/A	N/A
	b. fire service inlet	N/A	N/A
	c. Access to tank	N/A	N/A
	Over head tank Capacity	5,000 ltr	5000Liters
15	<b>Exit Signage.</b>	Required	Provided
16	<b>Provision of lifts.</b>		
	a. Pressurization of lift shaft	N/A	N/A
	b. pressurization of lift lobby	N/A	N/A
	c. communication in lift car	N/A	N/A
	d. Fireman's grounding switch	N/A	N/A
	e. Lift signage	N/A	N/A
17	<b>Standby power supply</b>	Required	Provided
18	<b>Refuge Area.</b>	Not Required	
	total area		
	location		


*MS*

19	<b>Fire control room</b>			
	a. detector system Panel	N/A	N/A	N/A
	b. Flow switch Panel	N/A	N/A	N/A
	c. PA system Panel	N/A	N/A	N/A
	d. Batter backup	N/A	N/A	N/A
	e. Building floor plans	N/A	N/A	N/A

20 **Special Fire Protection systems for protection of special risks, if any:**

The fire protection systems provided in the building were test checked randomly and found functional at the time of inspection. In view of the deemed compliance of the minimum standards on fire prevention and fire safety required under the rules the SFC issued vide letter No.F.6/DFS/MS/2013/EH/SZ/486, dated 26.06.2013, renewal under rule 37 of the Delhi Fire Service Rule 2010 is recommended.

Accordingly DFA is put up for your approval and signature please.




24/6

**Signature of the inspecting officer**

**Name Vedpal**

**Designation : Assistant Divisional Officer**

~~D.O. (S.D)~~



24/6/16