

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110 001

No. F6/DFS/MS/School/2016/52/1126

Dated: 08/07/16

FIRE SAFETY CERTIFICATE

Certified that M/S Wonderland Play School, located in between Tower No. 4 & 5, New Moti Bagh, GPRA Complex, New Delhi-110021, comprised of ground plus one upper floor, owned/occupied by Wonderland Play School was granted Fire Safety Certificate by this department vide letter No. F6/DFS/MS/School/2013/430, dated 11-06-2013. The premises was re-inspected by the officer concerned of this department on 17-06-2016 in the presence of Mr. Shailesh Jha, Manager Admn. of the school and found that the said school building have deemed complied with the fire prevention and fire safety requirements in accordance with the circular issued by the Director of Education dated 01.03.2011 and that the premises is fit for occupancy class "B" educational building with effect from ..08/07/...2016 for period of three years.

Issued 08/07/... 2016 at New Delhi by.

(Vipin Kental)

Chief Fire Officer

T.No.011-23413990

To:- Sh. Shailesh Jha, Manager M/s Wonderland Play School, located in between Tower No. 4 & 5, New Moti Bagh, GPRA Complex, New Delhi-110021. ^{ok}

Conditions for the validity of fire safety certificate are as under:-

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. The employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All fire fighting equipments shall be maintained in perfect working condition all time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities.
5. This Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in.
7. The owner/occupier shall apply for renewal of this Fire Safety Certificate in form J, six month prior to its expiry.

INSPECTION REPORT

1	Name & address of the building	M/S Wonderland Play School, located in between Tower No. 4 & 5, New Moti Bagh, GPRA Complex, New Delhi-110021.
2	Type of Occupancy	Educational Building "B"
3	Type of case	Renewal
4	Details of previous NOC	No.F6/DFS/MS/School/2013/430, Dated 11.06.2013.
5	Fire safety directives letter No	F.16/Estate/CC/Fire safety/2011/3298 to 3398, Dated- 01.03.11.
6	Date of inspection	17.06.2016.
7	Name of the inspecting Officers :	A.D.O. Vedpal.
8	Name and designation of officers from the building side	Sh. Shailesh Jha, Manager Admn.
9	Building Comprised of	Ground plus one upper floor only.
10	Year of construction	2012
11	Applicant's letter No.	Nil, Dated 30.05.2016.

S. NO.	Minimum Standards on fire prevention and fire safety U/R 33	Requirement as per Director Education Circular	Provided at site	Remarks MR / NMR
--------	---	--	------------------	------------------

1	Access to building			
	1) Road width	6m	6m	MR
	2) Gate width	N/A	N/A	N/A
	3) Width of internal road	N/A		N/A

2	Number, width Type & arrangement of exits			
	a. Number of staircases			
	1. Upper floors	01No.	01No.	MR
	2. basements	N/A	N/A	N/A
	b. Width of staircase			
	1. Upper floors	1.5m	1.90m	MR
	2. basements	N/A	N/A	N/A
	c. Protection of exits			
	1. Fire check door	N/A	N/A	N/A
	2. Pressurization	N/A	N/A	N/A
	d. No. of continuous staircase to terrace	01No.	01No.	MR
	e. Width of corridor	N/A	N/A	N/A
	f. Door size	1m	1m	MR

3	Compartmentation.			
	1. Fire check door	N/A	N/A	N/A
	2. Sealing of electrical shafts	N/A	N/A	N/A
	3. Fire Rating of shaft door	N/A	N/A	N/A
	4. water curtain	N/A	N/A	N/A
	5. Fire dampers	N/A	N/A	N/A

4	Smoke Management system.			
	basement	30 a/c per hour	N/A	N/A
	Upper Floors	12 a/c per hour	N/A	N/A

5	Fire Extinguishers			
	total numbers	06nos.	10nos.	MR
	Types		ABC & Water CO2	MR
	ISI marking		ISI Mark	MR

6	First-Aid Hose Reels.			
	total numbers on each floor	N/A	01No.	N/A
	Length of Hose reel hose	N/A	30m	N/A
	Nozzle Diameter	N/A	5mm	N/A

7	Automatic fire detection and alarming system			
	Type of detectors	N/A	Smoke & Heat	N/A
	location of Main Panel	N/A	Ground Floor	N/A
	location of Repeater panel	N/A	N/A	N/A
	Alternate source of power	N/A	N/A	N/A

	IOEFA	N/A	Provided	N/A
	Public Address System.	N/A	N/A	N/A
	Automatic Sprinkler System.			
	basement	N/A	N/A	N/A
	upper floors	N/A	N/A	N/A
	sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants			
	Size of riser/down-corner	N/A	150mm	N/A
	Number of Hydrants per floor	N/A	01No.	N/A
	hose Box	N/A	01No.	N/A
12	Yard Hydrants.			
	total number of hydrants	N/A	N/A	N/A
	hose box	N/A	N/A	N/A
13	Pumping arrangements			
	1. Ground level	N/A	N/A	N/A
	a. Discharge of main Pump	N/A	N/A	N/A
	b. Head of main pump	N/A	N/A	N/A
	c. Number of main pumps	N/A	N/A	N/A
	d. jockey pump out put	N/A	N/A	N/A
	e. jockey pump head	N/A	N/A	N/A
	f. Standby Pump output	N/A	N/A	N/A
	g. Stanby Pump head	N/A	N/A	N/A
	h. Auto Starting/Manual stopping	N/A	N/A	N/A
	pump house access	N/A	N/A	N/A
	2. Terrace level			
	a. Discharge of pump	N/A	450LPM+180LPM	N/A
	b. head of the pump	N/A	40m (each)	N/A
	c. Power supply	N/A	Provided	N/A
	d. Auto starting of pump	N/A	N/A	N/A
14	Captive water storage for fire fighting			
	1. Underground tank capacity	N/A	N/A	N/A
	a. Draw-off connection	N/A	N/A	N/A
	b. fire service inlet	N/A	N/A	N/A
	c. Access to tank	N/A	N/A	N/A
	Over head tank Capacity	N/A	10000Ltrs.	N/A
15	Exit Signage.	Required	Provided	MR
16	Provision of lifts.			
	a. Pressurization of lift shaft	N/A	N/A	N/A
	b. pressurization of lift lobby	N/A	N/A	N/A
	c. communication in lift car	N/A	N/A	N/A
	d. Fireman's grounding switch	N/A	N/A	N/A
	e. Lift signage	N/A	N/A	N/A
17	Standby power supply	N/A	N/A	N/A
18	Refuge Area.	Not Required		
	total area	N/A	N/A	N/A
	location	N/A	N/A	N/A
19	Fire control room			
	a. detector system Panel	N/A	N/A	N/A
	b. Flow switch Panel	N/A	N/A	N/A
	c. PA system Panel	N/A	N/A	N/A
	d. Batter backup	N/A	N/A	N/A
	e. Building floor plans	N/A	N/A	N/A


N-7

20

Special Fire Protection systems for protection of special risks, if any: N/A

The fire protection systems provided in the building were test checked at random and found functional at the time of inspection. In view of the deemed compliance of the minimum standards on fire prevention and fire safety required under circular of Director of Education, the FSC issued vide letter No: F6/DFS/MS/School/2013/430, dated 11.06.2013, renewal under rule 37 of the Delhi Fire Service Rule 2010 is recommended.

Accordingly DFA is put up for your approval and signature please.



19/6/16

Signature of the inspecting officer

Name: Vedpal

Designation : ADO

~~D.O. (S.D)~~

~~Anilans~~
22/6/16