

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI- 110001

NO. F6/DFS/MS/SCHOOL/2016/SZ/ 1185

Dated: 21/07/16

FIRE SAFETY CERTIFICATE

Certified that the New Indira Devi Public School, C1/175 Solanki Market, Madhu Vihar, New Delhi-110059, comprised of ground floor only (having seven rooms) owned/ occupied by New Indira Devi Public School was issued NOC by this department vide letter no. F6/MS/DFS/2007/647 dated 05.03.2007. The school building was re-inspected by the officer concerned of this department on 06.07.2016 in presence of Sh. Satpal Solanki (Manager) and found that the premises have deemed complied with the fire prevention and fire safety requirements in accordance with Directorate of Education GNCT of Delhi Letter No: Estate/CC/FireSafety/2011/3298 Dtd. 01.03.2011 and that the building is fit for occupancy class B "Educational building" with effect from21/07/16...for a period of **three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules 2010, printed overleaf.

Issued on21/07/16..... at New Delhi by

OK
VK
20/7
(Vipin Kental)
Chief Fire Officer
SM

Copy to:-

1. The Dy. Director, (Education), SDMC, 23rd floor, Civic Centre, Minto Road, N.Delhi.
2. Manager, Indira Devi Public School, C1/175, Solanki Market, Madhu Vihar, New Delhi-110059.

CONDITIONS

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupation, electric installation etc. may be got verified from the concerned authorities.
5. The Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction / unauthorized use of land if any.
6. All comments / directions of licensing Department shall always be permitted and followed.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in
8. The owner / occupier shall apply for renewal of this **Fire Safety Certificate to the Director in 'Form J' (sub Rule (1) of Rule 37)** along with copy of the certificate, six months prior to its expiry.

INSPECTION REPORT

1	Name & address of the building	New Indira Devi Publiuc School, C-1/175, Solanki Market, Madhu Vihar, New Delhi-110059.		
2	Type of Occupancy	Educational Building "B"		
3	Type of case	Renewal		
4	Details of previous NOC	F6/MS/DFS/2007/647 dated 05.03.2007		
5	Fire safety directives letter No	Directorate Of Education Circular. No. 262-362 Dated 17.01.2005.		
6	Date of inspection	06.7.2016		
7	Name of the inspecting Officers :	ADO S.P. Bhardwaj		
8	Name and designation of officers from the building side	Sh. Satpal Solanki (Manager)		
9	Year of construction	before 2007		
10	Applicant's letter No.	Nil Dated 16.06.2016	Ground Floor only having seven rooms	

S. NO.	Minimum Standards on fire prevention and fire safety U/R 33	D O E Circular dated 01.03.2011.	Provided at site	Remarks MR / NMR
--------	---	----------------------------------	------------------	------------------

1	Access to building			
	1) Road width	6 Mtrs.	6 Mtrs.	MR
	2) Gate width	4.5 Mtrs.	Directly Accessible from road	MR
	3) Width of internal road	N/A	N/A	N/A

2	Number, width Type & arrangement of exits			
	a. Number of staircases			
	1. Upper floors	N/A (GF Only)	N/A (GF Only)	N/A
	2. basements	N/A	N/A	N/A
	b. Width of staircase			
	1. Upper floors	N/A	N/A	N/A
	2. basements	N/A	N/A	N/A
	c. Protection of exits			
	1. Fire check door	N/A	N/A	N/A
	2. Pressurization	N/A	N/A	N/A
	d. No. of continuous staircase to terrace	N/A	N/A	N/A
	e. Width of corridor	1.25 Mtrs.	150 mm	MR
	f. Door size	1 Mtr.	1 Mtr.	MR

3	Compartmentation.			
	1. Fire check door	N/A	N/A	N/A
	2. Sealing of electrical shafts	N/A	N/A	N/A
	3. Fire Rating of shaft door	N/A	N/A	N/A
	4. water curtain	N/A	N/A	N/A
	5. Fire dampers	N/A	N/A	N/A

4	Smoke Management system.			
	basement		N/A	N/A
	upper floors	N/A	N/A	N/A

5	Fire Extinguishers			
	total numbers	2 Nos. Co2 OR ABC ISI Marked	4 Nos.	MR
	Types		ABC	MR
	ISI marking		ISI Marked	MR

6	First-Aid Hose Reels.			
	total numbers on each floor	N/A	N/A	N/A
	Length of Hose reel hose	N/A	N/A	N/A
	Nozzle Diameter	N/A	N/A	N/A
7	Automatic fire detection and alarming system			
	Type of detectors	N/A	N/A	N/A
	location of Main Panel	N/A	N/A	N/A
	location of Repeater panel	N/A	N/A	N/A
	Alternate source of power	N/A	N/A	N/A
	hooter's location	N/A	N/A	N/A
8	MOEFA	N/A	N/A	N/A
9	Public Address System.	N/A	N/A	N/A
10	Automatic Sprinkler System.			
	basement	N/A	N/A	N/A
	upper floors	N/A	N/A	N/A
	sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants			
	Size of riser/down-corner	N/A	N/A	N/A
	Number of Hydrants per floor	N/A	N/A	N/A
	hose Box	N/A	N/A	N/A
12	Yard Hydrants.			
	total number of hydrants	N/A	N/A	N/A
	hose box	N/A	N/A	N/A
13	Pumping arrangements			
	1. Ground level			
	a. Discharge of main Pump	N/A	N/A	N/A
	b. Head of main pump	N/A	N/A	N/A
	c. Number of main pumps	N/A	N/A	N/A
	d. jockey pump out put	N/A	N/A	N/A
	e. jockey pump head	N/A	N/A	N/A
	f. Standby Pump output	N/A	N/A	N/A
	g. Stanby Pump head	N/A	N/A	N/A
	h. Auto Starting/Manual stopping	N/A	N/A	N/A
	pump house access	N/A	N/A	N/A
	2. Terrace level			
	a. Discharge of pump	N/A	N/A	N/A
	b. head of the pump	N/A	N/A	N/A
	c. Power supply	N/A	N/A	N/A
	d. Auto starting of pump	N/A	N/A	N/A
14	Captive water storage for fire fighting			
	1. Underground tank capacity	N/A	N/A	N/A
	a. Draw-off connection	N/A	N/A	N/A
	b. fire service inlet	N/A	N/A	N/A
	c. Access to tank	N/A	N/A	N/A
	Over head tank Capacity	N/A	N/A	N/A
15	Exit Signage.	N/A	N/A	N/A
16	Provision of lifts.			
	a. Pressurization of lift shaft	N/A	N/A	N/A
	b. pressurization of lift lobby	N/A	N/A	N/A
	c. communication in lift car	N/A	N/A	N/A
	d. Fireman's grounding switch	N/A	N/A	N/A
	e. Lift signage	N/A	N/A	N/A


N14

	Standby power supply	N/A	N/A	N/A
	Refuge Area.	Not Required		
	total area			
	location			
19	Fire control room			
	a. detector system Panel	N/A	N/A	N/A
	b. Flow switch Panel	N/A	N/A	N/A
	c. PA system Panel	N/A	N/A	N/A
	d. Batter backup	N/A	N/A	N/A
	e. Building floor plans	N/A	N/A	N/A
20	Special Fire Protection systems for protection of special risks, if any:	ABC		

The fire protection systems provided in the building were checked and found functional at the time of inspection.

Keeping in view the deemed compliance of the minimum standards on fire prevention and fire safety required under the rules, the NOC issued vide letter F6/MS/DFS/2007/647 dated 05.03.2007, renewal of Fire Safety Certificate under Directorate of Education Circular No. 262-362 dated 17.01.2005 is recommended.

Accordingly DFA is put up for approval and signature please.


Signature of the Inspecting Officer
Name S.P. Bhardwaj
Designatic ADO (Dwarka)

Dojsw

11/7/16

DCFO(Sr)