

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI-110001

No. F6/DFS/MS/ *School/2016/52/1164*
FIRE SAFETY CERTIFICATE

Dated: *19/07/16*

Certified that the Nigam Pratibha Vidyalaya located at Masoodpur, Vasant Kunj, New Delhi-110070, comprised of Ground + 1 Upper Floor (2 Blocks) owned/occupied by MCD has already been issued FSC by this department vide letter No. F6/DFS/MS/School/2013/381 dated 27/05/13. The school was re-inspected by the officer concerned of this department on 14/07/16 in the presence of Mrs. Saroj Bala (Principal) & found to have deemed complied with the fire prevention and fire safety requirements in accordance with Circular no. F.16/Estate/CC/Fire/Safety/2011/3298 to 3398 dated 01/03/11 issued by Directorate of Education, Govt. of NCT of Delhi and that the building premises is fit for occupancy class Group 'B' Educational Building with effect from...*19/07/16* for a period of Three years subjected to condition as mentioned below.

Issued on *19/07/16*..... at New Delhi by

Vipin Kental
(Vipin Kental)
Chief Fire Officer
Delhi Fire Service
Tel: 011-23412225

E-Mail: cfoz.dlfire@nic.in

Copy to :- (1) Nigam Prathiba Vidyalaya,
Masoodpur, Vasant Kunj, New Delhi-110070
(2) Director of Education,
MCD, Civic Center, Jawharlal Nehru Marg, New Delhi.

Conditions for the validity of fire safety certificate:

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of fire fighting system.
4. The owner/ occupier shall submit a declaration every year in Form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in.
5. This fire safety certificate may not in any way be treated as regularization of unauthorized construction, if any.
6. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry."

INSPECTION REPORT

1. Name & address of the building : Nigam Pratibha Vidyalaya, Masoodpur, Vasant Kunj, New Delhi-110070
2. Type of Occupancy : Educational Building, School up to 5th standard
3. Type of Case : Old case
4. Details of Previous NOC : No. F6/DFS/MS/School/2013/381 dated 27/05/2013
5. Fire Safety directives letter No : Director of education circular dated 01/03/2011
6. Date of inspection : 14/07/2016
7. Name of Inspecting Officer : A. K. Malik
8. Name and designation of officers
From the building side : Smt. Saroj Bala (Principal)
9. Year of Construction : 2004
10. Applicant's letter No. : Nil dated 24/06/16 [2 Blocks, each having Ground + 1 Upper Floor]

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	Dir. Of Edu. Circular dt. 01.03.2011	Provided at site	Remarks MR/NMR
1.	Access to building			
	<ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 	Accessible -NA- -NA-	9m -NA- -NA-	MR -NA- -NA-
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	<ul style="list-style-type: none"> • Upper Floors • Basements 	2(each block) -NA-	2(each block) -NA-	MR -NA-
	b. Width of staircases			
	<ul style="list-style-type: none"> • Upper Floor • Basements 	1.50m OR less than 1.50m + 0.75m -NA-	1 st block 1.60m and 1.40m, 2 nd block 1.30m and 0.95m -NA-	MR -NA-
	c. Protection of exits			
	<ul style="list-style-type: none"> • Fire check door • Pressurization 	-NA- -NA-	-NA- -NA-	-NA- -NA-
	d. No. of continuous staircases to terrace	-NA-	-NA-	-NA-
	e. Width of Corridor	-NA-	-NA-	-NA-
	f. Door Size	1m	1m	MR
3.	Compartmentation			
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 	-NA- -NA- -NA- -NA- -NA-	-NA- -NA- -NA- -NA- -NA-	-NA- -NA- -NA- -NA- -NA-
4.	Smoke Management System			
	<ul style="list-style-type: none"> • Basements • Upper floors 	-NA- -NA-	-NA- -NA-	-NA- -NA-
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total numbers • Types • IS marking 	ISI Marked	9 No's ABC Yes	MR MR MR
6.	First-Aid Hose Reels			
	<ul style="list-style-type: none"> • Total numbers on each floor • Length of hose reel hose • Nozzle diameter 	-NA- -NA- -NA-	-NA- -NA- -NA-	-NA- -NA- -NA-
7.	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> • Type of detectors • Location of Main Panel • Location of Repeater Panel 	-NA- -NA- -NA-	-NA- -NA- -NA-	-NA- -NA- -NA-

8.	MOEFA	-NA-	-NA-	-NA-
9.	Public Address System	-NA-	-NA-	-NA-
10.	Automatic Sprinkler System	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> Basement 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> Ground Floor 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> Sprinkler above false ceiling 	-NA-	-NA-	-NA-
11.	Internal Hydrants	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> Size of riser/down-comer 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> Number of hydrants per floor 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> Hose Box 	-NA-	-NA-	-NA-
12.	Yard Hydrants	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> Total number of hydrants 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> Hose Box 	-NA-	-NA-	-NA-
13.	Pumping Arrangements	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> Discharge of main Pump Head of Main pump Number of main pumps Jockey Pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Starting/Manual Stopping 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> Terrace level <ul style="list-style-type: none"> Discharge of pump Head of the pump Power Supply Auto Starting of pump 	-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
14.	Captive Water Storage for fire fighting	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> Underground tank capacity <ul style="list-style-type: none"> Draw-off connection Fire service inlet Access to tank Overhead Tank capacity 	-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
15.	Exit Signage.	-NA-	-NA-	-NA-
16.	Provision of Lifts.	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> Pressurization of Lift Shaft 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> Pressurization of Lift lobby 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> Communication In lift Car 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> Fireman's Grounding Switch 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> Lift Signage 	-NA-	-NA-	-NA-
17.	Standby power supply	-NA-	-NA-	-NA-
18.	Refuge Area.	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> Total Area Location 	-NA-	-NA-	-NA-

19.	Fire Control Room			
	<ul style="list-style-type: none"> • Detector System Panel • Flow Switch Panel • PA System Panel • Battery backup • Building Floor Plans 	-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
20.	Special Fire Protection System for Protection of special Risks, if any:	-NA-	-NA-	-NA-

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

Keeping in view of the above substantial compliance of the minimum standards of fire prevention and fire safety measures as required under the rules it is recommended to grant Fire Safety Certificate under Director of Education Circular dated 1/3/11.

Accordingly DFA is put up.

A. K. Malik
15/7/16

Signature of Inspecting Officer
Name: A. K. Malik
Designation: Divisional Officer

DY. CFO(SZ)

[Signature]
15/7

DofS) 15
15-7-16

CFO (SZ)

Pl put up revised DFA

DofS) SZ

[Signature]
16/7

DofS) 198
15/7/16

[Signature]