

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001

No F 6 / DFS / MS / 2016 / 1150

Dated 15/07/16

FIRE SAFETY CERTIFICATE

Certified that the M/s Pik Wik Restaurant, located at fourth floor 409, V3S Ring Road Mall, Plot no. 21, Sec.-3, Rohini, Manglam Place, Delhi-85 in the building comprised of three basement, ground and eight upper floors owned/ occupied by Sh. Joginder Singh was granted Fire Safety Certificate by this department vide letter no. F6/DFS/MS/EH/2012/4225 dated 12.11.2012. The premises was re-inspected by the officers concerned of this department on 01.07.2016 in the presence of **Sh. Joginder Singh Pal**, Proprietor of the Restaurant and found the building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010. Hence the NOC is renewed and premises is fit for **Class -D(Assembly)** occupancy with effect from 15/07/16 for a period of **03 (Three) years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in
8. All the means of escape shall be kept free of any obstruction all the time to evacuate the occupant, in a safe manner, in the event of emergency.

Issued on ... 15/07/16 at New Delhi by


(Atul Garg)
Chief Fire Officer
Ph-011-23414250


Copy to:-

1. The Dy. Health Officer, North MCD,
Civil Line Zone, Sec-5, Rohini, Delhi-110054.
2. Mr. Joginder Pal Singh, M/s Pik Wik Restaurant, fourth floor 409, V3S Ring Road Mall, Plot no.21, Sec.-3, Rohini, Manglam Place, Delhi-85.

INSPECTION REPORT

1. Name & address of the building : Pik Wik Restaurant, fouth floor 409, V3S Ring Road Mall, Plot no. 21
Sec.-3, Rohini, Manglam Place, Delhi-85. (Basement+ Ground + 08 Floor)
2. Type of Occupancy : Mixed Occupancy (Assembly/ Business)
3. Type of Case : Renewal
4. Details of previous NOC : F6/DFS/MS/EH/2012/4225 dated 12.11.2012
5. Fire Safety directives letter No : NBC Part IV
6. Date of inspection : 12/06/2015
7. Name of the Inspecting Officers : ADO (RN)
8. Name and designation of officers
from the building side : Mr Joginder Pal Singh (Proprietor)
9. Year of Construction : --
10. Applicant's letter No. : Nil dated 31.05.2016

	Minimum Standards on fire prevention and fire safety U/R 33	NBC/ BBL Requirement	Provided at site	Remarks MR/NMR
1	Access to building			
	<ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 	09m	10m	MR
		4.5m	4.5m	MR
		6m	6m	MR
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases	04	04	MR
		04 for the Mall	04	MR
	b. Width of staircases	As per sanction plan	Provided	MR
		As per sanction Plan	Provided	MR
	c. Protection of exits	Required	Provided	MR
		For the Mall	For the Mall	MR
	d. No. of continuous staircases to terrace	01	01	MR
	e. Width of Corridor			

M

11/11

	f. Door Size	1.25m	1.25m	MR
3	Compartmentation. For the restaurant			
	• Fire check door	Required	NA	NA
	• Sealing of electrical shafts	Required	Provided	MR
	• Fire Rating of shaft door	Required	NA	NA
	• Water Curtain	Required	NA	NA
	• Fire Dampers	Required	NA	NA
4	Smoke Management System.			
	• Basements	30 a/c per hour	Exhaust fan	MR
	• Upper floors	12 a/c per hour	Natural Ventilated	MR
5	Fire Extinguishers For the restaurant			
	• Total numbers	08nos	10nos	MR
	• Types	ABC/Co2	ABC/Co2	MR
	• ISI marking	Yes	Yes	MR
6	First-Aid Hose Reels.			
	• Total numbers on each floor	02	02	MR
	• Length of hose reel hose	30 m	30m	MR
	• Nozzle diameter	5mm	5mm	MR
7	Automatic fire detection and alarming system.			
	• Type of detectors	Required	Provided	MR
	• Location of Main Panel	Required	Provided	MR
	• Location of Repeater Panel	Required	Provided	MR
	• Alternate source of power	Required	Provided	MR
	• Hooters' Location	Required	Provided	MR
8	MOEFA	Required	Provided	MR
9	Public Address System.	NA	NA	NA
10	Automatic Sprinkler System.			
	• Basement	NA	NA	NA
	• Upper Floor	Required	Provided	MR
	• Sprinkler above false ceiling	Required	Provided	MR

11/11

2/12

11	Internal Hydrants for the Mall			
	• Size of riser/down-comer	150mm	150mm	MR
	• Number of hydrants per floor	02	02	MR
	• Hose Box	02	02	MR
12	Yard Hydrants. For the Mall			
	• Total number of hydrants	Required	Provided	MR
	• Hose Box	Required	Provided	MR
13	Pumping Arrangements. Common with the Mall			
	• Ground Level			
	➤ Discharge of main Pump	2280 lpm	2280 lpm	MR
	➤ Head of Main pump	80m	80m	MR
	➤ Number of main pumps	02	02	MR
	➤ Jockey Pump out put	180 lpm	180 lpm	MR
	➤ Jockey pump head	80m	80m	MR
	➤ Standby Pump out put	2280 lpm	2280 lpm	MR
	➤ Standby Pump Head	80m	80m	MR
	➤ Auto Starting/ Manual stopping	Required	Provided	MR
	➤ Pump House Access	NA	NA	NA
	• Terrace level	NA	NA	NA
	➤ Discharge of pump	NA	NA	NA
	➤ Head of the pump	NA	NA	NA
	➤ Power Supply	NA	NA	NA
	➤ Auto Starting of pump	NA	NA	NA
14	Captive Water Storage for fire fighting. For the Mall			
	• Underground tank capacity	1 lac	Provided	MR
	➤ Draw-off connection	Required	Provided	MR
	➤ Fire service inlet	Required	Provided	MR
	➤ Access to tank	Required	Provided	MR
	• Overhead Tank capacity	50,000 ltr	50,000 ltrs	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.			
	• Pressurization of Lift Shaft	Required	Provided	MR

M

4/13

	<ul style="list-style-type: none"> Pressurization of Lift lobby Communication In lift Car Fireman's Grounding Switch Lift Signage 	Required	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
17	Standby power supply	Required	Provided	MR
18	Refuge Area.			
	➤ Total Area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19	Fire Control Room			
	<ul style="list-style-type: none"> Detector System Panel Flow Switch Panel PA System Panel Batter backup Building Floor Plans 	Required	Provided	MR
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of special Risks, if any:	NA	NA	NA

The fire protection systems provided in the building were tested/ checked and found some in working order at the time of inspection.

Keeping in view of the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010.

Handwritten signature
4/13

Signature of the Inspecting Officer
Name: - Rajesh Kumar
Designation:- ADO/RN

Do/Noted

Handwritten signature
5.7.16

Handwritten signature
19/07/16

Handwritten signature
19/07/16

Handwritten signature
18/7/16
PT PLG