

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110 001

No. F6/DFS/MS/2016/SZ/511/202

Dated: 27/07/16

FIRE SAFETY CERTIFICATE

Certified that M/S Mirza International Ltd., Plot No. A-7, Mohan Co-operative Industrial Estate, Mathura Road, New Delhi-110044, comprised of basement floor (storage), ground plus one upper floor, owned/occupied by M/S Mirza International Ltd., was granted Fire Safety Certificate by this department vide letter No. F6/DFS/MS/2013/SZ/511, dated 03-07-13. The premises was re-inspected by the officer concerned of this department on 13-07-2016 in the presence of Sh. Shashank Kumar (GM Administration) and found that the said building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class G "Industrial building" with effect from 27/07/2016 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 27/07/2016 at New Delhi by.


(Atul Garg)

Chief Fire Officer

T.No.011-23414250

Copy to:- Sh. Shashank Kumar, GM Administration, M/S Mirza International Ltd., Plot No. A-7, Mohan Co-operative Industrial Estate, Mathura Road, New Delhi-110044. alc
ke

Conditions for the validity of fire safety certificate are as under:-

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities.
5. This Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in.
7. The owner/occupier shall apply for renewal of this Fire Safety Certificate on form J, six month prior to its expiry.

INSPECTION REPORT


1	Name & address of the building	M/S Mirza International Ltd., Plot No. A-7, Mohan Co-operative Industrial Estate, Mathura Road, New Delhi-110044.		
2	Type of Occupancy	Industrial Building "Group G"		
3	Building comprised of	Basement, Ground plus one upper floor.		
4	Type of case	Renewal		
5	Details of previous NOC	No.F6/DFS/MS/2013/SZ/511, Dated 03.07.13.		
6	Fire safety directives letter No	F.6/DFS/MS/BP/99/2921, Dated 16.03.1999.		
7	Date of inspection	13.07.2016.		
8	Name of the inspecting Officers	ADO Vedpal		
9	Name and designation of officers from the building side	Sh. Shashank Kumar (GM Administration)		
10	Year of construction	1999-2000		
11	Applicant's letter No.	Nil	Dt. 10.06.2016	
S. NO.	Minimum Standards on fire prevention and fire safety U/R 33	Requirement as per NBC/BBL	Provided at site	Remarks / NMR MR
1	Access to building			
	1) Road width	9 mtrs	50m Main Mathru Road	MR
	2) Gate width	5m	5m	MR
	3) Width of internal road	N/A	4.5m two sides	N/A
2	Number, width Type & arrangement of exits			
	a. Number of staircases			
	1. Upper floors	02nos.	02nos.	MR
	2. basements	02nos.	02nos.	MR
	b. Width of staircase			
	1. Upper floors	1.5 m & 90cm	1.5m & 90cm	MR
	2. basements	1.5 mtrs(each)	1.5m (each)	MR
	c. Protection of exits			
	1. Fire check door	Required in basement only	Provided in basement only	MR
	2. Pressurization	N/A	N/A	N/A
	d. No. of continuous staircase to terrace	02nos.	02nos.	MR
	e. Width of corridor	N/A	N/A	N/A
	f. Door size	1.0 m	1.25m (each)	MR
3	Compartmentation.			
	1. Fire check door	Required	Provided in basement only	MR
	2. Sealing of electrical shafts	Required	Provided	MR
	3. Fire Rating of shaft door	Not Required	Not Required	N/A
	4. water curtain	Not Required	Not Required	N/A
	5. Fire dampers	Not Required	Not Required	N/A
4	Smoke Management system.			
	basement	30 a/c per hour	Exhust Fan Provided	MR
	upper floors	12 a/c per hour	Natural Ventilation	MR
5	Fire Extinguishers			
	total numbers		14 Nos	MR
	Types		ABC, Co2,	MR
	ISI marking	ISI	Yes	MR
6	First-Aid Hose Reels.			
	total numbers on each floor	01no.	01no.	MR
	Length of Hose reel hose	30 m	30m	MR
	Nozzle Diameter	5 mm	5mm	MR
7	Automatic fire detection and alarming system			
	Type of detectors	N/A	N/A	N/A
	location of Main Panel	N/A	N/A	N/A
	location of Repeater panel	N/A	N/A	N/A
	Alternate source of power	N/A	N/A	N/A
	hooter's location	N/A	N/A	N/A
8	MOEFA	N/A	Provided	N/A
9	Public Address System.	N/A	N/A	N/A
10	Automatic Sprinkler System.			
	basement	Required	Provided	MR
	upper floors	N/A	N/A	N/A
	sprinkler above false ceiling	N/A	N/A	N/A

11	Internal Hydrants			
	Size of riser/down-corner	N/A	100mm	N/A
	Number of Hydrants per floor	N/A	01no.	N/A
	hose Box	N/A	01no.	N/A
12	Yard Hydrants.			
	total number of hydrants	N/A	N/A	N/A
	hose box	N/A	N/A	N/A
13	Pumping arrangements			
	1. Ground level			
	a. Discharge of main Pump	N/A	N/A	N/A
	b. Head of main pump	N/A	N/A	N/A
	c. Number of main pumps	N/A	N/A	N/A
	d. jockey pump out put	N/A	N/A	N/A
	e. jockey pump head	N/A	N/A	N/A
	f. Standby Pump output	N/A	N/A	N/A
	g. Stanby Pump head	N/A	N/A	N/A
	h. Auto Starting/Manual stopping	N/A	N/A	N/A
	pump house access	N/A	N/A	N/A
	2. Terrace level			
	a. Discharge of pump	900+180 LPM	900+180LPM	MR
	b. head of the pump	40 mtr	40m(each)	MR
	c. Power supply	Required	Provided	MR
	d. Auto starting of pump	Required	Provided	MR
14	Captive water storage for fire fighting	As per sanctioned plan, 10000 ltrs UGWST & 12500 ltrs OHT required, but the owner has provided 25000 liters OHT and the same has been accepted by the competent authority in 2013 at the time of issuance of FSC.		
	1. Underground tank capacity	N/A	N/A	N/A
	a. Draw-off connection	N/A	N/A	N/A
	b. fire service inlet	N/A	N/A	N/A
	c. Access to tank	N/A	N/A	N/A
	Over head tank Capacity	10,000+12500 ltr	25000 Liters	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of lifts.			
	a. Pressurization of lift shaft	N/A	N/A	N/A
	b. pressurization of lift lobby	N/A	N/A	N/A
	c. communication in lift car	N/A	N/A	N/A
	d. Fireman's grounding switch	N/A	N/A	N/A
	e. Lift signage	N/A	N/A	N/A
17	Standby power supply	Required	Provided	MR
18	Refuge Area.	Not Required		
	total area			
	location			
19	Fire control room			
	a. detector system Panel	N/A	N/A	N/A
	b. Flow switch Panel	N/A	N/A	N/A
	c. PA system Panel	N/A	N/A	N/A
	d. Batter backup	N/A	N/A	N/A
	e. Building floor plans	N/A	N/A	N/A
20	Special Fire Protection systems for protection of special risks, if any: 02 nos CO2 type fire extinguishers provided near electric panel.			

The fire protection systems provided in the building were checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards on fire prevention and fire safety required under the rules the FSC issued vide letter No.F.6/DFS/MS/2013/SZ/511, dated 03.07.2013 renewal under rule 37 of the Delhi Fire Service Rule 2010 is recommended.

Accordingly DFA is put up for your approval and signature please.

 14/7/16
Signature of the inspecting officer

Name Vedpal

Designation : Assistant Divisional Officer

card - N/A