

**FORM 'H' : FORM FOR ISSUING FIRE SAFETY CERTIFICATE**

[See sub-rule (1) of rule 35]

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI

HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F6/DFS/MS/WZ/ 24/2016/1231

Dated: 4/8/2016

**FIRE SAFETY CERTIFICATE**

Certified that the M/s Nando's (A Unit of Janpath Restarants Pvt. Ltd.) Property No. 25, UGF, NWA Club Road, Punjabi Bagh West, New Delhi-110026 located on upper ground floor only, in a premises comprising Basement, Stilt Floor, Upper Ground Floor, 1<sup>st</sup> floor, 2<sup>nd</sup> Floor & 3<sup>rd</sup> Floor only owned / occupied by M/s Nando's (A Unit of Janpath Restarants Pvt. Ltd.) have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service rules, 2010 and verified by the officers concerned of Fire Service on 28.07.2016 in presence of Sh. Devender (General Manager / Brand) and that the building / premises is fit for occupancy class Assembly / Restaurant (Eating House) (Group-D) with effect from 4 / 8 /2016 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of conditions under 38 of the Delhi Fire Service rules, 2010.

Issued on 4/8/16..... at New Delhi.

  
(ATUL GARG)  
CHEF FIRE OFFICER,  
Phone No .011-23414250.

Copy to :-

1. Dy. Health officer, South Delhi Municipal Corporation, Public health Department, West Zone Vishal Enclave, New Delhi-27 w.r.t. letter No. D-2244/HD/WZ dated 05/07/2016.
2. Sh. Devender (G. M. / Brand), M/s Nando's (A Unit of Janpath Restarants Pvt. Ltd.) Property No. 25, UGF, NWA Club Road, Punjabi Bagh West, New Delhi-110026.

**Conditions for the validity of Fire Safety Certificate:-**

1. All the fire safety arrangement provided there in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non- functional fire safety measure shall be at the responsibility of the management.
3. The trained fire- fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. "The owner / Occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [WWW.dfs.Delhigovt.nic.in](http://WWW.dfs.Delhigovt.nic.in)
8. Basement shall be used strictly as per Building By Laws-1983.



## INSPECTION REPORT

1. Name & address of the building : **M/s Nando's(A Unit of Janpath Restarants Pvt. Ltd.)**, Property No. 25, UGF, NWA Club Road, Punjabi Bagh West, New Delhi-110026.
2. Type of Occupancy : Assembly / Restaurant (Eating House)
3. Type of Case : New (Restra at Upper Ground floor)
4. Details of previous NOC : Nil
5. Fire Safety directives letter No. : NBC (Part-IV)
6. Date of inspection : 28.07.2016
7. Name of the Inspecting Officers : A. K. Jaiswal (ADO JWP)
8. Name and designation of officers
- From the building side : Sh. Devender (General Manager / Brand)
9. Year of Construction : 2015-16
10. Applicant's letter No. : D-2244/HD/WZ Dated 05/07/2016.

S. No.	Minimum Standards on fire Prevention and fire safety U/R 33	NBC / BBL Requirement	Provided at site	Remarks MR/NMR
1.	<b>Access to building</b>			
	• Road width	09mtr	30 mtr	M.R.
	• Gate width	On main road	On main road	MR
	• Width of internal road	N/A	N/A	N/A.
2.	<b>Number, Width, Type &amp; Arrangement of Exits</b>			
	a. Number of staircases			
	• Upper Ground Floor	2	2	M.R.
	• Basement	N/A	N/A	N/A
	b. Width of staircases			
	• Upper Floors	2.00m x 1, 1.00m x 1	2.00m x1 & 1.50m x 1	M.R.
	• Basement	N/A	N/A	N/A
	c. Protection of exits			
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	d. No. of continuous staircases to terrace	1	1	M.R.
	e. Width of Corridor	N/A	N/A	N/A
	f. Door size	2.00m x 1 1.00m x 1	2.00m x1& 1.00 x 1	M.R.

3. Compartmentation.			
<ul style="list-style-type: none"> <li>• Fire check door</li> <li>• Sealing of electrical shafts</li> <li>• Fire Rating of shaft door</li> <li>• Water Curtain</li> <li>• Fire Dampers</li> </ul>	N/A	N/A	N/A
	N/A	N/A	N/A
	N/A	N/A	N/A
	N/A	N/A	N/A
	N/A	N/A	N/A
4. Smoke Management System.			
<ul style="list-style-type: none"> <li>• Basements</li> <li>• Upper floors</li> </ul>	N/A	N/A	N/A
	Required	Provided	M.R.
5. Fire Extinguishers			
<ul style="list-style-type: none"> <li>• Total numbers</li> <li>• Types</li> <li>• IS marking</li> </ul>	2	4	M.R.
	ABC & CO <sub>2</sub> type	Provided	M.R.
	ISI marks required	provided	M.R.
6. First-Aid Hose Reel.			
<ul style="list-style-type: none"> <li>• Total numbers on each floor</li> <li>• Length of hose reel hose</li> <li>• Nozzle diameter</li> </ul>	1	1	M.R.
	30 mtr.	Provided	M.R.
	5 mm	Provided	M.R.
7. Automatic fire detection and alarming system.			
<ul style="list-style-type: none"> <li>• Type of detectors</li> <li>• Location of Main Panel</li> <li>• Location of Repeater Panel</li> <li>• Alternate source of power</li> <li>• Hooter's Location</li> </ul>	NR	Smoke	NR
	NR	Provided	NR
	NR	Provided	NR
	NR	Provided	NR
	NR	Provided	NR
8. MOEFA	Required	Provided	M.R.
9. Public Address System.	N/A	N/A	N/A
10. Automatic Sprinkler system			
<ul style="list-style-type: none"> <li>• Basement</li> <li>• Upper Floor</li> <li>• Sprinkler above false ceiling</li> </ul>	N/A	N/A	N/A
	NR	Provided on upper Ground Floor	NR
	N/A	N/A	N/A
11. Internal Hydrants			
<ul style="list-style-type: none"> <li>• Size of riser/down-comer</li> <li>• Number of hydrants per floor</li> <li>• Hose Box</li> </ul>	100mm	100mm	MR
	1	1	MR
	1	1	MR

22

12.	<b>Yard Hydrants.</b>			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A

13.	<b>Pumping Arrangements.</b>			
	<b>Ground Level</b>			
	➤ Discharge of main pump	NR	NR	NR
	➤ Head of Main pump	NR	NR	NR
	➤ Number of main pumps	NR	NR	NR
	➤ Jockey Pump out put	NR	NR	NR
	➤ Jockey pump head	NR	NR	NR
	➤ Standby pump out put	NR	NR	NR
	➤ Standby pump Head	NR	NR	NR
	➤ Auto Starting/Manual stopping	NR	NR	NR
	➤ Pump Hose Access	NR	NR	NR
	<b>Terrace level</b>			
	➤ Discharge of pump	450 LPM	450 LPM	M.R
	➤ Head of the pump	40 MH	40 MH	M.R
	➤ Power supply	Required	Provided	M.R
	➤ Auto Starting of pump	required	Provided	M.R

14.	<b>Captive Water Storage for fire fighting.</b>			
	<b>Underground tank capacity</b>	NR	NR	NR
	➤ Draw -off connection	NR	NR	NR
	➤ Fire service inlet	NR	Provided	NR
	➤ Access to tank	NR	Provided	NR
	➤ Overhead Tank Capacity	10,000 ltrs	10,000 ltrs	M.R

15	<b>Exit Signage.</b>	Required	Provided	M.R.
----	----------------------	----------	----------	------

16.	<b>Provision of Lifts</b>			
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication In lift Car	N/A	N/A	N/A
	• Fireman's Grounding Switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A

N/4

17.	Standby power supply	Required	Provided	M.R
18.	Refuge Area			
	➤ Total Area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19.	Fire Control Room	Required	Provided	M.R
	➤ Detector System Panel	N/A	N/A	N/A
	➤ Flow Switch Panel	N/A	N/A	N/A
	➤ PA system Panel	N/A	N/A	N/A
	➤ Battery backup	N/A	N/A	N/A
	➤ Building Floor plans	N/A	N/A	N/A
20.	Special Fire Protection Systems for Protection of special Risks, if any:	N.R.	N.R.	N.R.

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view of the substantial compliance of the minimum standards of fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010 is recommended.

*A.K. Jaiswal*  
29/7/16

Signature of the Inspection Officer

Name: A. K. Jaiswal

Designation: ADO (Jwp.)

*D.O. (w)*

*Mukherjee*  
1/8/16

*[Signature]*  
27/8/16

*Dy. CPO (w2)*

*CPO. West*  
*[Signature]*  
4/10/16