

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI- 110001

No. F6/DFS/ans/school/2016/ND2/1228

Dated: 03/08/16

FIRE SAFETY CERTIFICATE

Certified that the Blessings World International School is running at ground plus one floor of a building comprising of basement, ground plus one upper floors at D-Block, Preet Vihar, Delhi-92 owned/occupied by Blessings World International School have complied with the fire prevention and fire safety requirements in accordance with the circular no. F-16/Estate/CC/FS/2011/3298 to 3398 dated 01/03/11 issued by the Director of Education and verified by the officer concerned of this department on 24/06/16 in the presence of Manager of the school and found that the GF+FF of building is fit for occupancy class B 'Educational Building' for with effect from 03/08/16.. for a period of **three** years, subject to conditions printed overleaf.

Issued on.....03/08/16.....at New Delhi by



(Sunil Chawdhary)
Dy. Chief Fire Officer

To,

The Manager,
Blessings World International School D-Block,
Preet Vihar, Delhi-92

Copy:-

The Director of Education,
Udyog Sadan, Plot No.419, FIE,
Patparganj Industrial Area, Delhi-110092.

o/c
RE

INSPECTION REPORT

1. Name & address of the building : Blessings World International School D-Block, Preet Vihar, Delhi-92.
2. Building is comprised of : B+G+1 (School at Ground + 1st Floor)
3. Type of Occupancy : Educational (Area approx 200 m² on each floor)
4. Type of Case : New Case
5. Details of Previous NOC : Nil
6. Fire Safety direction letter No : F.16/Estate/CC/Fire safety/2011/3298 to 3398 dated 01.03.11
7. Date of Inspection : 24.06.2016
8. Name of the Inspecting Officers : R.K.Yadav (ADO)
9. Name of the designation of Officer from the building side : Manager
10. Year of Construction : 2011
11. Applicant's letter No : dated 08.06.2014

S.No	Minimum Standards on fire safety requirements as per circular no. 3298 to 3398 Dated. 01.03.11	Requirement as per DOE DT-1-3-11	Provided at Site	Remarks MR/NMR
1	Access to building			
	Road width	6 m	6 m	MR
	Gate width	N.A	N.A	N.A
	Width of internal road	N.A	N.A	N.A
2	Number, Width, Type and Arrangement of Exits			
	a. Number of Staircases			
	Upper Floor	1 no.	1 no.	MR
	Basement	1 no.	1 no.	MR
	B. Width of Staircases			
	Upper Floor	1.5 m	1.5 m	MR
	Basement	1.5 m	1.5 m	MR
	c. Protection of exits			
	Fire check door	N.A	N.A	N.A
	Pressurization	N.A	N.A	N.A
	e. No. of continuous staircases to terrace	N.A.	N.A.	N.A.
g. Width of Corridor	1.5 m	1.5 m	MR	
h. Door Size	1 m	1 m	MR	
3	Compartmentation.			
	Fire check door	N.A	N.A	N.A
	Sealing of electrical shafts	N.A	N.A	N.A
	Fire rating of shaft door	N.A	N.A	N.A
	Water curtain	N.A	N.A	N.A
	Fire Dampers	N.A	N.A	N.A
4	Smoke Management System.			
	Basement	N.A	N.A	N.A
	Upper floor	N.A	N.A	N.A
5.	Fire Extinguisher			
	Total numbers	06 no.	08 no.	MR
	types	CO ₂ & ABC	CO ₂ & ABC	MR
	ISI marking	ISI marked	ISI marked	MR

M12

	Total numbers of each floor	N.A	1 no.Provided	MR
	Length of hose reel hose	N.A	1 no.Provided	MR
	Nozzle diameter	N.A	1 no.Provided	MR
7	Automatic fire detection and alarming system.			
	Type of detectors	N.A	N.A	N.A
	Location of main panel	N.A	N.A	N.A
	Location of repeater panel	N.A	N.A	N.A
	Alternate source of power	N.A	N.A	N.A
	Hooters	N.A	N.A.	N.A.
8	MOEFA	N.A	N.A.	N.A.
9	Public address System.	N.A	N.A.	N.A.
10	Automatic Sprinkler System.			
	basement	Required	Provided	MR
	upper floor	N.A	N.A	N.A
	sprinkler above false ceiling	N.A	N.A	N.A
11	Internal Hydrants			
	size of riser/down-comer	N.A	N.A	N.A
	Number of hydrants per floor	N.A	N.A	N.A
	Hose Box	N.A	N.A	N.A
12	Yard Hydrants.			
	Total number of hydrants	N.A	N.A	N.A
	Hose Box	N.A	N.A	N.A
13	Pumping Arrangements.			
	<ul style="list-style-type: none"> • Ground Level ➤ Discharge of main Pump ➤ Head of Main Pump ➤ Number of main pumps ➤ Jockey pump out put ➤ Jockey pump head ➤ Standby pump out put ➤ Standby pump Head ➤ Auto Starting /Manual stopping ➤ Pump House Access • Terrace Level ➤ Discharge of pump ➤ Head of the Pump ➤ Power supply ➤ Auto Starting of pump 	N.A	N.A	N.A
		N.A	N.A	N.A
		N.A	N.A	N.A
		N.A	N.A	N.A
		N.A	N.A	N.A
		N.A	N.A	N.A
		N.A	N.A	N.A
		N.A	N.A	N.A
		N.A	N.A	N.A
		N.A	N.A	N.A
		N.A	450 Lpm	MR
		N.A	40 m	MR
		N.A	Provided	MR
		N.A	Manual	MR
14	Captive Water Storage for Fire Fighting.			
	Underground tank capacity	N.A	N.A	N.A
	Draw-off connection	N.A	N.A	N.A
	Fire service inlet	N.A	N.A	N.A
	Access to tank	N.A	N.A	N.A
	Overhead Tank capacity	N.A	5,000 Lt.	MR
15	Exit Signage.	Required	Provided	MR

Contd.

N/3

16	Provision of Lifts.			
	Pressurization of Lift Shaft	N.A	N.A	N.A
	Pressurization of Lift lobby	N.A	N.A	N.A
	Communication in lift car	N.A	N.A	N.A
	Firemen's grounding switch	N.A	N.A	N.A
	Lift Signage	N.A	N.A	N.A
17	Standby power supply	N.A	N.A	N.A
18	Refuge Area.			
	Total area	N.A	N.A	N.A
	Location	N.A	N.A	N.A
19	Fire Control Room			
	Detector system panel	N.A	N.A	N.A
	Flow switch panel	N.A	N.A	N.A
	PA system panel	N.A	N.A	N.A
	Batter backup	N.A	N.A	N.A
	Building Floor Plans	N.A	N.A	N.A
20	Special Fire Protection systems for protection of special Risks, if any:	N.A	N.A	N.A

The fire protection systems provided in the building were tested/checked at the time of inspection.

Keeping in view the compliance of the minimum standards on fire prevention and fire safety required under the circular no. F16/Estate/CC/FireSafety/2011/3298 to 3398 dated 01/03/11, it is recommended to grant Fire Safety Certificate.

R.K. Yadav
15/12/2016

Signature of the Inspecting officer
Name- R.K. Yadav
Designation- ADO(LN)

DO(ED)

Line
15/7

DUFO(ND2)

du
15/7