

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE  
NEW DELHI- 110 001

No. F.6/DFS/MS/2016/1241

Dated: 5/8/16

FIRE SAFETY CERTIFICATE

Certified that the EDMC Primary School at Raghupura, Delhi-31, comprised of ground plus one upper floor owned/occupied by EDMC Primary School was issued FSC vide letter No. F.6/DFS/MS/School/2013/NDZ/576 Dated-18/07/13. The school building was inspected by the officer concerned of this department on 27/07/2016 in the presence of Smt. Ashok Bala Sharma (Principal) of the school and found that the school building have deemed complied with the fire prevention and fire safety requirements in accordance with Circular F16/Estate/CC/FireSafety/2011/3298 to 3398 dated 01/03/11 issued by Director of Education and the school building is fit for occupancy class "B" 'Educational Building' for ground+1floor only with effect from 5/8/16..... for a period of **three** years, subject to conditions, printed overleaf.

Issued on 5/8/2016..... at New Delhi by

43/8.  
(Vipin Kental)  
Chief Fire Officer

9/CRK

To,

The Principal,(1<sup>ST</sup> Shift)  
EDMC Primary School,  
Raghupura, Delhi-31.

Copy to:-

1. The Director of Education, EDMC,  
Udyog Sadan, Plot No. 419, FIE,  
Patparganj Industrial Area, Delhi-92.
2. The Principal,( 2<sup>ND</sup> Shift)  
EDMC Primary School,  
Raghupura, Delhi-31.

## CONDITIONS

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities.
5. This Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction /unauthorized use of land if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
7. The owner / occupier shall apply for renewal of this Fire Safety Certificate of the Director in Form 'J' [sub rule (1) of rule (37)] along with a copy of this Certificate, Six Months prior to its expiry

1. Name & address of the building : EDMC Primary School at Raghubarpura, Delhi-31.
2. Building is comprised of : G+1 Upper floor
3. Type of Occupancy : Educational
4. Type of Case : Renewal
5. Details of Previous FSC : F.6/DFS/MS/School/2013/NDZ/576 Dated-18/07/13
6. Fire Safety Circular No. : F.16/Estate/CC/FS/2011/3298 to 3398 dt 01.03.2011
7. Date of Inspection : 27/07/16
8. Name of the Inspecting officers : ADO R.K.Yadav
9. Name and designation of  
Officer from the building side : Smt.Ashok Bala Sharma (Principal)
10. Year of Construction : 2013
11. Applicant's letter No : Dated 12/07/16

N O	Minimum Standards on fire prevention and fire safety U/R33	Circular Requirement	Provided at Site	Remarks
1	<b>Access to building</b>			
	<ul style="list-style-type: none"> <li>• Road width</li> <li>• Gate width</li> <li>• Width of internal road</li> </ul>	06 m	3.5 m	Through one length hose
		N/A	N/A	N/A
		N/A	N/A	N/A
2	<b>Number, Width, Type and Arrangement of Exits</b>			
	<b>a. Number of Staircases</b>			
	<ul style="list-style-type: none"> <li>• Upper Floor</li> <li>• Basement</li> </ul>	2 no.	2 no.	MR
		N/A	N/A	N/A
	<b>B. Width of Staircases</b>			
	<ul style="list-style-type: none"> <li>• Upper Floor</li> <li>• Basement</li> </ul>	1.5 m	1.5 m each	MR
		N/A	N/A	N/A
	<b>c. Protection of exits</b>			
	<ul style="list-style-type: none"> <li>• Fire check door</li> <li>• Pressurization</li> </ul>	N/A	N/A	N/A
		N/A	N/A	N/A
	<b>d. No. of continuous staircases to terrace</b>	1 no.	1 no.	MR
	<b>e. Width of Corridor</b>	1.5 M	1.65 M	MR
	<b>f. Door Size</b>	1.0 Mtrs	1.0 Mtrs	MR
3	<b>Compartmentation.</b>			
	<ul style="list-style-type: none"> <li>• Fire check door</li> <li>• Sealing of electrical shafts</li> <li>• Fire rating of shaft door</li> <li>• Water curtain</li> <li>• Fire Dampers</li> </ul>	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
4	<b>Smoke Management System.</b>			
	<ul style="list-style-type: none"> <li>• Basement</li> <li>• Upper floor</li> </ul>	N/A	N/A	N/A
		N/A	N/A	N/A
5	<b>Fire Extinguishers</b>			
	<ul style="list-style-type: none"> <li>• Total numbers</li> <li>• Types</li> <li>• IS marking</li> </ul>	4 Nos.	Provided	MR
		ABC & Co2	ABC & Co2	MR
		ISI marked	ISI marked	MR

6	First-aid-Hose Reels.			
	Total numbers of each floor	N/A	N/A	N/A
	• Length of hose reel hose	N/A	N/A	N/A
	• Nozzle diameter	N/A	N/A	N/A
7	Automatic fire detection and alarming system.			
	• Type of detectors	N/A	N/A	N/A
	• Location of main panel	N/A	N/A	N/A
	• Location of repeater panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooter's location	N/A	N/A	N/A
8	MOEFA	N/A	Provided	MR
9	Public address System.	N/A	Provided	MR
10	Automatic Sprinkler System.	N/A	N/A	N/A
	• Basement	N/A	N/A	N/A
	• upper floor	N/A	N/A	N/A
	• sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants	N/A	N/A	N/A
	• size of riser/down-comer	N/A	N/A	N/A
	• Number of hydrants per floor	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
12	Yard Hydrants.	N/A	N/A	N/A
	• Total number of hydrants	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
13	Pumping Arrangements.			
	• Ground Level			
	➤ Discharge of main Pump	N/A	N/A	N/A
	➤ Head of Main Pump	N/A	N/A	N/A
	➤ Number of main pumps	N/A	N/A	N/A
	➤ Jockey pump out put	N/A	N/A	N/A
	➤ Jockey pump head	N/A	N/A	N/A
	➤ Standby pump out put	N/A	N/A	N/A
	➤ Standby pump Head	N/A	N/A	N/A
	➤ Auto Starting /Manual stopping	N/A	N/A	N/A
	➤ Pump House Access	N/A	N/A	N/A
	• Terrace Level			
	➤ Discharge of pump	N/A	N/A	N/A
	➤ Head of the Pump	N/A	N/A	N/A
	➤ Power supply	N/A	N/A	N/A
	➤ Auto Starting of pump	N/A	N/A	N/A
14	Captive Water Storage for Fire Fighting.			
	• Underground tank capacity	N/A	N/A	N/A
	➤ Draw-off connection	N/A	N/A	N/A
	➤ Fire service inlet	N/A	N/A	N/A
	➤ Access to tank	N/A	N/A	N/A
	• Overhead Tank capacity	N/A	N/A	N/A
15	Exit Signage.	N/A	N/A	N/A

N/9

16	Provision of Lifts.	N/A	N/A	N/A
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication in lift car	N/A	N/A	N/A
	• Firemen's grounding switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A
17	Standby power supply	N/A	N/A	N/A
18	Refuge Area.	N/A	N/A	N/A
	• Total area	N/A	N/A	N/A
	• Location	N/A	N/A	N/A
19	Fire Control Room	N/A	N/A	N/A
	• Detector system panel	N/A	N/A	N/A
	• Flow switch panel	N/A	N/A	N/A
	• PA system panel	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection systems for protection of special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were tested/checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules. The FSC issued vide letter no. F.6/DFS/MS/School/2013/NDZ/576 Dated-18/07/13 renew under the circular no. F.16/Estate/CC/Fire safety/2011/3298 to 3398 dated 01.03.11 is recommended.

*R.K. Yadav*  
28/7/2015

Signature of the Inspecting Officer  
Name:-R.K.Yadav  
Designation:-ADO (LN)

DYCFPO (NDZ) *[Signature]*  
28/7

C.F.P. FTB  
M.Scell

*[Signature]*  
29/7