

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI- 110001

NO. F6/DFS/MS/School/2016/SZ/ 1249

Dated: 8/8/16

FIRE SAFETY CERTIFICATE

Certified that the Shanti Gyan Vidhyapeeth School, located at Goyla (Dwarka) Near Sector-19, New Delhi – 110071, comprised of ground floor owned/occupied by Shanti Gyan Vidhyapeeth School was issued NOC by this office vide letter no. F6/DFS/MS/09/43 dated 6.01.2009. The said School building was re-inspected by the officer concerned of this department on 28.7.2016 in presence of Sh. Rohit Khurana (Manager) and found that the school management has added two more upper floors. The premises have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules 2010, and that the school building **(ground plus two upper floors)** is fit for occupancy class B "Educational Building" with effect from 8/8/16 for a period of **three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010 subject to conditions printed overleaf.

Issued on 8/8/2016 at New Delhi by


(Vipin Kental)
Chief Fire Officer
Delhi Fire Service


Copy to:

- 1 Deputy Director (Education) GNCT of Delhi, Old Secretariat, Delhi.
- 2 Manager, Shanti Gyan Vidhyapeeth School, located at Goyla (Dwarka) Near Sector-19, New Delhi – 110071.

CONDITIONS

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupation, electric installation etc. may be got verified from the concerned authorities.
5. The Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction / unauthorized use of land if any.
6. All comments / directions of licensing Department shall always be permitted and followed.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in.
8. The owner / occupier shall apply for renewal of this **Fire Safety Certificate to the Director in 'Form J' (sub Rule (1) of Rule 37)** along with copy of the certificate, six months prior to its expiry.

INSPECTION REPORT

1	Name & address of the building	Shanti Gyan Vidhyapeeth School, Goyla Near Sector-19, Dwarka, New Delhi-110071.		
2	Type of Occupancy	Educational Building "B"		
3	Type of case	Renewal/ Addition of two floors		
4	Details of previous NOC	F6/DFS/MS/09/43 dated 6.1.2009 (Ground Floor Only)		
5	Fire safety directives letter No	As per NBC Part IV		
6	Date of inspection	10.2.2016		
7	Name of the inspecting Officers :	ADO S.P. Bhardwaj		
8	Name and designation of officers from the building side	Sh. Rohit Khurana (Manager)		
9	Year of construction	2009/ 2014		
10	Applicant's letter No.	Nil Dated 8.7.2016	(Ground plus two upper floors)	
S. NO.	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR / NMR
1	Access to building			
	1) Road width	Accessible (6 Mtrs.)	6 Mtrs.	MR
	2) Gate width	Approachable (4.5 Mt	4.5 Mtrs. (Direct accessible from road)	MR
	3) Width of internal road	N/A	N/A	N/A
2	Number, width Type & arrangement of exits			
	a. Number of staircases			
	1. Upper floors	Two	Two	MR
	2. basements	N/A	N/A	N/A
	b. Width of staircase			
	1. Upper floors	1.5 Mtr	1.5 Mtr.	MR
	2. basements	N/A	N/A	N/A
	c. Protection of exits			
	1. Fire check door	N/A	N/A	N/A
	2. Pressurization	N/A	N/A	N/A
	d. No. of continuous staircase to terrace	Required	Two	MR
	e. Width of corridor	1.50 Mtrs.	1.75 Mtrs.	N/A
	f. Door size	1 Mtr.	1 Mtr.	MR
3	Compartmentation.			
	1. Fire check door	N/A	N/A	N/A
	2. Sealing of electrical shafts	N/A	N/A	N/A
	3. Fire Rating of shaft door	N/A	N/A	N/A
	4. water curtain	N/A	N/A	N/A
	5. Fire dampers	N/A	N/A	N/A
4	Smoke Management system.			
	basement	N/A	N/A	N/A
	upper floors		N/A	N/A

N7


5	Fire Extinguishers		8 Nos	MR
	total numbers	2 Nos. Each Floor (Co2 OR ABC) ISI	ABC & Co2	MR
	Types		Provided	MR
	ISI marking			
6	First-Aid Hose Reels.		One each floor	MR ✓
	total numbers on each floor	One each floor	One each floor	MR
	Length of Hose reel hose	30 m	30 m	MR
	Nozzle Diameter	5 mm	5 mm	
7	Automatic fire detection and alarming system			
	Type of detectors	N/A	N/A	N/A
	location of Main Panel	N/A	N/A	N/A
	location of Repeater panel	N/A	N/A	N/A
	Alternate source of power	N/A	N/A	N/A
	hooter's location	N/A	N/A	N/A
8	MOEFA	N/A	N/A	N/A
9	Public Address System.	N/A	N/A	
10	Automatic Sprinkler System.			
	basement	N/A	N/A	N/A
	upper floors	N/A	N/A	N/A
	sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants			
	Size of riser/down-corner	N/A	Provided	N/A
	Number of Hydrants per floor	N/A	One each floor	N/A
	hose Box	N/A	One each floor	N/A
12	Yard Hydrants.			
	total number of hydrants	N/A	N/A	N/A
	hose box	N/A	N/A	N/A
13	Pumping arrangements			
	1. Ground level			
	a. Discharge of main Pump	N/A	N/A	N/A
	b. Head of main pump	N/A	N/A	N/A
	c. Number of main pumps	N/A	N/A	N/A
	d. jockey pump out put	N/A	N/A	N/A
	e. jockey pump head	N/A	N/A	N/A
	f. Standby Pump output	N/A	N/A	N/A
	g. Stanby Pump head	N/A	N/A	N/A
	h. Auto Starting/Manual stopping	N/A	N/A	N/A
	pump house access	N/A	N/A	N/A
	2. Terrace level			
	a. Discharge of pump	450 LPM	450 LPM	MR ✓
	b. head of the pump	30 Meter	30 Meter	MR
	c. Power supply	Required	Provided	MR
d. Auto starting of pump	Required	Provided	MR	
14	Captive water storage for fire fighting			
	1. Underground tank capacity	N/A	N/A	N/A
	a. Draw-off connection	N/A	N/A	N/A
	b. fire service inlet	N/A	N/A	N/A
	c. Access to tank	N/A	N/A	N/A
	Over head tank Capacity	10000 Ltrs.	10000 Ltrs.	MR ✓
		Required	Provided	MR
15	Exit Signage.	Required	Provided	



2/8

16	Provision of lifts.			
	a. Pressurization of lift shaft	N/A	N/A	N/A
	b. pressurization of lift lobby	N/A	N/A	N/A
	c. communication in lift car	N/A	N/A	N/A
	d. Fireman's grounding switch	N/A	N/A	N/A
	e. Lift signage	N/A	N/A	N/A
17	Standby power supply	N/A	N/A	N/A
18	Refuge Area.	Not Required		
	total area			
	location			
19	Fire control room			
	a. detector system Panel	N/A	N/A	N/A
	b. Flow switch Panel	N/A	N/A	N/A
	c. PA system Panel	N/A	N/A	N/A
	d. Batter backup	N/A	N/A	N/A
	e. Building floor plans	N/A	N/A	N/A
20	Special Fire Protection systems for protection of special risks, if any: ABC fire extinguisher near electric panel			MR

In view of the compliance of minimum standards of fire prevention & fire safety requirements as required under the rules the Fire safety certificate issued vide letter no. F6/DFS/MS/09/43 dated 6.01.2009 for **ground floor**, is recommended for **ground plus two upper floors**, under rule 35 of the Delhi Fire Service Rules, 2010.

Accordingly DFA is put up for approval and signature please.


 Signature of the Inspecting Officer
 Name S.P. Bhardwaj
 Designation ADO (Dwarka)

~~DO/SW~~
~~DCFO (SZ)~~

 28/1/2016

 2/8