

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No.F.6/DFS/MS/2016/CNG/ w2/117

Dated: 23/08/2016

**FIRE SAFETY CERTIFICATE**

Certified that the CNG Station located at PaschimVihar, New Delhi-63, comprised of Ground Floor only owned / occupied by Indraprastha Gas Limited has already been issued NOC / FSC by this department vide letter No. F5(3A)/CNG/DFS/2004/534 dated 11/11/2004. The premises was re-inspected by the officer concerned of this department on 20.07.2016 in the presence of Mr. Raj Kumar (Manager) have complied with the fire prevention and fire safety requirements in accordance with OISD-179 and that the premises is fit for occupancy class Hazardous(Group-J / CNG Station)with effect from 23/08/2016 for a period of three years in accordance with rule 36 unless renewal under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the DFS rules,2010 subject to conditions printed below.

Issued on 23/08/16 at New Delhi by.

  
(ATUL GARG)  
CHIEF FIRE OFFICER  
Phone:-23414250



Copy to :-

1. General Manager (Fire & Safety), Indraprastha Gas Limited, IGL Bhawan, Plot No.4, Community Centre, R.K. Puram, Sec.-9, New Delhi.

**Conditions for the validity of Fire Safety Certificate:**

1. All the fire safety arrangement provided there in shall be maintained in good working conditions at all times.
2. Loss of life or property due to nonfunctional fire safety measure shall be at the responsibility of the management.
3. The trained Fire Fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc. shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. “The owner / Occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form ‘J’ [sub rule (1) of rule37] along with a copy of this Certificate, six months prior to its expiry”.
7. The owner / occupier shall submit a declaration every year in form “K” provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in

1. Name & address of the building: **CNG Station, Paschim Vihar, Near Basco Public School, New Delhi-63.**
2. Type of Occupancy : **Hazardous**
3. Type of Case : **Renewal**
4. Details of previous NOC : **F5(3A)/CNG/DFS/2004/534 dated 11/11/2004**
5. Fire Safety directives Letter No. : **OISD-~~197~~ 149**
6. Date of inspection : **20/07/2016**
7. Name of the Inspecting Officer : **A.K. Jaiswal, A.D.O. (Jwalapuri)**
8. Name and designation of Officer  
from the building side : **Mr. Raj Kumar (Manager)**
9. Year of Construction : **2003**
10. Applicant's letter No. : **IGL/F&S/2016-17/15/90/1 dated 24/06/2016**

S No	Minimum standards on fire prevention and fire safety U/R 33	BBL / NBC-IV / OISD / Guidelines Requirements	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	6mtr	30mtr	MR
	• Gate width	N/A	N/A	N/A
	• Width of internal road	N/A	N/A	N/A
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	N/A	N/A	N/A
	• Basements	N/A	N/A	N/A
	b. Width of staircases			
	• Upper floors	N/A	N/A	N/A
	• Basements	N/A	N/A	N/A
	c. Protection of exits			
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	d. No of continuous staircase to terrace	N/A	N/A	N/A
	e. Width Of Corridor	N/A	N/A	N/A
	f. Door Size	1mtr	Provided	MR
3.	Compartmentation			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire Rating of shaft door	N/A	N/A	N/A
	• Water Curtain	N/A	N/A	N/A
	• Fire Dampers			
4.	Smoke managements System			
	• Basements	N/A	N/A	N/A
	• Upper floors	N/A	N/A	N/A
5.	Fire Extinguishers			
	• Total numbers	14	14	M/R
	• Types	ISI marked DCP 10 K	Provided	M/R

	<ul style="list-style-type: none"> <li>Total numbers on each floor</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>Length of hose reel hose</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>Nozzle diameter</li> </ul>	N/A	N/A	N/A
7.	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> <li>Type of detector</li> </ul>	Hand Held explosive Meter / Detector	Provided found functional	MR
	<ul style="list-style-type: none"> <li>Location of Main Panel</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>Location of Repeater Panel</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>Alternate source of power</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>Hooters' Location</li> </ul>	N/A	N/A	N/A
8.	MOEFA	Required	Provided	MR
9.	Public Address System	N/A	N/A	N/A
10.	Co <sub>2</sub> flooding system			
	<ul style="list-style-type: none"> <li>Ground Floor</li> </ul>	Required in compressor Area	Provided	MR
	<ul style="list-style-type: none"> <li>Upper Floor</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>Sprinkler above false ceiling</li> </ul>	N/A	N/A	N/A
11.	Internal Hydrants			
	<ul style="list-style-type: none"> <li>Size of riser/down-comer</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>Number of hydrants per floor</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>Hose Box</li> </ul>	N/A	N/A	N/A
12.	Yard Hydrants			
	<ul style="list-style-type: none"> <li>Total number of hydrants</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>Hose Box</li> </ul>	N/A	N/A	N/A
13.	Pumping Arrangements			
	<ul style="list-style-type: none"> <li>Ground Level</li> </ul>	N/A		
	<ul style="list-style-type: none"> <li>Discharge of main pump</li> </ul>	N/A	N/A	
	➤ Head of main pump	N/A	N/A	N/A
	➤ Number of main pumps	N/A	N/A	N/A
	➤ Jockey pump out put	N/A	N/A	N/A
	➤ Jockey pump head	N/A	N/A	N/A
	➤ Standby Pump out put	N/A	N/A	N/A
	➤ Standby Pump Head	N/A	N/A	N/A
	➤ Auto Starting/Manual stopping	N/A	N/A	N/A
	➤ Pump House Access	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>Terrace level</li> </ul>			
	➤ Discharge of pump	N/A	N/A	N/A
	➤ Head of the pump	N/A	N/A	N/A
	➤ Power supply	N/A	N/A	N/A
	➤ Auto starting of pump	N/A	N/A	N/A
14.	Captive water Storage for fire fighting			
	<ul style="list-style-type: none"> <li>Underground tank capacity</li> </ul>	N/A	N/A	N/A
	➤ Draw of connection	N/A	N/A	N/A
	➤ Fire connection			

N/6

15	Exit Signage	Required	Provided	MR
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	N/A	N/A	N/A
	➤ Pressurization of lift lobby	N/A	N/A	N/A
	➤ Communication in lift Car	N/A	N/A	N/A
	➤ Fireman's Grounding Switch	N/A	N/A	N/A
	➤ Lift Signage	N/A	N/A	N/A
17.	Standby power supply	Required	Provided	MR
18.	Refuge Area	N/A	N/A	
	➤ Total area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19.	Fire control room			
	➤ Detector system panel	N/A	N/A	N/A
	➤ Flow Switch Panel	N/A	N/A	N/A
	➤ PA System Panel	N/A	N/A	N/A
	➤ Batter backup	N/A	N/A	N/A
	➤ Building Floor Plans	N/A	N/A	N/A
20.	Special Fire Protection Systems for Protection of special Risks, if any;	N/A	N/A	N/A

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the NOC issued vide letter No. **F5(3A)/CNG/DFS/2004/534 dated 11/11/2004** renewal under rule 35 of the Delhi Fire Service rules 2010 is recommended.

*A.K. Jaiswal*  
22/7/16

Signature of the Inspecting Officer

Name : A.K. Jaiswal

Designation : A.D.O. (Jwalapuri)

D.O. (C)

*Please speck.*  
*Jaiswal 25/7/16*