

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS : DELHI FIRE SERVICE : NEW DELHI - 110 001**

No. F.6/DFS/MS/FH/2016/SZ/1371

Dated: 08/09/16

**FIRE SAFETY CERTIFICATE**

Certified that the M/s Manoj Kumar Fire Works situated at Shop No. 9 (ground floor), Molarband Exten., Main Jaitpur Road, Badarpur, New Delhi proposed for running the trade of sale and possession of up to 600 Kg (100Kg fireworks and 500Kg Chinese/Sparklers) at the ground floor of a building comprised of ground floor only. The fireworks shop owned/ occupied by M/s Manoj Kumar Fire Works has complied with the guidelines issued by Delhi Police under Delhi Police Act and verified by the officer concerned of this department on 22/08/2016 in the presence of Mr. Manoj Kumar and the premises is fit for occupancy **Class Fire Works** w.e.f. 6/9/16 for a period of **Three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule-38 of the Delhi Fire Service Rules, 2010.

Issued on.....6/9/16..... at New Delhi.

*W. G. J.*  
(Vipin Kental)  
Chief Fire Officer  
Ph:-011-23412235

Copy to:-

1. Joint Commissioner of Police (Lic), 1<sup>st</sup> Floor, Police Station, Defence Colony, New Delhi (PFW/34)/2016/10785-87/Joint.CP/Lic. (Expl.), dated Nil
2. Sh. Manoj Kumar, M/s Manoj Kumar Fire Works, Shop No. 9, Molarband Exten., Main Jaitpur Road, Badarpur, New Delhi.

**Conditions for the validity of fire safety certificate:**

1. All the fire safety arrangement provided therein shall be maintained in good condition all the times.
2. Any loss of life for property due to non-functional of fire safety measures shall be responsibility of the management.
3. The trained firefighting staff should be available round the clock when shop is functional.
4. Any deviation w.r.t. construction etc shall be verified by the concern building sanctioning authority.
5. This fire safety certificate may not in any way be treated as regularization of unauthorized construction, if any.



**INSPECTION REPORT**


1. Name & address of the building : M/s Manoj Kumar Fire Works at Shop No. 9, Molarband Exten., Main Jaitpur Road, Distt South East, Badarpur, New Delhi.
2. Type of Occupancy : Fireworks (Sale and possession of up to 600 Kg (100Kg
3. Type of Case : New fireworks and 500Kg Chinese/Sparklers)
4. Details of Previous NOC : NIL
5. Fire Safety directives letter No : NIL
6. Date of inspection : 22.08.2016
7. Name of Inspecting Officer : A.K. Malik.
8. Name of the person from the building side : Sh. Manoj Kumar
9. Year of Construction : -NA-
10. Applicant's letter No. : Outdoor diary no. 7995 dated 12/08/16

S. No.	Point of Inspection	Requirement	Provided at site	Remarks MR/NMR
1.	<b>Type of construction and floor area &amp; floor level</b>			
	a. Minimum floor area	9m <sup>2</sup>	(2.6x3.5= 9.1) m <sup>2</sup>	MR
	b. Construction	Pucca	Provided	MR
	c. Premises Location	Not under the staircase/Mean of escape	Provided	MR
	d. Business permissible only at ground floor level	Required	Provided	MR
	e. Business from pavement of road prohibited	Prohibited	Provided	MR
2.	<b>Entrance &amp; Exits to the Licensed Premises</b>			
	The Licensed premises shall have independent entrance and exit	Required	Provided	MR
3.	<b>Type and distance of the surrounding risk</b>			
	The premises shall be situated at a distance of 15m from any such premises used for similar explosive/inflammable or hazardous material	Required 15m	Provided	MR
4.	<b>Nature of business run in the licensed premises</b>			
	The premises in which fireworks are kept shall be used only for possession and sale for fireworks and no other purpose	Required	Provided	MR
5.	<b>Type of electrical wiring and electrical fitting</b>			
	a. Preferably concealed or through conduit	Required	Provided	MR
	b. All electrical fitting should be flame/spark proof	Required	Provided with Casing & Capping	MR
6.	<b>Extension of shop for business</b>			
	Prohibited	Prohibited	Yes	MR
7.	<b>Approach Road</b>			
	The road width on the side of which premises is located should be 12m	12m	12m	MR
8.	<b>Fire Protection Arrangement</b>			
	a. Extinguisher Type and No's	2no. of Water type & 1 no. of ABC/CO <sub>2</sub> type	Provided	MR
	b. Sand and water buckets	2 No's Each	Provided	MR
	c. Water Drum	1 No.	Provided	MR
9.	<b>Any Other point that is contrary to the safety of people-NA-</b>			

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

Keeping in view of the above compliance of the minimum standards of fire prevention and fire safety measures as required under the rule 35 of the Delhi Fire Service Rules 2010, Fire Safety Certificate is recommended.

Accordingly DFA is put up for approval and signature.

  
29/8/16  
Signature of Inspecting Officer  
Name: A. K. Malik  
Designation: DO (SD)

204/CFO/52  
11/9/16/16/9.  
Dy. CFO (SZ)