

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS, DELHI FIRE SERVICE, NEW DELHI

No.F6/DFS/MS/School/2016/ ND2 /1389

Dated: 08/09/16

FIRE SAFETY CERTIFICATE

Certified that **Bhagwati Devi Shishu Bharti School, 280, Phatak Karor, Ajmeri Gate Bazar, Delhi-110006.** comprised of Ground floor, Mezzanine Plus two upper floors was granted FSC by this department vide letter No.F6/DFS/MS/School/2013/NDZ/789 dated **23/08/13**. The school premises was re-inspected by the officer concerned of this department on **23/08/16** in the presence of Mrs. Simmi Oberoi, Manager of the school and found that school management have complied with the fire prevention and fire safety requirements in accordance with the circular issued by the Director of Education dated 01.03. 2011 that the building is fit for occupancy, class **B "Educational Building"** with effect from 08/09/16 for a period of three years, subject to conditions printed below.

Issued on 08/09/16 at New Delhi.


(Vipin Kant)
Chief Fire Officer
Delhi Fire Service
Ph: - 011-23412225

Copy to:-

- (1) Director of Education, Old Secretariat, Delhi
- (2) The Principal, Bhagwati Devi Shishu Bharti School
280, Phatak Karor, Ajmeri Gate Bazar, Delhi-110006.

Conditions for the validity of fire safety certificate:-


1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
2. The means of escape shall be kept unobstructed / unlocked & remain available for speedy evacuation of occupants in case of an emergency.
3. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
4. The trained fire fighting staff should be available round the clock.
5. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
6. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to it expiry

11/11
INSPECTION REPORT

1. Name & address of the building :- Bhagwati Devi Shishu Bharti School
280, Phatak Karor, Ajmeri Gate Bazar, Delhi-06
2. Type of occupancy:- Group – B Education Building. Ground floor + Mezzanine + 02 upper floor
3. Type of case:- Renewal.
4. Details of previous FSC:- No.F6/DFS/MS/School/2013/NDZ/789 dated 23/08/13.
5. Fire safety directives No.- N/A
6. Date of inspection:- 23/08/16
7. Name of the inspecting officer:- A.D.O. Mehmood
8. Name & designation of officer:-
From the building side:- Mrs. Simmi Oberoi (manager)
9. Year of construction:- Old.
10. Applicant's letter No:- Nil. Dated 12/08/16

Old Case

S.No.	Minimum Standards on fire Prevention and fire safety U/R 33	As per Education Circular(Existing)	Provided at site	Remarks MR/NMR
1.	Access to Building			
	1) Road width	6 mtr.	06 mtr.	MR
	2) Gate width	1.40 mtr.	1.40 mtr.	MR
	3)Width of internal road	N/A	N/A	N/A
2.	Number, Width Type & Arrangement of Exits			
	A. Number of staircases			
	1. Upper floors	02 Nos.	02 Nos.	MR
	2. Basements	N/A	N/A	N/A
	B. Width of staircase			
	1. Upper floors	103 cms. & 93 cms	103 cms. & 93 cms	MR
	2. Basements	N/A	N/A	N/A
	C. Protection of exits			
	1. Fire check door	N/A	N/A	N/A
	2. Pressurization	N/A	N/A	N/A
	D. No. of continuous staircase to terrace			
	E. Width of corridor	N/A	N/A	N/A
	F. Door size	N/A	N/A	N/A
3.	Compartmentation			
	1) Fire check door	N/A	N/A	N/A
	2) Sealing of electrical shafts	N/A	N/A	N/A
	3) Fire rating of shaft door	N/A	N/A	N/A
	4) Water curtain	N/A	N/A	N/A
	5) Fire Dampers	N/A	N/A	N/A
4.	Smoke Management System			
	1) Basements	30 a/c per hour	N/A	N/A
	2) Upper floors	12 a/c per hour	N/A	N/A
5.	Fire Extinguishers			
	1) Total numbers	09 Nos.	09 Nos.	MR
	2) Types	ABC& CO2	Provided	MR




	3) ISI marking	ISI Marked	Provided	MR
6.	First-Aid Hose Reel			
	1) Total number of each floor	02 No.	Provided	N/A
	2) Length of hose reel hose	30 mtr.	Provided	N/A
	3) Nozzle diameter	5 mm	Provided	N/A
7.	Automatic Fire Detection & Alarming System			
	1) Type of detectors	N/A	N/A	N/A
	2) Location of main panel	N/A	N/A	N/A
	3) Location of repeater panel	N/A	N/A	N/A
	4) Alternate source of power	N/A	N/A	N/A
	5) Hooter's Location	N/A	N/A	N/A
8.	MOEFA			
		N/A	N/A	N/A
9.	Public Address System			
		Not required	Provided	N/A
10.	Automatic Sprinkler System			
	1) Basement	N/A	N/A	N/A
	2) Upper floors	N/A	N/A	N/A
	3) Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants			
	1) Size of riser/down-comer	100 mm	100 mm	MR
	2) Number of hydrants per floor	Not required	Two Provided	N/A
	3) Hose box	Not required	Two Provided	N/A
12.	Yard Hydrants			
	1) Total number of hydrants	N/A	N/A	N/A
	2) Hose box	N/A	N/A	N/A
13.	Pumping Arrangement			
	1) Ground level	N/A	N/A	N/A
	a) Discharge of main pump	N/A	N/A	N/A
	b) Head of main pump	N/A	N/A	N/A
	c) Number of main pump	N/A	N/A	N/A
	d) Jockey pump out put	N/A	N/A	N/A
	e) Jockey pump head	N/A	N/A	N/A
	f) Stand by pump output	N/A	N/A	N/A
	g) Stand by pump head	N/A	N/A	N/A
	h) Auto starting/Manual stopping	N/A	N/A	N/A
	2) Terrace level			
	a) Discharge of pump	450 LPM	Provided	MR
	b) Head of pump	40 mtr	Provided	MR
	c) Power supply	Required	Provided	MR
	d) Auto starting of pump	Required	Provided	MR
14.	Captive Water Storage for Fire Fighting			
	1) Under ground tank capacity	N/A	N/A	N/A
	a) Draw-off connection	N/A	N/A	N/A

[Handwritten signature]


	b) Fire service inlet	N/A	N/A	N/A
	c) Access to tank	N/A	N/A	MR
	d) Over head tank capacity	5000 ltrs	5000 ltrs.	MR
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.	N/A	N/A	N/A
	a) Pressurization of lift shaft	N/A	N/A	N/A
	b) Pressurization of lift lobby	N/A	N/A	N/A
	c) Communication in lift car	N/A	N/A	N/A
	d) Fireman's switch	N/A	N/A	N/A
	e) Lift signage	N/A	N/A	N/A
17.	Stand by Power Supply	Required	Provided	MR
18.	Refuge Area	N/A	N/A	N/A
	Total area location	N/A	N/A	N/A
19.	Fire Control Room	N/A	N/A	N/A
	a) Detector system panel	N/A	N/A	N/A
	b) Flow switch panel	N/A	N/A	N/A
	c) PA system panel	N/A	N/A	N/A
	d) Battery backup	N/A	N/A	N/A
	e) Building floor plan	N/A	N/A	N/A
20.	Special Fire Protection System for Protection of special Risk, if any:-			N/A


The fire protection system provided in the school were tested, checked at random and found functional at the time of inspection.


In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the FSC issued vide letter No.F6/DFS/MS/School/2013/NDZ/789 dated 23/08/13, renewal under rule35 of the Delhi Fire Service rules 2010, is recommended.



Mehmoed

Assistant Divisional Officer


DO (CS)


30/8/16


DYCSO (NDZ)


31/8