

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110 001.

No. F6/dfs/ms/school/2016/1402/1404

Dated: 12/09/16

FIRE SAFETY CERTIFICATE

Certified that the A.D. Public School is running at ground plus first floor of a building comprised of ground plus two upper floors (11th floor is being used as residence for school Chowkidar/Care taker) located at B-378, Street No.-06, Nehru Vihar, Delhi -110094 owned/occupied by A.D. Public School was issued NOC vide letter No.-F6/MS/DFS/06/2991 dated-09/10/2006. The school building was re-inspected by the officer concerned of this department on 12/08/2016 in presence of Mr. Madan Singh Bisht, Manager of the school and found that the school building has deemed complied with the fire prevention and fire safety requirements in accordance with Circular Letter No.262-362 Dated-17/01/05 issued by Director of Education and the school building is fit for occupancy class "B" 'Educational Building' for ground plus first floor with effect from 12/09/16 for a period of **three** years, subject to conditions, printed overleaf.

Issued on.....12/09/16..... at New Delhi by

12/9/16
(Vipin Kental)
Chief Fire Officer
Delhi Fire Service
o/c
H

To,
The Principal,
A.D. Public School,
B-378, Street No.-06, Nehru Vihar, Delhi -110094

Copy:-
The Dy. Director of Education
B-Block, Yamuna Vihar,
North-East, Delhi-110053

CONDITIONS

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities.
5. This Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction /unauthorized use of land if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dts.delhigovt.nic.in
7. The owner / occupier shall apply for renewal of this Fire Safety Certificate of the Director in Form 'J' [sub rule (1) of rule (37)] along with a copy of this Certificate, Six Months prior to its expiry

005W

1. Name & address of the building : A.D. Public School,
B-378, Street No.-6, Nehru Vihar, Delhi-110094
2. Building is comprised of : Ground plus two upper floors
(School is running on ground plus first floor)
3. Type of Occupancy : Educational
4. Type of Case : Renewal
5. Details of Previous NOC/FSC letter : F.6/MS/DFS/06/2991 Dated-09/10/2006
6. Fire Safety direction letter No : Dir. of Edu. Circular Letter No.262-362 Dated-17/01/05
7. Date of Inspection — 27/7/16 : 12/08/2016
8. Name of the Inspecting officers : ADO Vijay Bahadur
9. Name and designation of Officer from the building side : Mr. Madan Singh Bisht (Manager)
10. Year of Construction : 2001 & 2008
11. Applicant's letter No : Letter No.—Nil, Dated- 04/07/2016

Sr. No.	Minimum Standards on Fire Prevention and Fire Safety U/R33	Circular Requirement	Provided at Site	Remarks MR/NMR
01	Access to Building			
	• Road width	06 mtr.	06 mtr.	MR
	• Gate width	N/A	N/A	N/A
	• Width of internal road	N/A	N/A	N/A
02	Number, Width, Type and Arrangement of Exits			
	a. Number of Staircases			
	• Upper floor	01 No.	02 Nos.	MR
	• Basement	N/A	N/A	N/A
	B. Width of Staircases			
	• Upper floor	1.50 mtr.	1.10 & 0.80 mtr.	MR
	• Basement	N/A	N/A	N/A
	c. Protection of Exits			
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	d. No. of Continuous Staircases to Terrace	01 No.	01 No.	MR
	e. Width of Corridor	1.50 mtr.	1.50 mtr	MR
	f. Door Size	01 mtr.	01 mtr.	MR
03	Compartmentation.			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire rating of shaft door	N/A	N/A	N/A
	• Water curtain	N/A	N/A	N/A
	• Fire dampers	N/A	N/A	N/A
04	Smoke Management System.			
	• Basement	N/A	N/A	N/A
	• Upper floor	N/A	N/A	N/A
05.	Fire Extinguishers			
	• Total numbers	04 nos.	06 nos.	MR
	• types	ABC /CO ₂	ABC /CO ₂	MR
	• IS marking	ISI marked	ISI marked	MR

06	First-Aid-Hose Reels.			
	• Total numbers on each floor	01 No.	01 No.	MR
	• Length of hose reel hose	30 mtr.	30 mtr.	MR
	• Nozzle diameter	6.5 mm	6.5 mm	MR
07	Automatic Fire Detection and Alarming System.			
	• Type of detectors	N/A	N/A	N/A
	• Location of main panel	N/A	N/A	N/A
	• Location of repeater panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooter's location	N/A	N/A	N/A
08	MOEFA	N/A	N/A	N/A
09	Public Address System.	N/A	N/A	N/A
10	Automatic Sprinkler System.			
	• Basement	N/A	N/A	N/A
	• upper floor	N/A	N/A	N/A
	• sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants			
	• size of riser/down-comer	N/A	N/A	N/A
	• Number of hydrants per floor	N/A	N/A	N/A
	• Hose box	N/A	N/A	N/A
12	Yard Hydrants.			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose box	N/A	N/A	N/A
13	Pumping Arrangements.			
	➤ Ground Level			
	• Discharge of main pump	N/A	N/A	N/A
	• Head of Main pump	N/A	N/A	N/A
	• Number of main pumps	N/A	N/A	N/A
	• Jockey pump out put	N/A	N/A	N/A
	• Jockey pump head	N/A	N/A	N/A
	• Standby pump out put	N/A	N/A	N/A
	• Standby pump head	N/A	N/A	N/A
	• Auto starting /manual stopping	N/A	N/A	N/A
	• Pump house access	N/A	N/A	N/A
	➤ Terrace Level			
	• Discharge of pump	220 Lpm.	220 Lpm.	MR
	• Head of the pump	40 M	40 M	MR
	• Power supply	Required	Provided	MR
	• Auto starting of pump	Required	Provided	MR
14	Captive Water Storage for Fire Fighting.			
	• Underground tank capacity	N/A	N/A	N/A
	• Draw-off connection	N/A	N/A	N/A
	• Fire service inlet	N/A	N/A	N/A
	• Access to tank	N/A	N/A	N/A
	• Overhead tank capacity	2500 Ltr.	2500 Ltr.	MR
15	Exit Signage.	N/A	N/A	N/A
16	Provision of Lifts.			
	• Pressurization of lift Shaft	N/A	N/A	N/A
	• Pressurization of lift lobby	N/A	N/A	N/A
	• Communication in lift car	N/A	N/A	N/A
	• Firemen's grounding switch	N/A	N/A	N/A
	• Lift signage	N/A	N/A	N/A

N/5-

17	Standby Power supply	N/A	N/A	N/A
18	Refuge Area.			
	• Total area	N/A	N/A	N/A
	• Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector system panel	N/A	N/A	N/A
	• Flow switch panel	N/A	N/A	N/A
	• PA system panel	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building floor plans	N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of Special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were tested/checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under the rules, the NOC issued vide letter No.- F6/MS/DFS/06/2991 Dated-09/10/2006 renewal, under the Director of Education Circular Letter No.262-362 Dated-17/01/05, is recommended.

[Handwritten Signature]
24/8/16

Signature of the Inspecting Officer
Name- Vijay Bahadur
Designation- A.D.O(T.Pur)

~~DO(ED)~~

[Handwritten Signature]
26/8

~~DCFO (ND2)~~

[Handwritten Signature]
26/8

39/CF-ND2
30/8/16, 8/9/16.

CFD - FTM W
29/8