

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001**

No. F6/DFS/MS/School/SZ/2016/ 1407

Dated: 15/09/16

**FIRE SAFETY CERTIFICATE**

Certified that the **Little Keb School at Village Neb Sarai, New Delhi**, comprised of ground floor and two small rooms at 1<sup>st</sup> floor but the school is running at ground floor only **owned/occupied** by M/s Little Keb School was granted Fire Safety Certificate by this department vide letter No. F6/DFS/MS/School/2013/666 dated 06.08.2013. The premises was re-inspected by officer concerned of this department on 14.09.2016 in the presence of Mrs. Jayanti Kukreti, (Principal) and found that school have deemed complied with the fire prevention and fire safety requirements in accordance with Directorate of Education circular No. F.16/Fire Safety/2011/13298 to 3398 dated 01.03.2011 issued by Director of Education and the school building is fit for occupancy class "**Educational Building Group-B**" with effect from 15/09/ 2016 of the issue of this for a period of **Three years** subject to conditions as mentioned below.

Issued on ....15/09/16..... at New Delhi by

*Vipin Kental*  
(Vipin Kental)  
Chief Fire Officer  
Delhi Fire Service  
Ph.: 011-23412225

**Copy to: -**

1. The Principal, Little Keb School at Village Neb Sarai, New Delhi.
2. The Director of Education, Govt. of NCT of Delhi,  
Old Secretariat, New Delhi.

**Conditions for the validity of Fire Safety Certificate**

1. All the fire safety and means of escape facilities shall be maintained in good working condition at all time. Any lapse rendering the fire safety or means of evacuation facilities non-functional shall be the responsibility of the management.
2. Building Sanctioning authority may verify any deviation with regard to construction/occupancy in the building. In case of any deviation, the fire safety certificate stands null & void.
3. The staff shall be trained for operating fire fighting system and mock evacuation drill be conducted at regular interval and record be maintained.
4. The basement shall be used strictly as per the provisions of Building Bye Laws.
5. The Owner/Occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules, 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).
6. The Owner/Occupier shall apply for renewal of this Fire Safety Certificate to the Director in the form 'J' [sub rule (1) of rule 37] along with copy of this certificate, six months prior to its expiry. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).

N/S

**INSPECTION REPORT**

1	Name & Address of the Building	Little Keb School, Village Neb Sarai, New Delhi.		
2	Type of Occupancy	Educational Building "Group-B" (School)		
3	Building Comprised of	Ground floor and two small rooms at first floor		
4	Type of Case	Renewal		
5	Details of Previous NOC	F6/DFS/MS/School/2013/666 dated 06.08.2013		
6	Fire Safety Directives Letter No	Directorate of Education circular No. F.16/Estate/CC/ Fire Safety/2011/3298 to 3398 dated 01.03.2011		
7	Date of Inspection	14.09.2016		
8	Name of the Inspecting Officers	ADO R.N. Singh		
9	Name & Designation of Officers from the building side	Mrs. Jayanti Kukreti (Principal)		
10	Year of construction	Before 1990		
11	Applicant letter No.	Nil dated 16.08.2016		
<b>S. No</b>	<b>Minimum standards on Fire Prevention and Fire Safety U/R 33</b>	<b>Directorate of Education Circular Requirements</b>	<b>Provided at Site</b>	<b>Remarks MR/NMR</b>
<b>1</b>	<b>Access to Building.</b>			
	1. Road width	Accessible	4.5 Mts. + 2 Hose length	MR
	2. Gate width	NA	NA	NA
	3. Width of internal road	NA	NA	NA
<b>2</b>	<b>Number, width, type and arrangements of exits.</b>			
	<b>a. Number of Staircase</b>			
	1. Upper floors	NA	1 No	NA
	2. Basement floor	NA	NA	NA
	<b>b. Width of Staircase</b>			
	1. Upper floors	NA	NA <sup>1m</sup>	NA
	2. Basement floor	NA	NA	NA
	<b>c. Protection of exits</b>			
	1. Fire check door	NA	NA	NA
	2. Pressurization	NA	NA	NA
	<b>d. No. of continuous staircase to terrace</b>	NA	NA	NA
	<b>e. Width of corridor</b>	NA	NA	NA
	<b>f. Door size</b>	1 m	1 m	MR
<b>3</b>	<b>Compartmentation.</b>			
	1. Fire check door.	NA	NA	NA
	2. Sealing of electrical shafts.	NA	NA	NA
	3. Fire rating of shaft door.	NA	NA	NA
	4. Water curtain	NA	NA	NA
	5. Fire dampers.	NA	NA	NA
<b>4.</b>	<b>Smoke Management system.</b>			
	1. Basement	NA	NA	NA
	2. Upper floors	NA	NA	NA
<b>5.</b>	<b>Fire Extinguishers.</b>			
	1. Total numbers	4 Nos.	4 Nos.	MR
	2. Types	ABC/Co2	ABC	MR
	3. ISI Marking	Required	Provided	MR
<b>6.</b>	<b>First Aid Hose Reels.</b>			
	1. Total numbers on each floor.	NA	NA	NA
	2. Length of hose-reel hose.	NA	NA	NA
	3. Nozzle Diameter	NA	NA	NA


Renewal

Little Keb School at Village Neb Sarai

N/6

7	<b>Automatic Fire Detection and Alarming System.</b>			
	1. Type of detectors	NA	NA	NA
	2. Location of Main Panel	NA	NA	NA
	3. Location of Repeater Panel	NA	NA	NA
	4. Alternate source of power	NA	NA	NA
	5. Hooter's location	NA	NA	NA
8.	<b>MOEFA / SIREN</b>	NA	NA	NA
9.	<b>Public Address System</b>	NA	NA	NA
10.	<b>Automatic Sprinkler System</b>			
	1. Basement	NA	NA	NA
	2. Upper floors	NA	NA	NA
	3. Sprinkler above false ceiling	NA	NA	NA
11.	<b>Internal Hydrants.</b>			
	1. Size of Riser / Down-comer	NA	NA	NA
	2. Number of Hydrant per floor	NA	NA	NA
	3. Hose box.	NA	NA	NA
12.	<b>Yard Hydrants.</b>			
	1. Total number of hydrants.	NA	NA	NA
	2. Hose box.	NA	NA	NA
13.	<b>Pumping arrangements.</b>			
	<b>A. Ground Level</b>			
	a) Discharge of main pump.	NA	NA	NA
	b) Head of main pump.	NA	NA	NA
	c) Number of main pumps.	NA	NA	NA
	d) Jockey Pump output.	NA	NA	NA
	e) Jockey Pump head.	NA	NA	NA
	f) Standby Pump output.	NA	NA	NA
	g) Standby Pump head.	NA	NA	NA
	h) Auto Starting / Manual Stopping.	NA	NA	NA
	i) Pump house access.	NA	NA	NA
	<b>B. Terrace Level</b>			
	a) Discharge of pump.	NA	NA	NA
	b) Head of pump.	NA	NA	NA
	c) Power supply.	NA	NA	NA
	d) Auto starting of pump.	NA	NA	NA
14.	<b>Captive water storage for Fire Fighting.</b>			
	1. Underground tank capacity.	NA	NA	NA
	2. Draw-off connection.	NA	NA	NA
	3. Fire Service Inlet.	NA	NA	NA
	4. Access to tank.	NA	NA	NA
	5. Overhead tank capacity.	NA	NA	NA
15.	<b>Exit Signage.</b>	NA	NA	NA
16.	<b>Provision of Lifts.</b>			
	1. Pressurization of lift shaft.	NA	NA	NA
	2. Pressurization of lift lobby.	NA	NA	NA
	3. Communication in lift car.	NA	NA	NA
	4. Fireman's switch.	NA	NA	NA
	5. Lift signage.	NA	NA	NA
17.	<b>Standby Power Supply</b>	NA	NA	NA
18.	<b>Refuge Area</b>			
	1. Total area	NA	NA	NA
	2. Location	NA	NA	NA

N/7

19.	<b>Fire Control Room.</b> 1. Detector system panel. 2. Flow switch panel. 3. PA system panel. 4. Battery backup. 5. Building floor plan.	NA NA NA NA NA	NA NA NA NA NA	NA NA NA NA NA
20.	<b>Special Fire Protection System for the Protection of special Risk, if any.</b>			NA
<p>The Fire Protection system provided in the building were checked and found functional at the time of inspection.</p> <p>In view of the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under the circular of Director of Education dated 01/03/2011, Fire Safety Certificate issued vide letter No. F6/DFS/MS/School/2013/666 dated 06.08.2013, renewal under rule 37 of the Delhi Fire Service rules, 2010 is recommended</p> <p>Accordingly DFA is put up for approval and signature please.</p> <div style="text-align: right;">   Signature of the Inspecting Officer  Name : R.N. Singh  Designation: ADO </div>				

Div. Officer (SD)

*Div. Officer (SD)*  
15/9/16

Asst. CFO (Flw)

CFO (C2)