

FORM 'H'
FORM FOR ISSUING FIRE SAFETY CERTIFICATE

[Refer sub - rule (1) of rule 35]

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI

HEAD QUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE: NEW DELHI

No. F6/DFS/MS/EH/2016/1414

Dated: 19/09/2016

FIRE SAFETY CERTIFICATE

Certified that the **Punjab Grill** (A unit of Lite Bite Foods Pvt. Ltd.) at TF-01, 3rd Floor, Pacific Metro Mall Tagore Garden, Khayala, Subhash Nagar, New Delhi was issued FSC vide Letter No. F6/DFS/MS/EH/4255 dated 14/11/2012. FSC is issue to the Mall Vide Letter no. F6/DFS/MS/2014/WZ/345 dated 11/03/2014. The premises was re inspected by the officers concerned of this department on 24-08-2016 in the presence of **Mr. Jitender** (Manager) and found that the said building have deem complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rule, 2010 and that the premises is fit for occupancy class "Assembly" Group D with effect from 19/09/2016 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 19/09/2016 at New Delhi by.

(Atul Garg)
Chief Fire Officer,
Delhi Fire Service.

Copy to:

1. The Authorised Signatory,
Punjab Grill (A unit of Lite Bite Foods Pvt. Ltd.)
TF-01, 3rd Floor, Pacific Metro Mall Tagore Garden, Khayala, Subhash Nagar, New Delhi.
2. Dy. Health Officer (West Zone)
South Municipal Corporation, Rajouri Garden, New Delhi

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. Basement shall be used as per building bye laws.
7. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
8. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.

INSPECTION REPORT

1. Name & address of the building : Punjab Grill (A unit of Lite Bite Foods Pvt. Ltd.) at TF-01, 3rd Floor, Pacific Metro Mall Tagore Garden, Khayala, Subhash Nagar, New Delhi.
2. Type of Occupancy : Assembly
3. Type of Case : Renewal
4. Details of previous NOC : Letter No. F6/DFS/MS/EH/4255 dated 14/11/2012 for restaurant
FSC issue the Mall Vide Letter no. F6/DFS/MS/ 2014/WZ/345 dated 11/03/2014
5. Fire Safety directives Letter No. : N.A.
6. Date of inspection : 24-08-2016
7. Name of the Inspecting Officer : DO (West)
8. Name and designation of Officer
from the building side : Mr. Jitender (Manager)
9. Year of Construction : 2011
10. Applicant's letter No. : D-2337/HO/WZ/ Dated 14/07/2016

S No	Minimum standards on fire prevention and fire safety U/R 33	BBL Requirements	Provided at site	Remarks MR/NMR
1.	Access of building	(Common for the Building)		
	• Road width	12 m	60 m Provided	MR
	• Gate width	5 m	06 m Provided	MR
	• Width of internal road	6 m	12 m Provided	MR
2.	Number, width, Type & Arrangements of exits	(Common for the Building)		
0	a. Number of staircases			
	• Upper floors	02	02 Provided for the Restaurant	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper floors	2 staircase of 1.5 mtr width each	1.5 mtr Provided	MR
	• Basements	For the Mall	For the Mall	For the Mall
	c. Protection of exits			
	• Fire check door	Required	Provided	MR
	• Pressurization	Required for the restaurant	Provided	MR
	d. No of continuous staircase to terrace			
	e. Width Of Corridor	02 mtr	02 mtr Provided	MR
	f. Door Size	2 doors of 2 mtrs each for Restaurant	Provided	MR
3.	Compartmentation	(Common for the Building)		
	• Fire check door	Required	Provided	MR
	• Sealing of electrical shafts	Required	Provided	MR
	• Fire Rating of shaft door	Required	Provided	MR
	• Water Curtain			
	• Fire Dampers	NA	NA	NA
		Required	Provided	MR
4.	Smoke managements System	(Common for the Building)		
	• Basements	Required	Provided	MR
	• Upper floors	Required	Provided	MR

	<ul style="list-style-type: none"> Total numbers Types IS marking 	10 for the restaurant DCP & CO ₂ ISI marked	15 Provided Provided Provided	MR MR MR
6.	First – Aid Hose Reels			
	<ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter 	13 30 m 5 mm	04 for the restaurant Provided Provided	MR MR MR
7.	Automatic fire detection and alarming system (Common for the Building)			
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location 	Smoke & Heat for the restaurant 3 rd floor at restaurant level NA Required Required	Provided Provided NA Provided Provided	MR MR NA MR MR
8.	MOEFA	Required	Provided	MR
9.	Public Address System	Required for the Mall	Provided	MR
10.	Automatic Sprinkler System:			
	<ul style="list-style-type: none"> Basements Upper Floor Sprinkler above false ceiling 	For the Mall Required for the restaurant Required for the restaurant	For the Mall Provided Provided	For the Mall MR MR
11.	Internal Hydrants:			
	<ul style="list-style-type: none"> Size of riser/down- comer Number of hydrants per floor Hose Box 	150 mm 01 for the restaurant 01 for the restaurant	Provided Provided Provided	MR MR MR
12.	Yard Hydrants Common with the mall			
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	For the Mall For the Mall	For the Mall For the Mall	For the Mall For the Mall
13.	Pumping Arrangements: (Common for the Building)			
	<ul style="list-style-type: none"> Ground Level Discharge of main pump ➤ Head of main pump ➤ Number of main pumps ➤ Jockey pump out put ➤ Jockey pump head ➤ Standby Pump out put ➤ Standby Pump Head ➤ Auto Starting/Manual stopping ➤ Pump House Access Terrace level ➤ Discharge of pump ➤ Head of the pump ➤ Power supply ➤ Auto starting of pump 	2850 lpm 60 m 02 180 lpm 60 m 2850 lpm 60 m Required Required 450 lpm 50 m Required Required	2850 lpm Provided 60 m Provided 02 Provided 180 lpm Provided 60 m Provided 2850 lpm Provided 60 m Provided Provided Provided 450 lpm Provided 50 m Provided Provided Provided	MR MR MR MR MR MR MR MR MR MR MR MR MR
14.	Captive water Storage for fire fighting: Common with the Building			
	<ul style="list-style-type: none"> Under ground tank capacity ➤ Draw off connection ➤ Fire service inlet ➤ Access to tank Overhead Tank capacity 	NA NA NA NA 20, 000 ltrs	NA NA NA NA 20, 000 ltrs Provided	NA NA NA NA MR
15	Exit Signage	Required	Provided	MR
16.	Provision of Lifts: For Building			
	<ul style="list-style-type: none"> ➤ Pressurization of Lift Shaft ➤ Pressurization of lift lobby ➤ Communication in lift Car 	Required Required Required	Provided Provided Provided	MR MR MR

	➤ Lift Signage	Required	Provided	MR
	Standby power supply	Required	Provided	MR
18.	Refuge Area	N.R for the Restaurant		
	➤ Total area	NA	NA	NA
	➤ Location	NA	NA	NA
19.	Fire control room	Common with the Mall		
	➤ Detector system panel	Required	Provided	MR
	➤ Flow Switch Panel	Required	Provided	MR
	➤ PA System Panel	Required	Provided	MR
	➤ Battery backup	Required	Provided	MR
	➤ Building Floor Plans	Required	Provided	MR
20.	Special Fire Protection Systems for Protection of special Risks, if any;	NA	NA	NA

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of minimum standards on fire prevention and fire safety as required under the rules the NOC issued vide letter no. F6/DFS/MS/EH/4255 dated 14/11/2012 renewal under rule 35 of the Delhi Fire Service Rules 2010 is recommended.

Mukesh 26/8/16

Signature of the Inspecting Officer

Name Mukesh Verma

Designation D.O. (West)

Dy. LHO (W2)

PP Khande

Asst. Insp.

Spoken on 15/8/16.

Submitted please.

9/9/16

Dy. LHO (W2)

18/9/16

Mukesh 18/9/16