

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI

HEADQUARTERS : DELHI FIRE SERVICE : NEW DELHI - 110001

NO F 6/DFS/MS/EH/2016/M02/1422

Dated: 20/09/16

FIRE SAFETY CERTIFICATE

Certified that the **Zabardast Indian Kitchen (A unit of destination cafe private limited)** located at **Flat No E- 13/29, E Block Ground floor, Harsha Bhawan, Connaught Place, New Delhi-110001** comprised of **Basement G + 4 upper floors, restaurant at ground floor** owned/occupied by **Zabardast Indian Kitchen (A unit of destination cafe private limited)** have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and verified by officer concerned of Delhi Fire Service on 10/09/2016 in the presence is **Mr. Pushkar (G.M)** and found that the said premises is fit for occupancy class **Assembly /Business** with effect from 20/09/16 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40, subject to compliance of the conditions under rule 38 of the Delhi Fire service rule 2010,,printed below.

Issued 20/9/16---at New Delhi by.


2019
Sunil Chawdhary

DY. Chief Fire Officer
Delhi Fire Service

copy to:-

(1) Medical Officer of Health,
New Delhi Municipal Council,
Palika Kendra New Delhi.

(2) Zabardast Indian Kitchen (A unit of destination cafe private limited) located at flat no E- 13/29, E Block Ground floor, Harsha Bhawan, Connaught Place New Delhi -110001.

Condition:-

1. All the fire safety arrangement provided therein shall be maintained in good working conditions at all times.
2. All the means of escape shall be kept unobstructed /unlocked & remain available for speedy evacuation of occupants in case of an emergency.
3. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
4. The trained fire fighting staff should be available round the clock.
5. Any deviation w.r.t construction etc. shall be verified by the concerned building sanctioning authority.
6. The fire safety certificate may not be treated in any case for regularization of unauthorized construction if any.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi fire service 2010. The form is available on www.dfs.delhigovt.nic.in.
8. The owner / occupier shall apply for renewal of this fire safety certificated to the director in Form 'J' [sub rule (1) of rule 37] alongwith a copy of this certificate, six months prior to it expiry.

- 12/11 -

INSPECTION REPORT

1. Name & address of the building:- Zabardast Indian Kitchen (A unit of Destination Cafe Private Limited), Flat No. E-13/29, E- Block, Ground Floor, Harsha Bhawan, Connaught Place, New Delhi-110001
2. Type of occupancy:- Group – D Assembly Building
Basement, Gr. + 4 Upper Floors. (Restt. at Ground floor)
3. Type of case:- New
4. Details of previous NOC:- No.
5. Fire safety directives No.- N/A
6. Date of inspection:- 10/09/16
7. Name of the inspecting officer:- D.O. Gurmukh Singh & A.D.O. Manoj Kumar Sharma
8. Name & designation of officer From the building side:- Mr. Pushpender (G.M.).
9. Year of construction:- Old Heritage
10. Applicant's letter No:- No. MOH/D/931/(Lic.)/Si-I dated 09/08/16

S.No.	Minimum Standards on fire Prevention and fire safety U/R 33	Requirement/ NBC Pt. IV	Provided at site	Remarks MR/NMR
1.	Access to Building			
	1) Road width	6 mtr.	9 mtr.	MR
	2) Gate width	N/A	N/A	N/A
	3) Width of internal road	N/A	N/A	N/A
2.	Number, Width Type & Arrangement of Exits			
	A. Number of staircases			
	1. Upper floors	N/A	N/A	N/A
	2. Basements	N/A	N/A	N/A
	B. Width of staircase			
	1. Upper floors	N/A	N/A	N/A
	2. Basements	N/A	N/A	N/A
	C. Protection of exits			
	1. Fire check door	N/A	N/A	N/A
	2. Pressurization	N/A	N/A	N/A
	D. No. of continuous staircase to terrace	N/A	N/A	N/A
	E. Width of corridor	N/A	N/A	N/A
	F. Door size	2.0 mtr.	2.0 mtr. & 0.80 mtr.	MR
3.	Compartmentation			
	1) Fire check door	N/A	N/A	N/A
	2) Sealing of electrical shafts	N/A	N/A	N/A
	3) Fire rating of shaft door	N/A	N/A	N/A
	4) Water curtain	N/A	N/A	N/A
	5) Fire Dampers	N/A	N/A	N/A
4.	Smoke Management System			

- N/2 -

	1) Basements	30 a/c per hour	N/A	N/A
	2) Upper floors	12 a/c per hour	Exhaust fan provided	MR
5.	Fire Extinguishers			
	1) Total numbers	05 No.	06 No.	MR
	2) Types	ABC & CO2	ABC & CO2	MR
	3) ISI marking	ISI	Yes	MR
6.	First-Aid Hose Reel			
	1) Total number of each floor	01 no.	01 no.	MR
	2) Length of hose reel hose	30 m	30 m	MR
	3) Nozzle diameter	5 mm	5 mm	MR
7.	Automatic Fire Detection & Alarming System			
	1) Type of detectors	N/A	N/A	N/A
	2) Location of main panel	N/A	N/A	N/A
	3) Location of repeater panel	N/A	N/A	N/A
	4) Alternate source of power	N/A	N/A	N/A
	5) Hooter's Location	N/A	N/A	N/A
8.	MOEFA	Required	Provided	MR
9.	Public Address System	N/A	N/A	N/A
10.	Automatic Sprinkler System			
	1) Basement	N/A	N/A	N/A
	2) Upper floors	N/A	N/A	N/A
	3) Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants			
	1) Size of riser/down-comer	100 mm.	100 mm.	MR
	2) Number of hydrants per floor	1 No.	1 No.	MR
	3) Hose box	1 No.	1 No.	MR
12.	Yard Hydrants			
	1) Total number of hydrants	N/A	N/A	N/A
	2) Hose box	N/A	N/A	N/A
13.	Pumping Arrangement			
	1) Ground level	N/A	N/A	N/A
	a) Discharge of main pump	N/A	N/A	N/A
	b) Head of main pump	N/A	N/A	N/A
	c) Number of main pump	N/A	N/A	N/A
	d) Jockey pump out put	N/A	N/A	N/A
	e) Jockey pump head	N/A	N/A	N/A
	f) Stand by pump output	N/A	N/A	N/A
	g) Stand by pump head	N/A	N/A	N/A
	h) Auto starting/Manual stopping	N/A	N/A	N/A
	2) Terrace level			
	a) Discharge of pump	450 LPM	450 LPM	MR

h
m

19/7/5

	b) Head of pump	40 mtr.	40 mtr.	MR
	c) Power supply	Required	Provided	MR
	d) Auto starting of pump	Required	Provided	MR
14.	Captive Water Storage for Fire Fighting			
	1) Under ground tank capacity	N/A	N/A	N/A
	a) Draw-off connection	N/A	N/A	N/A
	b) Fire service inlet	N/A	N/A	N/A
	c) Access to tank	N/A	N/A	N/A
	d) Over head tank capacity	10,000 Ltrs.	10,000 Ltrs.	MR
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	a) Pressurization of lift shaft	N/A	N/A	N/A
	b) Pressurization of lift lobby	N/A	N/A	N/A
	c) Communication in lift car	N/A	N/A	N/A
	d) Fireman's switch	N/A	N/A	N/A
	e) Lift signage	N/A	N/A	N/A
17.	Stand by Power Supply	Required	Provided	MR
18.	Refuge Area			
	Total area location	N/A	N/A	N/A
19.	Fire Control Room			
	a) Detector system panel	N/A	N/A	N/A
	b) Flow switch panel	N/A	N/A	N/A
	c) PA system panel	N/A	N/A	N/A
	d) Battery backup	N/A	N/A	N/A
	e) Building floor plan	N/A	N/A	N/A
20.	Special Fire Protection System for Protection of special Risk, if any:			N/A

The fire protection systems provided in the building were tested, checked at random and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules, grant of fire Safety Certificate, under rule 35 of the Delhi Fire Service Rules 2010, is recommended please.

Usdnd
12/9/16
Gurmukh Singh
Divisional Officer

mesh
Manoj Kumar Sharma
Assistant Divisional Officer

Dy CFO (NDZ)

dh
14/9