

No.


F6/DFS/MS/2016/1424

Dated: 21.09.2016

FIRE SAFETY CERTIFICATE

Certified that M/s Dr.B.R.Ambedkar Institute of Rotary Cancer, AIIMS Complex, Ansari Nagar, New Delhi-110029, comprised of basement, ground plus seven upper floors, owned/occupied by All India Institute of Medical Sciences was granted Fire Safety Certificate by this department vide letter no. F6/DFS/MS/GH/2012/3289, dated 10.09.2012. The premises was re-inspected by the officer concerned of this department on 03.09.2016 in the presence of Mr. Deepak Kumar, Dy. Chief Security Officer and found that the premises have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the building fit for **Occupancy Group "C" (Institutional Building)** with effect from... 21.09.2016 for a period of **three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010, subject to condition as mentioned below.

Issued on 21.09.2016 at New Delhi by


(Vipin Kental)
Chief Fire Officer
T.No.011-23412225

Copy To:- Mr. Deepak Kumar, Dy. Chief Security Officer, All India Institute of Medical Sciences Ansari Nagar, New Delhi-110029. 

Conditions for the validity of fire safety certificate is as under

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities.
5. This Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in.
7. The owner/occupier shall apply for renewal of this Fire Safety Certificate in form J, six month prior to its expiry.

INSPECTION REPORT

1	Name & address of the building	M/s Dr.B.R.Ambedkar Institute of Rotary Cancer, AIIMS Complex, Ansari Nagar, New Delhi-110029.		
2	Type of Occupancy	Institutional Building "C" (Hospital)		
3	Building comprised of	Basement, Ground plus seven upper floors.		
3	Type of case	Renewal.		
4	Details of previous NOC	No.F6/DFS/MS/2012/3289, Dated 10.09.2012.		
5	Fire safety directives letter No	No.F6/MS/DFS/Hospital/BP/2000/1101, Dated 23.06.2000 for fire fighting system only in existing building.		
6	Date of inspection	03.09.2016		
7	Name of the inspecting Officers	ADO Vedpal		
8	Name and designation of officers from the building side	Sh.Depak Kumar Dy. Chief Security Officer of the Hospital.		
9	Year of construction	1968		
10	Applicant's letter No.	Security/Fire/Inspection/DFS/2016, Dated 05.08.2016.		
S. NO.	Minimum Standards on fire prevention and fire safety U/R 33	Requirement as per BBL/NBC	Provided at site	Remarks MR / NMR
1	Access to building			
	1) Road width	9 Mtrs	9Mtrs	MR
	2) Gate width	N/A	N/A	N/A
	3) Width of internal road	N/A	N/A	N/A
2	Number, width Type & arrangement of exits			
	a. Number of staircases			
	1. Upper floors	03nos.+1ramp	03nos.+1ramp	MR
	2. basements	02nos.	02nos.	MR
	b. Width of staircase			
	1. Upper floors	1.37m(each)	1.30,1.25,1.25m & ramp=2m	MR(old case)
	2. basements	1.25m(each)	1.30m & 1.25m	MR(old case)
	c. Protection of exits			
	1. Fire check door	Required	Provided	MR
	2. Pressurization	N/A	N/A	N/A
	d. No. of continuous staircase to terrace	02nos.	02nos.	MR
	e. Width of corridor	N/A	2m	N/A
	f. Door size	1m	1 Mtr & 1.25 Mtr	MR(old building)
3	Compartmentation.			
	1. Fire check door	Required	Provided	MR
	2. Sealing of electrical shafts	Required	Provided	MR
	3. Fire Rating of shaft door	N/A	N/A	N/A
	4. water curtain	N/A	N/A	N/A
	5. Fire dampers	N/A	N/A	N/A
4	Smoke Management system.			
	basement	30 a/c per hour	Provided	MR
	upper floors	12 a/c per hour	Natural Ventilation	MR
5	Fire Extinguishers			
	total numbers	58Nos	80 Nos.	MR
	Types	ABC, WCO2 & CO2	ABC, CO2 & Water	MR
	ISI marking	ISI	Mist	MR
6	First-Aid Hose Reels.			
	Total numbers on each floor	BF=2nos, GF to 5th F=3nos & 6th & 7th F=2nos.	BF=2nos, GF to 5th F=3nos & 6th & 7th F=2nos.	MR
	Length of Hose reel hose	30 Mtr	30m	MR
	Nozzle Diameter	5mm	5mm	MR
7	Automatic fire detection and alarming system			
	Type of detectors	Heat & Smoke	Provided	MR
	location of Main Panel	Ground Floor	Ground Floor	MR
	location of Repeater panel	N/A	N/A	N/A
	Alternate source of power	Required	Provided	MR
	hooter's location	All Areas	Provided	MR
8	MOEFA	Required	Provided	MR
9	Public Address System.	Required	Provided	MR

INSPECTION REPORT

10	Automatic Sprinkler System.			
	basement	Required	Provided	MR
	upper floors	N/A	Provided	N/A
	sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants			
	Size of riser/down-corner	150mm	150mm	MR
	Number of Hydrants per floor	BF=2nos, GF to 5th F=3nos & 6th & 7th F=2nos.	BF=2nos, GF to 5th F=3nos & 6th & 7th F=2nos.	MR
	hose Box	BF=2nos, GF to 5th F=3nos & 6th & 7th F=2nos.	BF=2nos, GF to 5th F=3nos & 6th & 7th F=2nos.	MR
12	Yard Hydrants.			
	total number of hydrants	06nos.	06nos.	MR
	house box	06nos.	06nos.	MR
13	Pumping arrangements			
	1. Ground level			
	a. Discharge of main Pump	2850LPM	2850LPM	MR
	b. Head of main pump	70m	70m	MR
	c. Number of main pumps	02nos.	02nos.	MR
	d. jockey pump out put	180LPM	180+180LPM	MR
	e. jockey pump head	70m	70m(each)	MR
	f. Standby Pump output	2850LPM	2850LPM	MR
	g. Stanby Pump head	70m	70m	MR
	h. Auto Starting/Manual stopping	Required	Provided	MR
	pump house access	Required	Provided	MR
	2. Terrace level			
	a. Discharge of pump	N/A	N/A	N/A
	b. head of the pump	N/A	N/A	N/A
	c. Power supply	N/A	N/A	N/A
	d. Auto starting of pump	N/A	N/A	N/A
14	Captive water storage for fire fighting			
	1. Underground tank capacity	2,00,000 ltr	2,00,000 Ltr Provided	MR
	a. Draw-off connection	Required	Provided	MR
	b. fire service inlet	Required	Provided	MR
	c. Access to tank	Required	Provided	MR
	Over head tank Capacity	20000Liters	20000Liters	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of lifts.			
	a. Pressurization of lift shaft	N/A	Provided	N/A
	b. pressurization of lift lobby	N/A	N/A	N/A
	c. communication in lift car	Required	Provided	MR
	d. Fireman's grounding switch	Required	Provided	MR
	e. Lift signage	Required	Provided	MR
17	Standby power supply	Required	Provided	MR
18	Refuge Area.	Not Required		
	total area			
	location			
19	Fire control room			
	a. Detector system Panel	Required	Provided	MR
	b. Flow switch Panel	N/A	N/A	N/A
	c. PA system Panel	Required	Provided	MR
	d. Batter backup	Required	Provided	MR
	e. Building floor plans	N/A	N/A	N/A


21/22

INSPECTION REPORT

20	Special Fire Protection systems for protection of special risks, if any: HT, LT & Transformer are provided with ABC & CO2 Type fire extinguishers. MR
----	---

The fire protection systems provided in the building were test checked at random and found functional at the time of inspection. In view of the deemed compliance of the minimum standards on fire prevention and fire safety required under the rules the NOC issued vide letter No.F.6/DFS/MS/GH/2012/3289, dated 10.09.2012, renewal under rule 37 of the Delhi Fire Service Rule 2010 is recommended. The shortcomings communicated vide this office letter dated 13.11.2015 have been complied at sr. nos. 2,3,4,5,6,11,13,15 & 16.

Accordingly DFA is put up for your approval and signature please.


5/9/16

Signature of the inspecting officer

Name Vedpal

Designation : Assistant Divisional Officer

~~D.O. (S.D.)~~

~~Anilam~~
5/9/16

~~Dy. C/O (S2)~~

~~Karp~~
6/9

