

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F6/DFS/MS/SCHOOL/2016/1434

Dated: 26/09/2016

FIRE SAFETY CERTIFICATE

Certified that Rajkiya Pratibha Vikas Vidyalaya (ID-1617009) located at A-6, Paschim Vihar, New Delhi- 110063, comprised of Ground floor only owned / occupied by **Delhi Govt.**, has already been issued NOC / FSC by this department vide letter No. F6/DFS/MS/School/2011/333 dated 02/12/2011. The premises was re-inspected by the officer concerned of this department on 03.09.2016 in the presence of Smt. Mukta Soni (Principal) and observed that Fire prevention and fire safety arrangements provided in the premises, found in good working condition. The premises have therefore, deemed complied with the fire prevention and fire safety requirements in accordance with the circular issued by No. F6/Estate/CC/Fire/Safety/2011/3298-3398 dated 01/03/2011 and that the building / premises is fit for occupancy class **Educational** (Group B) with effect from 26/09/2016 for a period of 3 (three) years subject to conditions printed below.

Issued on 26/09/2016 at New Delhi by.


(ATUL GARG)
CHIEF FIRE OFFICER,
Phone No. 011-23414250.

Copy to :-

1. Smt. Mukta Soni (Principal), Rajkiya Pratibha Vikas Vidyalaya (ID-1617009), A-6, Paschim Vihar, New Delhi- 110063.

Conditions for the validity of Fire Safety Certificate:-

1. All the fire safety arrangement provided there in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non- functional fire safety measure shall be at the responsibility of the management.
3. The trained fire- fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. "The owner / Occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in

1. Name & address of the building: Rajkiya Pratibha Vikas Vidyalaya (ID-1617009),
A-6, Paschim Vihar, New Delhi- 110063.
2. Type of Occupancy : Educational (G+1)
3. Type of Case : Renewal
4. Details of previous NOC : F6/DFS/MS/School/2011/333 dated 02/12/2011
5. Fire Safety directives Letter No. : DOE Circular Dated 01/03/2011
6. Date of inspection : 03/09/2016
7. Name of the Inspecting Officer : A. K.-Jaiswal
8. Name and designation of Officer
from the building side : Smt. Mukta Soni (Principal)
9. Year of Construction : -----

Total Area-15540m2
Covered Area-3276m2
Class Rooms-25
Students-776

10. Applicant's letter No. : - RPVV/PV/A6/208 dated 09/08/2016

S No	Minimum standards on fire prevention and fire safety U/R 33	DOE. Circ. Dated 01/03/2011 Requirements	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	Accessible	Provided	MR
	• Gate width	Accessible	Provided	MR
	• Width of internal road	N/A	N/A	N/A
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	4	4	MR
	• Basements	N/A	N/A	N/A
	b. Width of staircases			
	• Upper floors	1.50 mtr.	1.50 mtr x 4	MR
	• Basements	N/A	N/A	N/A
	c. Protection of exits			
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	d. No of continuous staircase to terrace	1	Provided	MR
	e. Width Of Corridor	1.50 mtr.	Provided	MR
	f. Door Size	1.00 mtr	1 mtr	MR
3.	Compartmentation			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire Rating of shaft door	N/A	N/A	N/A
	• Water Curtain	N/A	N/A	N/A
	• Fire Dampers			
4.	Smoke managements System			
	• Basements	N/A	N/A	N/A
	• Upper floors	N/A	N/A	N/A
5.	Fire Extinguishers			
	• Total numbers	8	8	NMR
	• Types	ISI marked	Provided	M/R

6.	• Total numbers on each floor	N/A	N/A	N/A
	• Length of hose reel hose	N/A	N/A	N/A
	• Nozzle diameter	N/A	N/A	N/A
7.	Automatic fire detection and alarming system			
	• Type of detector	N/A	N/A	N/A
	• Location of Main Panel	N/A	N/A	N/A
	• Location of Repeater	N/A	N/A	N/A
	• Panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooters' Location	N/A	N/A	N/A
8.	MOEFA	N/A	N/A	N/A
9.	Public Address System	N/A	N/A	N/A
10.	Automatic Sprinkler System			
	• Basements	N/A	N/A	N/A
	• Upper Floor	N/A	N/A	N/A
	• Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants			
	• Size of riser/down-comer	N/A	N/A	N/A
	• Number of hydrants per floor	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
12.	Yard Hydrants			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
13.	Pumping Arrangements			
	• Ground Level	N/A		
	• Discharge of main pump	N/A	N/A	
	➤ Head of main pump	N/A	N/A	N/A
	➤ Number of main pumps	N/A	N/A	N/A
	➤ Jockey pump out put	N/A	N/A	N/A
	➤ Jockey pump head	N/A	N/A	N/A
	➤ Standby Pump out put	N/A	N/A	N/A
	➤ Standby Pump Head	N/A	N/A	N/A
	➤ Auto Starting/Manual stopping	N/A	N/A	N/A
	➤ Pump House Access	N/A	N/A	N/A
	• Terrace level			
	➤ Discharge of pump	N/A	N/A	N/A
	➤ Head of the pump	N/A	N/A	N/A
	➤ Power supply	N/A	N/A	N/A
	➤ Auto starting of pump	N/A	N/A	N/A
14.	Captive water Storage for fire fighting			
	• Underground tank capacity	N/A	N/A	N/A

15	Exit Signage	N/A	N/A	M/R
16	Provision of Lifts			
	➤ Pressurization of Lift Shaft	N/A	N/A	N/A
	➤ Pressurization of lift lobby	N/A	N/A	N/A
	➤ Communication in lift Car	N/A	N/A	N/A
	➤ Fireman's Grounding Switch	N/A	N/A	N/A
	➤ Lift Signage	N/A	N/A	N/A
17	Standby power supply	N/A	N/A	N/A
18	Refuge Area	N/A	N/A	N/A
	➤ Total area	N/A	N/A	
	➤ Location	N/A	N/A	N/A
19	Fire control room	N/A	N/A	N/A
	➤ Detector system panel	N/A	N/A	N/A
	➤ Flow Switch Panel	N/A	N/A	N/A
	➤ PA System Panel	N/A	N/A	N/A
	➤ Batter backup	N/A	N/A	N/A
	➤ Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of special Risks, if any;	N/A	N/A	N/A

Note:-General requirements for schools as per Director of Education circular dated 01/03/2011.

1. Escape routeClear.....
2. LPG cylinders in laboratoriesNil.....
3. Electric wiring ... Conduit Wiring..... MCB and ELCB
4. Electric meter board not under the staircase
5. Basement use as per BBL 1983NA.....
6. Emergency telephone no. boardDisplayed.....
7. Generator setNil.....

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the NOC issued vide letter No. F6/DFS/MS/School/2011/333 dated 02/12/2011 renewal under rule 35 of the Delhi Fire Service rules 2010 is recommended.

Ashok Kumar Jaiswal
12/9/16

Signature of the Inspecting Officer

Name : Ashok Kumar Jaiswal

Designation : A.D.O. (Jwala Puri)

D.O/(w)

Ashok Kumar Jaiswal
15/9/16