

FORM 'H'  
FORM FOR ISSUING FIRE SAFETY CERTIFICATE  
[Refer sub - rule (1) of rule 35]  
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE  
NEW DELHI



No. F6/DFS/MS/2016/02/1433

Dated: 26/9/16

FIRE SAFETY CERTIFICATE

Certified that the M/s Gola Sizzlers (A unit of Kesari Hospitality Pvt. Ltd.) located at J - 2/14, B K Datta Market, Rajouri Garden, New Delhi - 110027 comprised of Basement, Ground plus Two Upper Floors with restaurants on Ground Plus Two Upper Floors was issued FSC vide letter no. **F.6/DFS/MS/EH/2013/573 dated 18/07/2013** was re-inspected by the officers concerned of this department on **16.09.2016** in the presence of **Mr. Mohit Nanda (Director)** and found that the said Restaurant have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rule, 2010 and that the premises is fit for occupancy class "Assembly Building" Group D of Sub Division-D 5 with effect from 26/9/16 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010 printed overleaf.

Issued on 26/9/16 at New Delhi by.

  
(Anil Garg)  
Chief Fire Officer,  
Delhi Fire Service.  


Copy to:

1. **Mr. Mohit Nanda (Director)**  
M/s Gola Sizzlers (A unit of Kesari Hospitality Pvt. Ltd.),  
J - 2/14, B K Datta Market, Rajouri Garden, New Delhi - 110027.

**Following fire safety directives must be adhered to:-**

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. Basement shall be used as per building bye laws.
7. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
8. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).

## INSPECTION REPORT

1. Name & address of the building : **Gola Sizzlers** (A unit of Kesari Hospitality Pvt. Ltd.) located at J – 2/14, B K Datta Market, Rajouri Garden, New Delhi –27. (comprised of Basement, Ground plus Two Upper Floors with restaurants on Ground Plus Two Upper Floors).
2. Type of Occupancy : Assembly
3. Type of Case : Renewal
4. Details of previous NOC : **F.6/DFS/MS/EH/2013/573 dated 18/07/2013**
5. Fire Safety directives letter No. : Nil
6. Date of inspection : 16.09.2016
7. Name of the Inspecting Officers : Mukesh Verma DO (M.N.)
8. Name and designation of officers  
From the building side : Mr. Mohit Nanda (Director)
9. Year of Construction : 2007
10. Applicant's letter No. : nil dated 29/08/2016

S. No.	Minimum Standards on fire Prevention and fire safety U/R 33	BBL Requirement	Provided at site	Remarks MR/NMR
1.	<b>Access to building</b>			
	• Road width	Accessible	Provided	M/R
	• Gate width	Accessible	Provided	M/R
	• Width of internal road	NR	NR	NR
2.	<b>Number, Width, Type &amp; Arrangement of Exits</b>			
	a. Number of staircases			
	• Upper Floors	02	02 Provided	M/R
	• Basement	02	02 Provided	M.R.
	b. Width of staircases			
	• Upper Floors	1m & 75 cm	1 m & 75 cm	M.R.
	• Basement	1m & 75 cm	1 m & 75 cm	M.R.
	c. Protection of exits			
	• Fire check door	Required in basement	Provided	M.R.
	• Pressurization	NA	NA	NA
	d. No. of continuous staircases to terrace	02	02 Provided	M/R
	e. Width of Corridor	NA	NA	NA
	f. Door size	1 m	1 m Provided	M.R
3.	<b>Compartmentation.</b>			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4.	<b>Smoke Management System.</b>			
	• Basements	30 a/c per hour Required	Provided	M.R.
	• Upper floors	12 a/c per hour Required	Provided	M.R.

5.	<b>Fire Extinguishers</b>			
	• Total numbers	06 nos.	Provided 10 nos.	M.R
	• Types	ABC & CO <sub>2</sub>	Provided	M.R
	• IS marking	ISI marked	Provided	M.R
6.	<b>First-Aid Hose Reels.</b>			
	• Total numbers on each floor	01 on each floor	Provided	M.R
	• Length of hose reel hose	30 m required	Provided	M.R
	• Nozzle diameter	5 mm	Provided	M.R
7.	<b>Automatic fire detection and alarming system.</b>			
	• Type of detectors	NA	NA	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
	• Hooter's Location	NA	NA	NA
8.	<b>MOEFA</b>	Required	Provided	M.R
9.	<b>Public Address System</b>	NA	NA	NA
10.	<b>Automatic Sprinkler system</b>	Required	Provided	M.R
	• Basement	Required	Provided	M.R
	• Upper Floor	Required	Provided	M.R
	• Sprinkler above false ceiling	Required	Provided	M.R
11.	<b>Internal Hydrants</b>			
	• Size of riser/down-comer	NA	NA	NA
	• Number of hydrants per floor	NA	NA	NA
	• Hose Box	NA	NA	NA
12.	<b>Yard Hydrants.</b>			
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA
13.	<b>Pumping Arrangements.</b>			
	<b>Ground Level</b>			
	➤ Discharge of main pump	NA	NA	NA
	➤ Head of Main pump	NA	NA	NA
	➤ Number of main pumps	NA	NA	NA
	➤ Jockey Pump out put	NA	NA	NA
	➤ Jockey pump head	NA	NA	NA
	➤ Standby pump out put	NA	NA	NA
	➤ Standby pump Head	NA	NA	NA
	➤ Auto Starting/Manual stopping	NA	NA	NA
	➤ Pump Hose Access	NA	NA	NA
	<b>Terrace level</b>			
	➤ Discharge of pump	450 LPM & 180 LPM	450 LPM , 180LPM	M.R.
	➤ Head of the pump	40 mtr each	Provided 40 mtr each	M.R.
	➤ Power supply	Required	Provided	M.R.
	➤ Auto Starting of pump	Required	Provided	M.R.

14.	<b>Captive Water Storage for fire fighting.</b>			
	<b>Underground tank capacity</b>			
	➤ Draw -off connection	NA	NA	NA
	➤ Fire service inlet	NA	NA	NA
	➤ Access to tank	NA	NA	NA
	➤ Overhead Tank Capacity	5,000 ltrs	5,000 ltrs provided	M.R.
15	<b>Exit Signage.</b>	required	Provided	M.R.
16.	<b>Provision of</b>			
	• Pressurization of Lift Shaft	NA	NA	NA
	• Pressurization of Lift lobby	NA	NA	NA
	• Communication In lift Car	NA	NA	NA
	• Fireman's Grounding Switch	NA	NA	NA
	• Lift Signage			
17.	<b>Standby power supply</b>	Required	Provided 125 KVS	M.R
18.	<b>Refuge Area</b>			
	➤ Total Area	NA	NA	NA
	➤ Location	NA	NA	NA
19.	<b>Fire Control Room</b>			
	➤ Detector System Panel	NA	NA	NA
	➤ Flow Switch Panel	NA	NA	NA
	➤ PA system Panel	NA	NA	NA
	➤ Batter backup	NA	NA	NA
	➤ Building Floor plans	NA	NA	NA
20.	Special Fire Protection Systems for Protection of special Risks, if any:			

The fire protection systems provided in the building were test checked and found functional at the time of inspection. Keeping in view the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the NOC vide letter No. **F.6/DFS/MS/EH/2013/573** dated **18/07/2013** renewal under rule 35 of the Delhi Fire Service rule 2010 is recommended.

Signature of the Inspection Officer *Mukesh Verma 21/8/16*

Name Mukesh Verma

Designation DO (West)

*Dy. CPO (West) - out of station*  
*CPO (West) 22/8/16*