

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001**

No. F6/DFS/MS/School/SZ/2016/ 1458

Dated: 28/9/16

**FIRE SAFETY CERTIFICATE**

Certified that the **Sarvodaya Kanya Vidyalaya, M.B. Road, Pushp Vihar, New Delhi**, comprised of ground plus one upper floor was granted Fire Safety Certificate by this department vide letter No. F6/DFS/MS/School/2012/3590 dated 28.09.2012. The premises was re-inspected by officer concerned of this department on 27.08.2016 in the presence of Mrs. Sneha Aggarwal, Principal of the school and found that school management have deemed complied with the fire prevention and fire safety arrangements in accordance with Directorate of Education circular No. F.16/Fire Safety/2011/13298 to 3398 dated 01.03.2011 issued by Director of Education and the building is fit for occupancy class "**Educational Building Group-B**" with effect from 28/9/ 2016 of the issue of this for a period of **Three years** subject to conditions as mentioned below.

Issued on 28/9/16..... at New Delhi by

  
Vipin Kental  
Chief Fire Officer  
Ph.: 011-23412225

**Copy to: -**

1. The Principal, Sarvodaya Kanya Vidyalaya,  
M.B. Road, Pushp Vihar, New Delhi-110017
2. The Director of Education, Govt. of NCT of Delhi,  
Old Secretariat, New Delhi.

**Conditions for the validity of Fire Safety Certificate**

1. All the fire safety and means of escape facilities shall be maintained in good working condition at all time. Any lapse rendering the fire safety or means of evacuation facilities non-functional shall be the responsibility of the management.
2. Building Sanctioning authority may verify any deviation with regard to construction/occupancy in the building. In case of any deviation, the fire safety certificate stands null & void.
3. The staff shall be trained for operating fire fighting system and mock evacuation drill be conducted at regular interval and record be maintained.
4. The basement shall be used strictly as per the provisions of Building Bye Laws.
5. The Owner/Occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules, 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).
6. The Owner/Occupier shall apply for renewal of this Fire Safety Certificate to the Director in the form 'J' [sub rule (1) of rule 37] along with copy of this certificate, six months prior to its expiry. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).

## INSPECTION REPORT

1	Name & Address of the Building	Sarvodaya Kanya Vidyalaya, M.B. Road, Pushp Vihar, New Delhi-110017		
2	Type of Occupancy	Educational Building "Group-B" (School)		
3	Building Comprised of	Ground plus one upper floor.		
4	Type of Case	Renewal		
5	Details of Previous NOC	Nil		
6	Fire Safety Directives Letter No	Circular No. F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01.03.2011		
7	Date of Inspection	27.08.2016		
8	Name of the Inspecting Officers	ADO R.N. Singh		
9	Name & Designation of Officers from the building side	Mrs. Sneh Aggarwal, Principal of the school		
10	Year of construction	2010		
11	Applicant letter No.	188 dated 04.08.2016		
<b>S. No</b>	<b>Minimum standards on Fire Prevention and Fire Safety U/R 33</b>	<b>Directorate of Education Circular dated 01.03.2011 Requirements</b>	<b>Provided at Site</b>	<b>Remarks MR/NMR</b>
<b>1</b>	<b>Access to Building.</b>			
	1. Road width	Accessible	6 m	MR
	2. Gate width	NA	NA	NA
	3. Width of internal road	NA	NA	NA
<b>2</b>	<b>Number, width, type and arrangements of exits.</b>			
	<b>a. Number of Staircase</b>			
	1. Upper floors	2 Nos.	5 Nos.	MR
	2. Basement floor	NA	NA	NA
	<b>b. Width of Staircase</b>			
	1. Upper floors	1.50 m	1No-1.50m 4 Nos.-1.80m	MR
	2. Basement floor	NA	NA	NA
	<b>c. Protection of exits</b>			
	1. Fire check door	NA	NA	NA
	2. Pressurization	NA	NA	NA
	<b>d. No. of continuous staircase to terrace</b>	1 No	1 No	NA
	<b>e. Width of corridor</b>	NA	NA	NA
	<b>f. Door size</b>	1m	1m	MR
<b>3</b>	<b>Compartmentation.</b>			
	1. Fire check door.	NA	NA	NA
	2. Sealing of electrical shafts.	NA	NA	NA
	3. Fire rating of shaft door.	NA	NA	NA
	4. Water curtain	NA	NA	NA
	5. Fire dampers.	NA	NA	NA
<b>4.</b>	<b>Smoke Management system.</b>			
	1. Basement	NA	NA	NA
	2. Upper floors	NA	NA	NA
<b>5.</b>	<b>Fire Extinguishers.</b>			
	1. Total numbers	24 Nos.	24 Nos.	MR
	2. Types	ABC/Co2	ABC - 20 Nos. Co2- 04 Nos.	MR
	3. ISI Marking	Required	Provided	MR

Renewal

SKV, M.B. Road, Pushp Vihar

N/7

<b>6.</b>	<b>First Aid Hose Reels.</b>			
	1. Total numbers on each floor.	NA	NA	NA
	2. Length of hose-reel hose.	NA	NA	NA
	3. Nozzle Diameter	NA	NA	NA
<b>7</b>	<b>Automatic Fire Detection and Alarming System.</b>			
	1. Type of detectors	NA	NA	NA
	2. Location of Main Panel	NA	NA	NA
	3. Location of Repeater Panel	NA	NA	NA
	4. Alternate source of power	NA	NA	NA
	5. Hooter's location	NA	NA	NA
<b>8.</b>	<b>MOEFA / SIREN</b>	NA	NA	NA
<b>9.</b>	<b>Public Address System</b>	NA	NA	NA
<b>10.</b>	<b>Automatic Sprinkler System</b>			
	1. Basement	NA	NA	NA
	2. Upper floors	NA	NA	NA
	3. Sprinkler above false ceiling	NA	NA	NA
<b>11.</b>	<b>Internal Hydrants.</b>			
	1. Size of Riser / Down-comer	NA	NA	NA
	2. Number of Hydrant per floor	NA	NA	NA
	3. Hose box.	NA	NA	NA
<b>12.</b>	<b>Yard Hydrants.</b>			
	1. Total number of hydrants.	NA	NA	NA
	2. Hose box.	NA	NA	NA
<b>13.</b>	<b>Pumping arrangements.</b>			
	<b>A. Ground Level</b>			
	a) Discharge of main pump.	NA	NA	NA
	b) Head of main pump.	NA	NA	NA
	c) Number of main pumps.	NA	NA	NA
	d) Jockey Pump output.	NA	NA	NA
	e) Jockey Pump head.	NA	NA	NA
	f) Standby Pump output.	NA	NA	NA
	g) Standby Pump head.	NA	NA	NA
	h) Auto Starting / Manual Stopping.	NA	NA	NA
	i) Pump house access.	NA	NA	NA
	<b>B. Terrace Level</b>			
	a) Discharge of pump.	NA	NA	NA
	b) Head of pump.	NA	NA	NA
	c) Power supply.	NA	NA	NA
	d) Auto starting of pump.	NA	NA	NA
<b>14.</b>	<b>Captive water storage for Fire Fighting.</b>			
	1. Underground tank capacity.	NA	NA	NA
	2. Draw-off connection.	NA	NA	NA
	3. Fire Service Inlet.	NA	NA	NA
	4. Access to tank.	NA	NA	NA
	5. Overhead tank capacity.	NA	NA	NA
<b>15.</b>	<b>Exit Signage.</b>	NA	NA	NA

Renewal


SKV, M.B. Road, Pushp Vihar

<b>16.</b>	<b>Provision of Lifts.</b>			
	1. Pressurization of lift shaft.	NA	NA	NA
	2. Pressurization of lift lobby.	NA	NA	NA
	3. Communication in lift car.	NA	NA	NA
	4. Fireman's switch.	NA	NA	NA
	5. Lift signage.	NA	NA	NA
<b>17</b>	<b>Standby Power Supply</b>	NA	NA	NA
<b>18.</b>	<b>Refuge Area</b>			
	1. Total area	NA	NA	NA
	2. Location	NA	NA	NA
<b>19.</b>	<b>Fire Control Room.</b>	NA	NA	NA
<b>20.</b>	<b>Special Fire Protection System for the Protection of special Risk, if any.</b>			NA

The Fire Protection system provided in the building were checked at random and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under the circular of Directorate of Education dated 01/03/2011, Fire Safety Certificate issued vide letter No. F6/DFS/MS/School/2012/3590 dated 28.09.2012, renewal under rule 37 of the Delhi Fire Service rules, 2010 is recommended


Accordingly DFA is put up for approval and signature please.

  
 Signature of the Inspecting Officer  
 Name : R.N. Singh  
 Designation: ADO



Renewal

SKV, M.B. Road, Pushp Vihar

Div. Officer (SZ)

  
6/19/16



  
  
6/19