

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110 001

NO. FC/DFS/MS/School/2016/SZ/1449

Dated: 27/9/16

FIRE SAFETY CERTIFICATE

Certified that M/s Fr. Agnel School, located at Gautam Nagar, New Delhi-110049, comprised of basement, ground plus three upper floors, owned/occupied by Fr. Agnel School, was granted Fire Safety Certificate by this department vide letter No.F6/DFS/MS/School/2013/SZ/1277, dated 03.12.2013. The premises was re-inspected by the officer concerned of this department on 08-09-2016 in the presence of Sh. Babu George, Office Executive of the school and found that the said premises have deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of Delhi Fire Service Rules 2010 and that the building is fit for occupancy class-B "Educational" with effect from 27/09/2016 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of Delhi Fire Service Rules,2010.

Issued on 27/9/16 2016 at New Delhi by

W  
26/9  
(Vipin Kental)

Chief Fire Officer

T. No.011- 23412225

OLC  
W

Copy to:-1. Director of Education, Old Secretariat, Civil Lines, Delhi-54.

2 .Principal, M/s Fr. Agnel School, located at Gautam Nagar, New Delhi-110049.

Conditions for the validity of fire safety certificate are as under:-

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. The employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All fire fighting equipments shall be maintained in perfect working condition all time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities.
5. This Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).
7. The owner/occupier shall apply for renewal of this Fire Safety Certificate, six month prior to its expiry.

### INSPECTION REPORT

1	Name & address of the building	M/s Fr. Agnel School, located at Gautam Nagar, New Delhi-110049.
2	Type of Occupancy	Educational Building "B"
3	Type of case	Renewal
4	Details of previous NOC	No.F6/DFS/MS/School/2013/SZ/1277, Dated 03.12.2013.
5	Fire safety directives letter No	No.262 to 362, Dated- 17.01.2005.
6	Date of inspection	08.09.2016.
7	Name of the inspecting Officers	A.D.O. Vedpal.
8	Name and designation of officers from the building side	Sh. Babu George, Office Exrcutive.
9	Building Comprised of	Two Blocks=Basement, ground plus three upper flooors and one bloc=Ground plus three upper floors.
10	Year of construction	1986
11	Applicant's letter No.	FASD/SO/ADM-II/716, Dated 22.08.2016.

S. NO.	Minimum Standards on fire prevention and fire safety U/R 33	Requirement as per Circular 262-362	Provided at site	Remarks MR / NMR
--------	---	-------------------------------------	------------------	------------------

<b>1</b>	<b>Access to building</b>			
	1) Road width	Accessible	9m	MR
	2) Gate width	N/A	5m (two numbers)	N/A
	3) Width of internal road	N/A		N/A

<b>2</b>	<b>Number, width Type &amp; arrangement of exits</b>			
	<b>a. Number of staircases</b>			
	1. Upper floors	02nos in each block	02nos in each block	MR
	2. basements	02nos in each block	One Block=1no. Other Block=2nos.	MR(old case)
	<b>b. Width of staircase</b>			
	1. Upper floors	Required	Block 01=1.5m & 1.5m, Block 02=1.5m & 1.5m, Block 03=1.5m & 70cm	MR(old case)
	2. basements	Required	One Block=1.5m, Other Block=83cm & 1.45m ramp	MR(old case)
	<b>c. Protection of exits</b>			
	1. Fire check door	N/A	N/A	N/A
	2. Pressurization	N/A	N/A	N/A
	<b>d. No. of continuous staircase to terrace</b>	Required	01no. In each block having ground plus one upper floor.	MR
	<b>e. Width of corridor</b>	N/A	N/A	N/A
	<b>f. Door size</b>	Required	1Mtr Provided	MR

<b>3</b>	<b>Compartmentation.</b>			
	1. Fire check door	N/A	N/A	N/A
	2. Sealing of electrical shafts	N/A	N/A	N/A
	3. Fire Rating of shaft door	N/A	N/A	N/A
	4. water curtain	N/A	N/A	N/A
	5. Fire dampers	N/A	N/A	N/A

<b>4</b>	<b>Smoke Management system.</b>			
	basement	N/A	Exhaust fans provided	N/A
	Upper Floors		Exhaust fans provided in hall	N/A

<b>5</b>	<b>Fire Extinguishers</b>			
	total numbers	50nos	50nos.	MR
	Types	ABC, WCO2 & CO2	ABC & Water CO2	MR
	ISI marking	ISI Mark	ISI Mark	MR

<b>6</b>	<b>First-Aid Hose Reels.</b>			
	total numbers on each floor	05nos.	05nos at each floor	MR
	Length of Hose reel hose	30m	30m	MR
	Nozzle Diameter	6.5mm	6.5mm	MR

7	<b>Automatic fire detection and alarming system</b>			
	Type of detectors	N/A	N/A	N/A
	location of Main Panel	N/A	N/A	N/A
	location of Repeater panel	N/A	N/A	N/A
	Alternate source of power	N/A	N/A	N/A
	hooter's location	N/A	N/A	N/A
8	<b>MOEFA</b>	N/A	Provided	N/A
9	<b>Public Address System.</b>	N/A	Provided	N/A
10	<b>Automatic Sprinkler System.</b>			
	basement	Required	Provided	MR
	upper floors	N/A	N/A	N/A
	sprinkler above false ceiling	N/A	N/A	N/A
11	<b>Internal Hydrants</b>			
	Size of riser/down-corner	100mm	100mm	MR
	Number of Hydrants per floor	05nos.	05nos at each floor	MR
	hose Box	05nos.	05nos at each floor	MR
12	<b>Yard Hydrants.</b>			
	total number of hydrants	N/A	N/A	N/A
	hose box	N/A	N/A	N/A
13	<b>Pumping arrangements</b>			
	<b>1. Ground level</b>	N/A	N/A	N/A
	a. Discharge of main Pump	N/A	N/A	N/A
	b. Head of main pump	N/A	N/A	N/A
	c. Number of main pumps	N/A	N/A	N/A
	d. jockey pump out put	N/A	N/A	N/A
	e. jockey pump head	N/A	N/A	N/A
	f. Standby Pump output	N/A	N/A	N/A
	g. Stanby Pump head	N/A	N/A	N/A
	h. Auto Starting/Manual stopping	N/A	N/A	N/A
	pump house access	N/A	N/A	N/A
	<b>2. Terrace level</b>			
	a. Discharge of pump	450+180LPM	900 +900LPM	MR
	b. head of the pump	40m(each)	40m(each)	MR
	c. Power supply	Required	Provided	MR
	d. Auto starting of pump	Required	Provided	MR
14	<b>Captive water storage for fire fighting</b>			
	1. Underground tank capacity	50000Liters	50000Liters	MR
	a. Draw-off connection	N/A	N/A	N/A
	b. fire service inlet	N/A	Provided	N/A
	c. Access to tank	N/A	N/A	N/A
	Over head tank Capacity	5000Liters	15000 Liters (each)on two blocks having basements	MR
15	<b>Exit Signage.</b>	Required	Provided	MR
16	<b>Provision of lifts.</b>			
	a. Pressurization of lift shaft	N/A	N/A	N/A
	b. pressurization of lift lobby	N/A	N/A	N/A
	c. communication in lift car	N/A	N/A	N/A
	d. Fireman's grounding switch	N/A	N/A	N/A
	e. Lift signage	N/A	N/A	N/A
17	<b>Standby power supply</b>	N/A	N/A	N/A
18	<b>Refuge Area.</b>	Not Required		
	total area	N/A	N/A	N/A
	location	N/A	N/A	N/A
19	<b>Fire control room</b>			
	a. detector system Panel	N/A	N/A	N/A
	b. Flow switch Panel	N/A	N/A	N/A
	c. PA system Panel	N/A	N/A	N/A
	d. Batter backup	N/A	N/A	N/A
	e. Building floor plans	N/A	N/A	N/A

N/R

20

Special Fire Protection systems for protection of special risks, if any: N/A

The fire protection systems provided in the building were test checked at random and found functional at the time of inspection. In view of the deemed compliance of the minimum standards on fire prevention and fire safety required under circular of Director of Education dated 17.01.2005, the NOC issued vide letter No: F6/DFS/MS/School/2013/SZ/1277, dated 03.12.2013, renewal under rule 37 of the Delhi Fire Service Rule 2010 is recommended.

Accordingly DFA is put up for your approval and signature please.


 12/9/16

Signature of the inspecting officer


Name: Vedpal

Designation : ADO

~~D.O. (S.D)~~

 16/9/16

~~dy (FO) (Rw)~~

 19/9/16