

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110 001

No. PG/DFS/MS/2016/ND2/1486

Dated: 28/9/16

FIRE SAFETY CERTIFICATE

Certified that the AL ISLAH Public School is running at ground plus one floor of a building comprising of ground plus two upper floors at B-124, Gali No.4, Babu Nagar, Delhi-94 owned/occupied by AL ISLAH Public School have complied with the fire prevention and fire safety requirements in accordance with the circular no.F-16/Estate/CC/FS/2011/3298 to 3398 dated 01/03/11 issued by the Director of Education and verified by the officer concerned of this department on 26/08/16 in the presence of Mr.Sarif (Principal) of the school and found that the GF+FF of building is fit for occupancy class B 'Educational Building' for with effect from ^{28/9/16} for a period of **three** years, subject to conditions printed overleaf.

Issued on 28/9/16 at New Delhi by


27/9
(Vipin Kental)
Chief Fire Officer



To,
The Principal,
AL ISLAH Public School,
B-124, Gali No.4, Babu Nagar, Delhi-94

Copy:-
Dy. Director of Education,
Anand Vihar Delhi

CONDITIONS :

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities.
5. This Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction/unauthorized use of land if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in

N/A

- 1. Name & address of the building : AL ISLAH Public School, at B-124, Gali No.4, Babu Nagar, Delhi-94.
- 2. Building is comprised of : G+2 (School running at Ground plus first floor only)
- 3. Type of Occupancy : Educational 2nd floor is being used as residence
- 4. Type of Case : New
- 5. Details of Previous NOC letter : Nil
- 6. Fire Safety direction letter No : F16/Estate/CC/FireSafety/2011/3298 to 3398 dt-01/03/11
- 7. Date of Inspection : 26/08/16
- 8. Name of the Inspecting officers : ADO R.K. Yadav
- 9. Name and designation of Officer from the building side : Mr. Sarif (Principal)
- 10. Year of Construction : 1995
- 11. Applicant's letter No : Date 25/07/16


Sr. No	Minimum Standards on Fire Prevention and Fire Safety U/R33	Circular/ Requirement	Provided at Site	Remarks MR/NMR
01	Access to Building			
	• Road width	06 m.	06 m.	MR ✓
	• Gate width	4.5 m.	4.5 m.	MR ✓
	• Width of internal road	N/A	N/A	N/A
02	Number, Width, Type and Arrangement of Exits			
	a. Number of Staircases			
	• Upper floor	02 no.	02 no.	MR
	• Basement	N/A	N/A	N/A
	b. Width of Staircases			
	• Upper floor	1.50 m	One no. 1.0 m & II nd no. .90 m	MR ✓
	• Basement	N/A	N/A	N/A
	c. Protection of Exits			
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	d. No. of Continuous Staircases to Terrace	01 no.	01 no.	MR ✓
	e. Width of Corridor	1.50 m	1.50 m	MR ✓
	f. Door Size	01 m	01 m	MR ✓
03	Compartmentation.			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire rating of shaft door	N/A	N/A	N/A
	• Water curtain	N/A	N/A	N/A
	• Fire dampers	N/A	N/A	N/A
04	Smoke Management System.			
	• Basement	N/A	N/A	N/A
	• Upper floor	N/A	N/A	N/A
05.	Fire Extinguishers			
	• Total numbers	04 nos.	04 nos.	MR ✓
	• types	ABC /CO ₂	ABC /CO ₂	MR ✓
	• IS marking	ISI marked	ISI marked	MR ✓

06	First-Aid-Hose Reels.			
	Total numbers on each floor	N/A	N/A	N/A
	• Length of hose reel hose	N/A	N/A	N/A
	• Nozzle diameter	N/A	N/A	N/A
07	Automatic Fire Detection and Alarming System.			
	• Type of detectors	N/A	N/A	N/A
	• Location of main panel	N/A	N/A	N/A
	• Location of repeater panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooter's location	N/A	N/A	N/A
08	MOEFA			
09	Public Address System.			
10	Automatic Sprinkler System.			
	• Basement	N/A	N/A	N/A
	• upper floor	N/A	N/A	N/A
	• sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants			
	• size of riser/down-comer	N/A	N/A	N/A
	• Number of hydrants per floor	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
12	Yard Hydrants.			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
13	Pumping Arrangements.			
	➤ Ground Level			
	• Discharge of main Pump	N/A	N/A	N/A
	• Head of Main Pump	N/A	N/A	N/A
	• Number of main pumps	N/A	N/A	N/A
	• Jockey pump out put	N/A	N/A	N/A
	• Jockey pump head	N/A	N/A	N/A
	• Standby pump out put	N/A	N/A	N/A
	• Standby pump Head	N/A	N/A	N/A
	• Auto Starting /Manual stopping	N/A	N/A	N/A
	• Pump House Access	N/A	N/A	N/A
	➤ Terrace Level			
	• Discharge of pump	N/A	N/A	N/A
	• Head of the Pump	N/A	N/A	N/A
	• Power supply	N/A	N/A	N/A
	• Auto Starting of pump	N/A	N/A	N/A
14	Captive Water Storage for Fire Fighting:			
	• Underground tank capacity	N/A	N/A	N/A
	• Draw-off connection	N/A	N/A	N/A
	• Fire service inlet	N/A	N/A	N/A
	• Access to tank	N/A	N/A	N/A
	• Overhead Tank capacity	N/A	N/A	N/A
15	Exit Signage.			
		N/A	N/A	N/A

16	Provision of Lifts.			
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication in lift car	N/A	N/A	N/A
	• Firemen's grounding switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A
17	Standby power supply	N/A	N/A	N/A
18	Refuge Area.			
	• Total area	N/A	N/A	N/A
	• Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector system panel	N/A	N/A	N/A
	• Flow switch panel	N/A	N/A	N/A
	• PA system panel	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection systems for protection of special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were tested checked and found functional at the time of inspection.

Keeping in view the compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rule 2010.


 Signature of the Inspecting Officer
 Name : R.K.Yadav
 Designation : ADO(LN)

DO(ED)

Handwritten signature
08/9/16

Handwritten signature
DUFO(AD2)

Handwritten signature
9/9