

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110 001

No. FG/DFS/MS/2016/1467

Dated: 03/10/2016

FIRE SAFETY CERTIFICATE

Certified that the Shree Laxmi Narayan Sewa Ashram Trust (Regd.), Mandawali Fazalpur (Near Balco Society Mkt.) Delhi-92 Comprised of Basement, ground plus two upper floors owned/occupied by Shree Laxmi Narayan Sewa Ashram Trust have complied with the fire prevention and fire safety requirements in accordance with rules 33 of the Delhi Fire Service Rules, 2010 and verified by the officer concerned of Fire Service on 27/08/16 in the presence of Mr. R.S. Negi (Manager) of the Community Hall and that the building is fit for occupancy class "D" 'Assembly Building' with effect from.... for a period of **three** years in accordance with the rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010, printed overleaf.

Issued on 03/10/16 at New Delhi by


(Vipin Kental)
Chief Fire Officer

To,
Manager,
Shree Laxmi Narayan Sewa Ashram Trust (Regd.),
Mandawali Fazalpur (Near Balco Society Mkt.) Delhi..

Copy to:-

1. The Deputy Health Officer (EDMC),
SHD (N)-Zone, Health Department,
Delhi-110032

CONDITIONS :

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities.
5. This Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction /unauthorized use of land if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in.
7. The owner / occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule (37)] along with a copy of this Certificate, six months prior to its expiry.

- INSPECTION REPORT N/16
1. Name & address of the building : Shree Laxmi Narayan Sewa Ashram Trust (Regd.)
Mandawali Fazalpur (Near Balco Society Mkt.) Delhi.
 2. Building is comprised of : B+G+2 Upper floors
 3. Type of Occupancy : Assembly (Banquet Hall)
 4. Type of Case : New Case
 5. Details of Previous NOC : Nil
 6. Fire Safety direction letter No : F6/DFS/MS/BP/2004/72 Dated-12/01/04
 7. Date of Inspection : 27/08/16
 8. Name of the Inspecting Officers: : R.K.Yadav (ADO)
 9. Name of the designation of Officer
from the building side : R.S.Negi (Manager)
 10. Year of Construction : 2004
 11. Applicant's letter No : dated 01/08/16

S.No	Minimum Standards on fire prevention and fire safety U/R33	Requirement /NBC	Provided at Site	Remarks MR/NMR
1	Access to building			
	Road width	6 m	18 m	MR ✓
	Gate width	4.5 m	4.5 m	MR ✓
	Width of internal road	N.A.	N.A.	N.A.
2	Number, Width, Type and Arrangement of Exits			
	a. Number of Staircases			
	Upper Floor	2 no.	2 no.	MR ✓
	Basement	2 no.	2 no.	MR ✓
	b. Width of Staircases			
	Upper Floor	1.5 m	1.5 m each	MR ✓
	Basement	1.5 m	1.5 m each	MR ✓
	c. Protection of exits			
	Fire check door	Required	provided	MR ✓
	Pressurization	Required	provided	MR ✓
	e. No. of continuous staircases to terrace	2 no.	2 no.	MR ✓
	g. Width of Corridor	N.A.	N.A.	N.A.
h. No. of door	2 no.	2 no.	MR ✓	
i. Door Size	2 m	2 m, 1.10m & 1.60 m	MR ✓	
3	Compartmentation.			
	Fire check door	Required	provided	MR ✓
	Sealing of electrical shafts	Required	Provided	MR ✓
	Fire rating of shaft door	N.A.	N.A.	N.A.
	Water curtain	N.A.	N.A.	N.A.
	Fire Dampers	N.A.	N.A.	N.A.
4	Smoke Management System.			
	Basement	Ventilated	provided	MR ✓
	Upper floor	Ventilated	Ventilated	MR ✓
5	Fire Extinguisher			
	Total numbers	10 no.	provided	MR ✓
	types	CO ₂ & ABC	provided	MR ✓
	IS marking	ISI marked	provided	MR ✓

6	First-aid-Hose Reels.			
	Total numbers of each floor	1 no.	Provided	MR
	Length of hose reel hose	30 m	Provided	MR
	Nozzle diameter	5 mm	Provided	MR
7	Automatic fire detection and alarming system.			
	Type of detectors	Required	Provided	MR
	Location of main panel	Required	Provided	MR
	Location of repeater panel	Required	Provided	MR
	Alternate source of power	Required	Provided	MR
	Hooters's location	Required	Provided	MR
8	MOEFA	Required	provided	MR
9	Public address System.	N.A.	N.A.	N.A.
10	Automatic Sprinkler System.			
	basement	Required	Provided	MR
	upper floor	Required	provided	MR
	sprinkler above false ceiling	Required	provided	MR
11	Internal Hydrants			
	size of riser/down-comer	100 mm	Provided	MR
	Total no. of hydrants each floor	1 no.	Provided	MR
	Hose Box per floor	1 no.	Provided	MR
12	Yard Hydrants.			
	Total number of hydrants	Required	provided	MR
	Hose Box	Required	provided	MR
13	Pumping Arrangements.			
	<ul style="list-style-type: none"> • Ground Level ➤ Discharge of main Pump ➤ Head of Main Pump ➤ Number of main pumps ➤ Jockey pump out put ➤ Jockey pump head ➤ Standby pump out put ➤ Standby pump Head ➤ Auto Starting /Manual stopping ➤ Pump House Access • Terrace Level ➤ Discharge of pump ➤ Head of the Pump ➤ Power supply ➤ Auto Starting of pump 			
		900 Lpm	Provided	MR
		40 M	Provided	MR
		1 No.	Provided	MR
		180 Lpm	provided	MR
		40 M	provided	MR
		900 Lpm	provided	MR
		40 M	provided	MR
		Required	Manual	MR
		N.A.	N.A.	N.A.
		900 LPM	Provided	MR
		40 m	Provided	MR
		Required	Provided	MR
		Required	provided	MR
14	Captive Water Storage for Fire Fighting.			
	Underground tank capacity	50,000 Liters	Provided	MR
	Draw-off connection	Required	Provided	MR
	Fire service inlet	Required	provided	MR
	Access to tank	Required	provided	MR
	Overhead Tank capacity	10,000 Liters	Provided	MR
15	Exit Signage.	Required	Provided	MR

N/8

16	Provision of Lifts.			
	Pressurization of Lift Shaft	Required	Provided	MR
	Pressurization of Lift lobby	Required	provided	MR
	Communication in lift car	Required	Provided	MR
	Firemen's grounding switch	Required	provided	MR
	Lift Signage	Required	Provided	MR
17	Standby power supply	Required	Provided	MR
18	Refuge Area.			
	Total area	N.A.	N.A.	N.A.
	Location	N.A.	N.A.	N.A.
19	Fire Control Room			
	Detector system panel	N.A.	N.A.	N.A.
	Flow switch panel	N.A.	N.A.	N.A.
	PA system panel	N.A.	N.A.	N.A.
	Batter backup	N.A.	N.A.	N.A.
	Building Floor Plans	N.A.	N.A.	N.A.
20	Special Fire Protection systems for protection of special Risks, if any:	N.A.	N.A.	N.A.

The fire extinguishers provided in the building were tested/ checked and found functional at the time of inspection.

Keeping in view the compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rule 2010.

Signature of the Inspecting Officer

Name- R.K. Yadav

Designation- ADO (LN)

~~DO(ED)~~

Line
08/9

DO(ED)

DO
9/9

46/cd NO2
1st 9/16/4/16.

C.F/O.

M. Scell

FTD.

W
15/9.

Sir, FT letter is put up for signature please

R.K. Yadav