

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001**

No. F6/DFS/MS/School/SZ/2016/ 1480

Dated: 05/10/16

**FIRE SAFETY CERTIFICATE**

Certified that the **S.D.M.C. Primary Boys School, Rangpuri, New Delhi-110037**, comprised of ground plus one upper floor Owned/Occupied by SDMC was issued Fire Safety Certificate by this department vide letter No. F6/DFS/MS/School/2012/3109 dated 27/08/2012. The premises was re-inspected by officer concerned of this department on 17.09.2016 in the presence of Mr. Anil Kumar (Principal) of the school and found that school have deemed complied with the fire prevention and fire safety arrangements in accordance with Directorate of Education circular No. F.16/Fire Safety/2011/13298 to 3398 dated 01.03.2011 issued by Director of Education and the building/premises is fit for occupancy class "**Educational Building Group-B**" with effect from 05/10/ 2016 of the issue of this certificate for a period of **Three years** subject to conditions as mentioned below.

Issued on .....05/10/16..... at New Delhi by

310.  
Vipin Kental  
Chief Fire Officer  
Ph.: 011-23412225

**Copy to: -**

1. The Principal, SDMC, Primary Boys School, Rangpuri, New Delhi-110037
2. The Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi.

**Conditions for the validity of Fire Safety Certificate**

1. All the fire safety and means of escape facilities shall be maintained in good working condition at all time. Any lapse rendering the fire safety or means of evacuation facilities non-functional shall be the responsibility of the management.
2. Building Sanctioning authority may verify any deviation with regard to construction/occupancy in the building. In case of any deviation, the fire safety certificate stands null & void.
3. The staff shall be trained for operating fire fighting system and mock evacuation drill be conducted at regular interval and record be maintained.
4. The basement shall be used strictly as per the provisions of Building Bye Laws.
5. The Owner/Occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules, 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).
6. The Owner/Occupier shall apply for renewal of this Fire Safety Certificate to the Director in the form 'J' [sub rule (1) of rule 37] along with copy of this certificate, six months prior to its expiry. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).

N/S

**INSPECTION REPORT**

1	Name & Address of the Building	SDMC Primary Boys School, Rangpuri, New Delhi-37		
2	Type of Occupancy	Educational Building "Group-B" (School)		
3	Building Comprised of	Ground + One Upper Floor		
4	Type of Case	Renewal		
5	Details of Previous NOC	F6/DFS/MS/School/2012/3109 Dated 27/08/2012		
6	Fire Safety Directives Letter No	F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01.03.2011		
7	Date of Inspection	17.09.2016		
8	Name of the Inspecting Officers	ADO R.N. Singh		
9	Name & Designation of Officers from the building side	Mr. Anil Kumar, Principal		
10	Year of construction	2003		
11	Applicant letter No.	Nil dated 22/08/2016		
<b>S. No</b>	<b>Minimum standards on Fire Prevention and Fire Safety U/R 33</b>	<b>Directorate of Education Circular Requirements</b>	<b>Provided at Site</b>	<b>Remarks MR/NMR</b>
<b>1</b>	<b>Access to Building.</b>			
	1. Road width	Accessible	6 Mts.	MR
	2. Gate width	NA	4 Mtr	NA
	3. Width of internal road	NA	NA	NA
<b>2</b>	<b>Number, width, type and arrangements of exits.</b>			
	<b>a. Number of Staircase</b>			
	1. Upper floors	2 No.	3 No.	MR
	2. Basement floor	NA	NA	NA
	<b>b. Width of Staircase</b>			
	1. Upper floors	1.50 Mts. / 0.75 Mts.	1.80 1.30 & 1.30 m	MR
	2. Basement floor	NA	NA	NA
	<b>c. Protection of exits</b>			
	1. Fire check door	NA	NA	NA
	2. Pressurization	NA	NA	NA
	<b>d. No. of continuous staircase to terrace</b>	NA	NA	NA
	<b>e. Width of corridor</b>	NA	NA	NA
	<b>f. Door size</b>	1 Mtr	1 Mtr	MR
<b>3</b>	<b>Compartmentation.</b>			
	1. Fire check door.	NA	NA	NA
	2. Sealing of electrical shafts.	NA	NA	NA
	3. Fire rating of shaft door.	NA	NA	NA
	4. Water curtain	NA	NA	NA
	5. Fire dampers.	NA	NA	NA
<b>4.</b>	<b>Smoke Management system.</b>			
	1. Basement	NA	NA	NA
	2. Upper floors	NA	NA	NA
<b>5.</b>	<b>Fire Extinguishers.</b>			
	1. Total numbers		11 Nos.	MR
	2. Types	ISI Marked	ABC- 10, Co2- 01	MR
	3. ISI Marking		Provided	MR
<b>6.</b>	<b>First Aid Hose Reels.</b>			
	1. Total numbers on each floor.	NA	NA	NA
	2. Length of hose-reel hose.	NA	NA	NA
	3. Nozzle Diameter	NA	NA	NA

Renewal

SDMC Primary Boys School, Rangpuri

Ri

7 Automatic Fire Detection and Alarming system.				
	1. Type of detectors	NA	NA	NA
	2. Location of Main Panel	NA	NA	NA
	3. Location of Repeater Panel	NA	NA	NA
	4. Alternate source of power	NA	NA	NA
	5. Hooter's location	NA	NA	NA
8.	MOEFA	NA	NA	NA
9.	Public Address System	NA	NA	NA
10.	Automatic Sprinkler System			
	1. Basement	NA	NA	NA
	2. Upper floors	NA	NA	NA
	3. Sprinkler above false ceiling	NA	NA	NA
11.	Internal Hydrants.			
	1. Size of Riser / Down-comer	NA	NA	NA
	2. Number of Hydrant per floor	NA	NA	NA
	3. Hose box.	NA	NA	NA
12.	Yard Hydrants.			
	1. Total number of hydrants.	NA	NA	NA
	2. Hose box.	NA	NA	NA
13.	Pumping arrangements.			
	1. Ground Level			
	a) Discharge of main pump.	NA	NA	NA
	b) Head of main pump.	NA	NA	NA
	c) Number of main pumps.	NA	NA	NA
	d) Jockey Pump output.	NA	NA	NA
	e) Jockey Pump head.	NA	NA	NA
	f) Standby Pump output.	NA	NA	NA
	g) Standby pump head.	NA	NA	NA
	h) Auto Starting / Manual Stopping.	NA	NA	NA
	2. Terrace Level			
	a) Discharge of pump.	NA	NA	NA
	b) Head of pump.	NA	NA	NA
	c) Power supply.	NA	NA	NA
	d) Auto starting of pump.	NA	NA	NA
14.	Captive water storage for Fire Fighting.			
	1. Underground tank capacity.	NA	NA	NA
	2. Draw-off connection.	NA	NA	NA
	3. Fire Service Inlet.	NA	NA	NA
	4. Access to tank.	NA	NA	NA
	5. Overhead tank capacity.	NA	NA	NA
15.	Exit Signage.	Required NA	Provided	MR NA
16.	Provisions of Lifts.			
	1. Pressurization of lift shaft.	NA	NA	NA
	2. Pressurization of lift lobby.	NA	NA	NA
	3. Communication in lift car.	NA	NA	NA
	4. Fireman's switch.	NA	NA	NA
	5. Lift signage.	NA	NA	NA
17	Standby Power Supply	NA	NA	NA
18.	Refuge Area			
	1. Total area	NA	NA	NA
	2. Location	NA	NA	NA

N)7

<b>19.</b>	<b>Fire Control Room.</b>			
	1. Detector System Panel.	NA	NA	NA
	2. Flow Switch Panel.	NA	NA	NA
	3. PA system Panel.	NA	NA	NA
	4. Battery backup	NA	NA	NA
	5. Building floor plan	NA	NA	NA
<b>20.</b>	<b>Special Fire Protection System for the Protection of special Risk, if any.</b>			NA
<p>The Fire Protection system provided in the building were checked and found functional at the time of inspection.</p> <p>In view of the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under the rules, the FSC issued vide letter No. F6/MS/DFS/School/2013/135 dated 02/04/2013, renewal under rule 37 of the Delhi Fire Service rules, 2010 is recommended</p> <p>Accordingly, DFA is put up for approval and signature please.</p>				
				<p><i>[Signature]</i> 20/9/16</p> <p>Signature of the Inspecting Officer Name: R.N. Singh Designation: ADO</p>

Renewal

SDMC Primary Boys School, Rangpuri

Div. Officer (SD)

*[Signature]*  
20/9/16

*[Signature]*  
22/9/16

277/cfo s2  
20/9/16/4/A

CFOC S27  
*[Signature]*

FTM.

m-spell

*[Signature]*  
22/9.