

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110 001

No.

F6/DFS/MS/EH/2016/1482

Dated:

05/10/16

FIRE SAFETY CERTIFICATE

Certified that M/s Rhythm Restaurant located at 50/8, 1st Floor, Yusuf Sarai, Main Market, New Delhi-110016, comprised of Basement, Ground plus two upper floors but restaurant is at 1st floor only, owned/occupied by M/ Rhythm Restaurant was granted FSC by this department vide letter No. F6/DFS/MS/EH/2013/SZ/646, dated 29-07-2013. The premises was re-inspected by the officer concerned of this department on 22-09-2016 in the presence of Sh. Raj Kumar Sharma and found that the said eating house at 1st floor only have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class "D" Restaurant with effect from 05/10/2016 for period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 05/10/2016 at New Delhi by

(Vipin Kental)

Chief Fire Officer

T.No.011-23412225

Copy to:- 1. The Dy. Health Officer, Health Deptt. South MCD, Green Park, New Delhi.
2. M/S Rhythm Restaurant at 50/8, 1st Floor, Yusuf Sarai, Main Market, New Delhi-110016.

Conditions for the validity of fire safety certificate are as under:-

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. The employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All fire fighting equipments shall be maintained in perfect working condition all time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities.
5. This Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in.
7. The owner/occupier shall apply for renewal of this Fire Safety Certificate, six month prior to its expiry.

N/17

INSPECTION REPORT

1. Name & address of the building : M/s Rhythm Restaurant at 50/8, 1st Floor, Yusaf Sarai, Main Market, New Delhi-110016.
2. Building is comprised of : Basement, Ground plus two upper floors.
(Restaurant is at 1st floor only).
3. Type of Occupancy : Group-D, Assembly Building.
4. Type of Case : Old Case
5. Details of Previous NOC : No.F.6/MS/DFS/EH/2013/SZ/646, dated-29.07.13.
6. Fire Safety direction letter No : Circular No.718, dated 4.4.2005.
7. Date of Inspection : 22.09.2016
8. Name of the Inspecting Officers: : Vedpal (ADO)
9. Name and designation of Officer
from the building side : Sh. Raj Kumar Sharma (Owner)
10. Year of Construction : 2000.
11. Applicant's letter No : No.Nil, dated 22.08.16.

S.No	Minimum Standards on fire prevention and fire safety U/R33	Requirements as per circular 4.4.2005	Provided at Site	Remarks
1	Access to building			
	Road width	Accessible	18m	MR
	Gate width	N.A.	N.A.	N.A.
	Width of internal road	N.A.	N.A.	N.A.
2	Number, Width, Type and Arrangement of Exits.			
a. Number of Staircases Upper Floor Basement B. Width of Staircases Upper Floor Basement c. Protection of exits Fire check door Pressurization e. No. of continuous staircases to terrace g. Width of Corridor h. Door Size				
	02nos.	02nos.		MR
	N.A.	N.A.		N.A.
	Required	1.11m & 72cm		MR(old case)
	N.A.	N.A.		N.A.
	N.A.	N.A.		N.A.
	N.A.	N.A.		N.A.
	N.A.	N.A.		N.A.
	01no.	01no.		MR
	N.A.	N.A.		N.A.
	Required 2nos.	1.22m & 90cm		MR(old case)
	3	Compartmentation		
Fire check door Sealing of electrical shafts Fire rating of shaft door Water curtain Fire Dampers	N.A.	N.A.		N.A.
	N.A.	N.A.		N.A.
	N.A.	N.A.		N.A.
	N.A.	N.A.		N.A.
	N.A.	N.A.		N.A.
4	Smoke Management System.			
Basement Upper floor	30a/c per hour	N.A.		N.A.
	12 a/c per hour	Exhaust fans Provided		MR
5.	Fire Extinguisher			
Total numbers types IS marking	04 nos.	06 nos.		MR
	CO ₂ & ABC	CO ₂ & ABC		MR
	ISI marked	ISI marked		MR
6	First-aid-Hose Reels.			
Total numbers on each floor Length of hose reel hose	01no.	01no.		MR
	30m	30m		MR

7	Automatic fire detection and alarming system			
	Type of detectors	N.A.	N.A.	N.A.
	Location of main panel	N.A.	N.A.	N.A.
	Location of repeater panel	N.A.	N.A.	N.A.
	Alternate source of power	N.A.	N.A.	N.A.
	Hooters	N.A.	N.A.	N.A.
8	MOEFA	Required	Provided	MR
9	Public address System.	N.A.	Provided	N.A.
10	Automatic Sprinkler System.			
	Basement	N.A.	N.A.	N.A.
	upper floor	Required	Provided	MR
	sprinkler above false ceiling	N.A.	N.A.	N.A.
11	Internal Hydrants			
	size of riser/down-comer	100mm	100mm	MR
	Number of hydrants per floor	01no.	01no.	MR
	Hose Box	01no.	01no.	MR
12	Yard Hydrants.			
	Total number of hydrants	N.A.	N.A.	N.A.
	Hose Box	N.A.	N.A.	N.A.
13	Pumping Arrangements.			
	• Ground Level	N.A.	N.A.	N.A.
	➤ Discharge of main Pump	N.A.	N.A.	N.A.
	➤ Head of Main Pump	N.A.	N.A.	N.A.
	➤ Number of main pumps	N.A.	N.A.	N.A.
	➤ Jockey pump out put	N.A.	N.A.	N.A.
	➤ Jockey pump head	N.A.	N.A.	N.A.
	➤ Standby pump out put	N.A.	N.A.	N.A.
	➤ Standby pump Head	N.A.	N.A.	N.A.
	➤ Auto Starting /Manual stopping	N.A.	N.A.	N.A.
	➤ Pump House Access	N.A.	N.A.	N.A.
	• Terrace Level	Required	Provided	MR
	➤ Discharge of pump	450LPM	450LPM	MR
	➤ Head of the Pump	40m	35m	MR(old case)
	➤ Power supply	Required	Provided	MR
	➤ Auto Starting of pump	Required	Provided	MR
14	Captive Water Storage for Fire Fighting.			
	On ground tank capacity	N.A.	N.A.	N.A.
	Draw-off connection	N.A.	N.A.	N.A.
	Fire service inlet	N.A.	N.A.	N.A.
	Access to tank	N.A.	N.A.	N.A.
	Overhead Tank capacity	5000Ltrs.	5000Litrs	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.			
	Pressurization of Lift Shaft	N.A.	N.A.	N.A.
	Pressurization of Lift lobby	N.A.	N.A.	N.A.
	Communication in lift car	N.A.	N.A.	N.A.
	Firemen's grounding switch	N.A.	N.A.	N.A.
	Lift Signage	N.A.	N.A.	N.A.
17	Standby power supply	Required	Provided 50Kva Generator set	MR
18	Refuge Area.			
	Total area	N.A.	N.A.	N.A.
	Location	N.A.	N.A.	N.A.

N/19

M/S Rhythm Restaurant at 50/8, 1st Floor, Yusuf Sarai, Main Market, New Delhi-110016.

19	Fire Control Room	N.A.	N.A.	N.A.
	Detector system panel	N.A.	N.A.	N.A.
	Flow switch panel	N.A.	N.A.	N.A.
	PA system panel	N.A.	N.A.	N.A.
	Batter backup	N.A.	N.A.	N.A.
	Building Floor Plans	N.A.	N.A.	N.A.
20	Special Fire Protection systems for of special Risks, if any:	N.A.	N.A.	N.A.

The fire protection systems provided in the building were test checked at random and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards on fire prevention and fire safety required under the rules the FSC issued vide letter No.F.6/DFS/MS/EH/2013/SZ/646, dated 29.07.2013 renewal under rule 37 of the Delhi Fire Service Rule 2010 is recommended. Shortcomings communicated vide letter dated 30.08.16 have been complied at serial numbers 13, 14 & 15.

Accordingly DFA is put up for your approval and signature please.

[Signature]
22/9/16

Signature of the Inspecting Officer
Name : Vedpal
Designation : ADO

~~D.O. (S.D)~~
[Signature]
23/9/16

28/08/16
27/9



[Signature]
27/9

[Signature]
27/9

CFA 24/9

PTM.

M-SCM
[Signature]
26/9