

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS, DELHI FIRE SERVICE, CONNAUGHT PLACE,  
NEW DELHI-110001**


No.: F6/MS/DFS/EH/ 2016/1486

Dated:- 06/10/16

**FIRE SAFETY CERTIFICATE**

Certified that the banquet in the name & style **TARANG Banquet Hall** at Ground floor of the building comprised of comprised of basement, ground plus two upper floors at A-9/136, Road No. 56, Gazipur Village, Delhi – 96, owned/occupied by M/s Tarang Gardens and Banquets Pvt. Limited was granted FSC by this department vide letter no.F6/DFS/MS/EH/2013/NDZ/982 dated 27.09.2013. The premises was inspected by the officer concerned of this department on 29.09.16 in the presence of Sh.Vijay Malik (Director) and found that the said Assembly building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the building is fit for occupancy Group D (Assembly Building), with effect from ....06/10/2016 for period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010, printed overleaf .

Issued .....06/10/16.....at New Delhi by.

  
(Vipin Kental)  
Chief Fire Officer  
Delhi Fire Service

Copy to:-

1. The Dy. Health Officer,  
East Delhi Municipal Corporation,  
Health Department, Shahdara (South) Zone,  
Karkardooma, Delhi.
2. Sh. Vijay Malik (Director),  
TARANG Banquet Hall,  
A-9/136, Road No. 56, Gazipur Village, Delhi – 96.

**CONDITIONS:**

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities.
5. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).
6. This Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction/ unauthorized use of land if any.

1. Name & address of the building: Tarang Banquet Hall at A-9/136, Road No. 56, Gazipur Village, Delhi-96.
2. Type of Occupancy : Assembly *at G.F only*
3. Type of Case : Renewal
4. Details of previous NOC : F6/DFS/MS/EH/2013/NDZ/982 Dated 27/09/13
5. Fire Safety directives letter No : F.6/DFS/MS/BP/2013/2135 dated: 02.09.13
6. Date of inspection : 29/09/2016
7. Name of the Inspecting Officers : DO S K Dua
8. Name and designation of officers  
from the building side : Sh. Vijay Malik (Director)
9. Year of Construction : 2008
10. Applicant's letter No. : Letter no. NIL dated 19/09/2016


S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR
1	<b>Access to building</b>			
	• Road width	12 Mtrs.	40 Mtrs.	MR
	• Gate width	4.5 Mtrs.	4.5 Mtrs.	MR
	• Width of internal road	N/A	N/A	N/A
2	<b>Number, Width, Type &amp; Arrangement of Exits</b>			
	a. Number of staircases	2 Nos.	2 Nos.	MR
	• Upper Floors	2 Nos.	2 Nos.	MR
	• Basements	2 Nos. <i>or</i>	2 Nos.	MR
	b. Width of staircases	1.5 M & 1.15 M	1.5 M & 1.15 M	MR (old case)
	• Upper Floors	1.5 M & 1.15 M	1.5 M & 1.15 M	MR (old case)
	• Basements	1.5 M & 1.15 M	1.5 M & 1.15 M	MR (old case)
	c. Protection of exits			
	• Fire check door	Required	Provided	MR
	• Pressurization	N/A	N/A	N/A
	e. No. of continuous staircases to terrace	1 No.	1 No.	MR
	g. Width of Corridor	N/A	N/A	N/A
	h. Door Size	2.0 Mtr.	3 Nos of 2.0 M	MR
3	<b>Compartmentation.</b>			
	• Fire check door	Required	Provided	MR
	• Sealing of electrical shafts	Required	Provided	MR
	• Fire Rating of shaft door	N/A	N/A	N/A
	• Water Curtain	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A
4	<b>Smoke Management System.</b>			
	• Basements	30 a/c per hour	Exhaust Fan	MR
	• Upper floors	12 a/c per hour	Provided	MR
5	<b>Fire Extinguishers</b>			
	• Total numbers		10 Nos.	MR

	<ul style="list-style-type: none"> <li>IS marking</li> </ul>	ISI marked	Provided	MR
6	<b>First-Aid Hose Reels.</b>			
	<ul style="list-style-type: none"> <li>Total numbers on each floor</li> </ul>	Required	1 No.	MR (old case)
	<ul style="list-style-type: none"> <li>Length of hose reel hose</li> </ul>	30 m	30 m	MR (old case)
	<ul style="list-style-type: none"> <li>Nozzle diameter</li> </ul>	5 mm	5 mm	MR (old case)
7	<b>Automatic fire detection and alarming system.</b>			
	<ul style="list-style-type: none"> <li>Type of detectors</li> </ul>	Heat/Smoke	Provided	MR
	<ul style="list-style-type: none"> <li>Location of Main Panel</li> </ul>	Required	Provided at reception	MR
	<ul style="list-style-type: none"> <li>Location of Repeater Panel</li> </ul>	Required	Provided	MR
	<ul style="list-style-type: none"> <li>Alternate source of power</li> </ul>	Required	D.G. Set	MR
	<ul style="list-style-type: none"> <li>Hooters' Location</li> </ul>			
8	<b>MOEFA</b>	Required	Provided	MR
9	<b>Public Address System.</b>	Not Required	Provided	MR
10	<b>Automatic Sprinkler System.</b>			
	<ul style="list-style-type: none"> <li>Basement</li> </ul>	Required	Provided	MR
	<ul style="list-style-type: none"> <li>Upper Floor</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>Sprinkler above false ceiling</li> </ul>	N/A	N/A	N/A
11	<b>Internal Hydrants</b>			
	<ul style="list-style-type: none"> <li>Size of riser/down-comer</li> </ul>	100 mm	100 mm	MR (old case)
	<ul style="list-style-type: none"> <li>Number of hydrants per floor</li> </ul>	01 No.	01 No.	MR (old case)
	<ul style="list-style-type: none"> <li>Hose Box</li> </ul>	01 No.	01 No.	MR (old case)
12	<b>Yard Hydrants.</b>			
	<ul style="list-style-type: none"> <li>Total number of hydrants</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>Hose Box</li> </ul>	N/A	N/A	N/A
13	<b>Pumping Arrangements.</b>			
	<ul style="list-style-type: none"> <li>Ground Level</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>➤ Discharge of main Pump</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>➤ Head of Main pump</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>➤ Number of main pumps</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>➤ Jockey Pump out put</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>➤ Jockey pump head</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>➤ Standby Pump out put</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>➤ Standby Pump Head</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>➤ Auto Starting/ Manual stopping</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>➤ Pump House Access</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>Terrace level</li> </ul>	1620 LPM	1620 LPM & 450 LPM	MR (old case)
	<ul style="list-style-type: none"> <li>➤ Discharge of pump</li> </ul>	40 M	40 M	MR
	<ul style="list-style-type: none"> <li>➤ Head of the pump</li> </ul>	Required	Electricity	MR
	<ul style="list-style-type: none"> <li>➤ Power Supply</li> </ul>	Required	Auto	MR
	<ul style="list-style-type: none"> <li>➤ Auto Starting of pump</li> </ul>			
14	<b>Captive Water Storage for fire fighting.</b>			

	<ul style="list-style-type: none"> <li>Underground tank capacity</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>➤ Draw-off connection</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>➤ Fire service inlet</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>➤ Access to tank</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>Overhead Tank capacity</li> </ul>	20,000 Ltrs.	20,000 Ltrs.	MR
15	<b>Exit Signage.</b>	Required	Provided	MR
16	<b>Provision of Lifts.</b>			
	<ul style="list-style-type: none"> <li>Pressurization of Lift Shaft</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>Pressurization of Lift lobby</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>Communication In lift Car</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>Fireman's Grounding Switch</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>Lift Signage</li> </ul>	N/A	N/A	N/A
17	<b>Standby power supply</b>	Required	D.G. Set	MR
18	<b>Refuge Area.</b>			
	<ul style="list-style-type: none"> <li>➤ Total Area</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>➤ Location</li> </ul>	N/A	N/A	N/A
19	<b>Fire Control Room</b>			
	<ul style="list-style-type: none"> <li>Detector System Panel</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>Flow Switch Panel</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>PA System Panel</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>Batter backup</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>Building Floor Plans</li> </ul>	N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of special Risks, if any:	Required	HT & LT panel protected with local application i.e. Co2 fire extinguishers	MR

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under the rules. The Fire Safety Certificate issued vide letter no. F.6/DFS/MS/EH/2013/NDZ/982 dated 27/09/13 renewal under rule 35 of the Delhi Fire Service Rule 2010 is recommended.


  
Signature of the Inspecting Officer

Name S.K. Dua

Designation Div. Officer

(i) DFA signed  
(ii) The compliance of short comings may be mentioned in for note also.

51/d/NDZ  
5/10/16/10

  
DCFO (NDZ)

FT for  
msell  
2/5/10