

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110 001

No.

FR/DFS/MS/School/2016/NO2/1493

Dated:

10/10/16

FIRE SAFETY CERTIFICATE

Certified that the Greenway International School is running at ground plus one floor of a building comprising of basement, ground plus one upper floors at Block-A, Vivak Vihar Delhi was issued NOC vide letter No F6/MS/DFS/06/2332 dated 05.09.06. The school building was inspected by the officer concerned of this department on 07/12/2015 in the presence of Mrs. Somya Sachdeva (Principal) of the school and found that the school building have deemed complied with the fire prevention and fire safety requirements in accordance with Circular F16/Estate/CC/Fire safety/2011/3298 to 3398 dated 01/03/11 issued by Director of Education and the school building is fit for occupancy class "B" 'Educational Building' for ground +1floor except basement only with effect from 10/10/16 for a period of **three** years, subject to conditions, printed overleaf.

Issued on 10/10/16 at New Delhi by

(Vipin Kental)
Chief Fire Officer
Delhi Fire Service

To,

The Principal,
Greenway International School,
Block-A, Vivak Vihar Delhi-95.

Copy to:-

The Director of Education, EDMC,
Udyog Sadan, Plot No. 419, FIE,
Patparganj Industrial Area, Delhi-92.

CONDITIONS

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities.
5. This Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction /unauthorized use of land if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on
7. The basement shall not be used for any purpose of will remain sealed/closed till the compliance of shortcoming communicated by letter dt 03/06/16.
8. The owner / occupier shall apply for renewal of this Fire Safety Certificate of the Director in Form 'J' [sub rule (1) of rule (37)] along with a copy of this Certificate, Six Months prior to its expiry

- N/4
1. Name & address of the building : Greenway International School at Block-A, Vivak Vihar Delhi-95.
 2. Building is comprised of : B+G+1 upper floor (School running at G+1 floor only & basement is closed) *(Photo placed in file in between C-20 & C-21)*
 3. Type of Occupancy : Educational
 4. Type of Case : Renewal
 5. Details of Previous NOC letter : F6/MS/DFS/06/2332 dated 05.09.06 for GF+FF
 6. Fire Safety Circular No. : F.16/Estate/CC/FS/2011/3298 to 3398 dated 1.3.11
 7. Date of Inspection : 26.09.2016
 8. Name of the Inspecting officers : ADO R.K. Yadav
 9. Name and designation of Officer from the building side : Mrs. Sania Sachdeva (Principal)
 10. Year of Construction : 2002
 11. Applicant's letter No : Dated 27.09.2016

NO	Minimum Standards on fire prevention and fire safety as per circular no.3298 to 3398 dt-01.03.11	Requirement	Provided at Site	Remarks
1	Access to building			
	• Road width	06 M	06 M	MR
	• Gate width	N/A	N/A	N/A
	• Width of internal road	N/A	N/A	N/A
2	Number, Width, Type and Arrangement of Exits			
	a. Number of Staircases			
	• Upper Floor	01 Nos.	02 Nos.	MR
	• Basement	N/A	N/A	N/A
	B. Width of Staircases			
	• Upper Floor	1.5 M	1.45 M, 80 M	MR
	• Basement	N/A	N/A	N/A
	c. Protection of exits			
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	e. No. of continuous staircases to terrace	1 No.	1 No.	MR
	g. Width of Corridor	1.5 M	1.5 M	MR
	h. Door Size	1.0 M	1.0 M	MR
	Compartmentation.			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire rating of shaft door	N/A	N/A	N/A
	• Water curtain	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A
4	Smoke Management System.			
	• Basement	N/A	N/A	N/A
	• Upper floor	N/A	N/A	N/A
5.	Fire Extinguishers			
	• Total numbers	06 Nos.	06 Nos.	MR ✓
	• types	ABC & Co2	ABC & Co2	MR ✓
	• IS marking	ISI marked	ISI marked	MR ✓

N/2

6	First-aid-Hose Reels.			
	Total numbers of each floor	N/A	02 No.	MR
	• Length of hose reel hose	N/A	30 m	MR
	• Nozzle diameter	N/A	05 mm	MR
7	Automatic fire detection and alarming system.			
	• Type of detectors	N/A	N/A	N/A
	• Location of main panel	N/A	N/A	N/A
	• Location of repeater panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooter's location	N/A	N/A	N/A
8	MOEFA	N/A	N/A	N/A
9	Public address System.	N/A	N/A	N/A
10	Automatic Sprinkler System.	N/A	Provided	MR
	• Basement	N/A	N/A	N/A
	• upper floor	N/A	N/A	N/A
	• sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants	N/A	N/A	N/A
	• size of riser/down-comer	N/A	N/A	N/A
	• Number of hydrants per floor	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
12	Yard Hydrants.	N/A	N/A	N/A
	• Total number of hydrants	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
13	Pumping Arrangements.	N/A	N/A	N/A
	• Ground Level	N/A	N/A	N/A
	➤ Discharge of main Pump	N/A	N/A	N/A
	➤ Head of Main Pump	N/A	N/A	N/A
	➤ Number of main pumps	N/A	N/A	N/A
	➤ Jockey pump out put	N/A	N/A	N/A
	➤ Jockey pump head	N/A	N/A	N/A
	➤ Standby pump out put	N/A	N/A	N/A
	➤ Standby pump Head	N/A	N/A	N/A
	➤ Auto Starting /Manual stopping	N/A	N/A	N/A
	➤ Pump House Access	N/A	N/A	N/A
	• Terrace Level	N/A	N/A	N/A
	➤ Discharge of pump	450LPM	Provided	MR
	➤ Head of the Pump	40 M	Provided	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto Starting of pump	Required	Provided	MR
14	Captive Water Storage for Fire Fighting.			
	• Underground tank capacity	N/A	N/A	N/A
	➤ Draw-off connection	N/A	N/A	N/A
	➤ Fire service inlet	N/A	N/A	N/A
	➤ Access to tank	N/A	N/A	N/A
	• Overhead Tank capacity	10,000 Liters	Provided	MR
5	Exit Signage.	N/A	Provided	MR




N/13

16	Provision of Lifts.	N/A	N/A	N/A
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication in lift car	N/A	N/A	N/A
	• Firemen's grounding switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A
17	Standby power supply	N/A	N/A	N/A
18	Refuge Area.	N/A	N/A	N/A
	• Total area	N/A	N/A	N/A
	• Location	N/A	N/A	N/A
19	Fire Control Room	N/A	N/A	N/A
	• Detector system panel	N/A	N/A	N/A
	• Flow switch panel	N/A	N/A	N/A
	• PA system panel	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection systems for protection of special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were tested/checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules. The NOC issued vide letter no. F6/MS/DFS/06/2332 dated 05.09.06 renewal under the circular no. F.16/Estate/CC/FS/2011/3298 to 3398 dated 1.3.11 is recommended Fire Safety Certificate.




Signature of the Inspecting Officer

Name: R. K. Yadav

Designation: ADO(LN)

~~DO(ED)~~


26/9/2016