

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110 001

No. F.6/DFS/MS/EH/2016/SZ/ 1498

Dated: 10/10/16

FIRE SAFETY CERTIFICATE

Certified that the M/s Spice Market Restaurant, GF-17-18 & First Floor 18, D-2, Southern Park, District Centre, Saket, New Delhi-110017, comprised of 2 tier Basements, Ground floor & 5 Upper Floors, but the Restaurant is running on Ground Floor & First Floor only was granted FSC by this department vide letter No.F6/MS/DFS/EH/2013/SZ/660 dated 01/08/2013. The premises was re-inspected by the officer concerned of this department on 19/09/16 in the presence of Mr. I. D. Sharma and found that the restaurant have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class **Group- D Assembly Building** with effect from ~~10/10/16~~ 10/10/16-2016 for a period of **three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule-38 of the Delhi Fire Service Rules, 2010.

Issued on.....10/10/16.....at New Delhi by.

(Vipin Kental)
Chief Fire Officer
Tel: 011-23412225

Copy to:-

1. The Joint Commissioner of Police (Lic.), First Floor, P.S. Defence Colony, New Delhi-110049
2. The Dy. Health Officer, Central Zone, MCD, Lajpat Nagar Road, New Delhi
3. M/s Spice Market Restaurant, GF-17-18 & First Floor 18, D-2, Southern Park, District Centre, Saket, New Delhi-110017

Conditions for the validity of fire safety certificate:

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of firefighting system.
4. The owner/ occupier shall submit a declaration every year in Form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
5. This fire safety certificate may not in any way be treated as regularization of unauthorized construction, if any.
6. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry."

INSPECTION REPORT

1. Name & address of the building: Spice Market Restaurant, GF-17-18 & First Floor 18, D-2, Southern Park, District Centre, Saket, New Delhi-110017
2. Type of Occupancy : Group D Assembly Building (Eating House)
3. Type of Case : Renewal [Restaurant is running in Ground Floor & First Floor]
4. Details of Previous NOC : F6/MS/DFS/EH/2013/SZ/660 dated 01/08/2013
5. Fire Safety directives letter No : Nil [Building is 2B+G+ 5 Upper Floors]
6. Date of inspection : 19/9/2016
7. Name of Inspecting Officer : A.K. Malik
8. Name and designation of officers
From the building side : Mr. I. D. Sharma
9. Year of Construction : 2010
10. Applicant's letter No. : Nil dated 17/08/2016 [Outdoor diary no.8231 dated 22/08/2016]

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC/BBL Requirement	Provided at site	Remarks MR/NMR
1.	Access to building [Southern Park Mall FSC No. of F6/MS/DFS/SZ/Mercantile/2015/1415 dated 04/08/15]			
	<ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 	Restaurant within Mall	As Above	MR
2.	Number, Width, Type & Arrangement of Exits [Provided & Maintained by Mall management]			
	a. Number of staircases			
	<ul style="list-style-type: none"> • Upper Floors • Basements 	2 Nos Restaurant within Mall	2 Nos As Above	MR NA
	b. Width of staircases			
	<ul style="list-style-type: none"> • Upper Floor • Basement 	1.5m Restaurant within Mall	1.5m As Above	MR NA
	c. Protection of exits			
	<ul style="list-style-type: none"> • Fire check door • Pressurization 	Restaurant within Mall Restaurant within Mall	As Above As Above	NA NA
	d. No. of continuous staircases to terrace	Restaurant within Mall	As Above	NA
	e. Width of Corridor	Restaurant within Mall	As Above	NA
	f. Door Size	Restaurant within Mall	As Above	NA
		Required	Two Exits Provided	MR
3.	Compartmentation			
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 	Restaurant within Mall Restaurant within Mall Restaurant within Mall Restaurant within Mall Restaurant within Mall	As Above As Above As Above As Above As Above	NA NA NA NA NA
4.	Smoke Management System [Provided & Maintained by Mall management]			
	<ul style="list-style-type: none"> • Basements • Upper floors 	30 ACPH 12 ACPH	As Above As Above	NA MR
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total numbers • Types • IS marking 	6 No's ISI marked	8 Nos ABC-6No's CO ₂ -2 No's	MR MR MR
6.	First-Aid Hose Reels [Provided & Maintained by Mall management]			
	<ul style="list-style-type: none"> • Total numbers on each floor • Length of hose reel hose • Nozzle diameter 	One (Near to Restaurant) 30 m 5 mm	As Above As Above As Above	MR MR MR
7.	Automatic fire detection and alarming system [Provided & Maintained by Mall management]			
	<ul style="list-style-type: none"> • Type of detectors • Location of Main Panel 	NA NA	As Above As Above	NA NA

8. Name and designation of officers : Mr. I. D. Sharma
 From the building side : Mr. I. D. Sharma
 9. Year of Construction : 2010
 10. Applicant's letter No. : Nil dated 17/08/2016[Outdoor diary no.8231 dated 22/08/2016]

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC/BBL Requirement	Provided at site	Remarks MR/NMR
1.	Access to building [Sothern ParkMall FSC No. of F6/MS/DFS/SZ/Mercantile/2015/1415 dated 04/08/15]			
	<ul style="list-style-type: none"> Road width Gate width Width of internal road 	Restaurant within Mall	As Above	MR
2.	Number, Width, Type & Arrangement of Exits [Provided & Maintained by Mall management]			
	a. Number of staircases			
	<ul style="list-style-type: none"> Upper Floors Basements 	2 Nos Restaurant within Mall	2 Nos As Above	MR NA
	b. Width of staircases			
	<ul style="list-style-type: none"> Upper Floor Basement 	1.5m Restaurant within Mall	1.5m As Above	MR NA
	c. Protection of exits			
	<ul style="list-style-type: none"> Fire check door Pressurization 	Restaurant within Mall Restaurant within Mall	As Above As Above	NA NA
	d. No. of continuous staircases to terrace	Restaurant within Mall	As Above	NA
	e. Width of Corridor	Restaurant within Mall	As Above	NA
	f. Door Size	Restaurant within Mall	As Above	NA
		Required	Two Exits Provided	MR
3.	Compartmentation			
	<ul style="list-style-type: none"> Fire check door Sealing of electrical shafts Fire Rating of shaft door Water Curtain Fire Dampers 	Restaurant within Mall Restaurant within Mall Restaurant within Mall Restaurant within Mall Restaurant within Mall	As Above As Above As Above As Above As Above	NA NA NA NA NA
4.	Smoke Management System [Provided & Maintained by Mall management]			
	<ul style="list-style-type: none"> Basements Upper floors 	30 ACPH 12 ACPH	As Above As Above	NA MR
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> Total numbers Types IS marking 	6 No's ISI marked	8 Nos ABC-6No's CO ₂ -2 No's	MR MR MR
6.	First-Aid Hose Reels [Provided & Maintained by Mall management]			
	<ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter 	One (Near to Restaurant) 30 m 5 mm	As Above As Above As Above	MR MR MR
7.	Automatic fire detection and alarming system [Provided & Maintained by Mall management]			
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location 	NA NA NA NA NA	As Above As Above As Above As Above As Above	NA NA NA NA NA
8.	MOEFA	Required	Provided	MR
9.	Public Address System	NA	As Above	NA
10.	Automatic Sprinkler System [Provided & Maintained by Mallmanagement]			
	<ul style="list-style-type: none"> Basement 	NA	As Above	NA

	➤ Discharge of main Pump	NA	NA	NA
	➤ Head of Main pump	NA	NA	NA
	➤ Number of main pumps	NA	NA	NA
	➤ Jockey Pump out put	NA	NA	NA
	➤ Jockey pump head	NA	NA	NA
	➤ Standby Pump out put	NA	NA	NA
	➤ Standby Pump Head	NA	NA	NA
	➤ Auto Starting/Manual Stopping	NA	NA	NA
	➤ Pump House Access	NA	NA	NA
	• Terrace level	NA	NA	NA
	➤ Discharge of pump	[Provided & Maintained by Mall management]		
	➤ Head of the pump	450 LPM	As Above	MR
	➤ Power Supply	40 M	As Above	MR
	➤ Auto Starting of pump	Required	As Above	MR
		Required	As Above	MR
14.	Captive Water Storage for firefighting [Provided & Maintained by Mall management]			
	• Underground tank capacity	NA	As Above	NA
	➤ Draw-off connection	NA	As Above	NA
	➤ Fire service inlet	NA	As Above	NA
	➤ Access to tank	NA	As Above	NA
	• Overhead Tank capacity	10,000 Lts	As Above	MR
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts. [Provided & Maintained by Mall management]			
	• Pressurization of Lift Shaft	NA	NA	NA
	• Pressurization of Lift lobby	NA	NA	NA
	• Communication In lift Car	NA	NA	NA
	• Fireman's Grounding Switch	NA	NA	NA
	• Lift Signage	NA	NA	NA
17.	Standby power supply	Required	Provided	MR
18.	Refuge Area. [Provided & Maintained by Mall management]			
	➤ Total Area	NA	NA	NA
	➤ Location	NA	NA	NA
19.	Fire Control Room [Provided & Maintained by Mall management]			
	• Detector System Panel	NA	NA	NA
	• Flow Switch Panel	NA	NA	NA
	• PA System Panel	NA	NA	NA
	• Batter backup	NA	NA	NA
	• Building Floor Plans	NA	NA	NA
20.	Special Fire Protection System for Protection of special Risks, if any:	NA	NA	NA


The fire protection systems provided in the building were randomly tested, checked and found functional at the time of inspection.

N/13-

Spice Market Restaurant, GF-17-18 & First Floor 18, D-2, Southern Park, District Centre, Saket, New Delhi-110017

Keeping in view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules , It is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010.

Accordingly FSC in shape of DFA is put up for approval.


7/8/16

Signature of Inspecting Officer

Name:- A.K. Malik

Designation:- DO (SZ)